

UNIVERSITY-OXFORD, MS, USA

WMO: 720541

Lat: 34.383N

Lon: 89.550W

Elev: 138

StdP: 99.68

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 53806

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-5.2	-16.0	0.9	-3.9	-12.6	1.3	-1.5	8.5	6.4	7.8	6.3	1.3	0	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	33.9	23.6	32.8	23.9	32.3	23.8	25.7	31.3	25.3	30.8	24.8	30.0	2.2	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.3	27.8	23.7	18.9	27.5	22.9	18.0	26.8	79.9	31.1	78.0	30.3	75.7	30.4	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.1	5.3	-12.0	35.9	3.2	1.4	-14.3	36.9	-16.1	37.6	-17.9	38.4	-20.2	39.4		
			-12.7	27.0	2.9	0.9	-14.8	27.6	-16.5	28.1	-18.1	28.6	-20.2	29.2		
				</												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	4.9	7.1	11.1	16.4	20.5	24.9	26.0	25.7	23.1	16.0	9.9	6.7
	DBStd	8.85	5.94	6.25	5.62	4.34	4.02	2.33	2.22	2.25	3.45	4.69	5.11	5.39
	HDD10.0	565	180	120	56	5	1	0	0	0	0	6	63	134
	HDD18.3	1802	418	314	229	86	28	0	0	0	5	104	255	363
	CDD10.0	2779	21	40	90	196	326	448	497	487	393	191	61	31
	CDD18.3	977	1	1	6	27	95	198	238	228	148	31	2	1
	CDH23.3	8714	0	4	41	214	744	1846	2264	2058	1281	252	8	2
	CDH26.7	3478	0	0	3	27	210	766	989	882	533	69	0	0
Wind	WSAvg	1.9	2.4	2.6	2.5	2.4	2.0	1.6	1.4	1.3	1.4	1.6	1.9	2.2
Precipitation	PrecAvg	1430	125	127	143	137	141	103	103	88	97	91	135	151
	PrecMax	2128	321	349	408	469	334	339	282	289	254	329	302	506
	PrecMin	924	9	24	34	27	18	6	25	12	11	0	30	12
	PrecStd	299	74	74	74	81	80	74	58	54	57	66	77	92
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.3	23.7	27.2	28.8	32.1	34.9	35.1	35.1	34.9	32.1	24.9	22.8
		MCWB	15.9	17.5	17.5	19.9	21.7	22.7	24.5	24.4	22.2	20.8	17.6	18.4
	2%	DB	18.6	21.4	24.1	27.4	30.1	32.9	33.7	33.8	33.0	28.0	22.4	20.0
		MCWB	15.2	16.3	16.5	18.5	21.5	24.0	24.6	24.0	22.4	20.3	16.0	17.5
	5%	DB	17.0	19.0	22.4	26.1	28.9	32.3	32.6	32.5	32.3	26.2	20.2	17.7
		MCWB	13.8	15.2	15.4	17.9	21.1	23.9	24.7	24.0	22.4	18.8	16.1	15.8
	10%	DB	14.0	17.4	20.0	24.0	27.6	31.0	32.0	31.3	30.0	23.8	18.0	15.9
		MCWB	11.1	13.4	14.5	17.0	20.4	23.6	24.5	23.7	22.3	18.5	14.3	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	18.9	18.9	21.4	23.6	25.8	26.4	26.4	25.2	23.4	20.2	19.5
		MCDB	19.5	21.2	23.8	26.3	27.9	31.4	32.0	32.7	30.5	28.4	21.8	21.5
	2%	WB	16.0	17.6	17.9	20.3	22.7	25.3	25.7	25.6	24.3	22.3	18.5	17.8
		MCDB	18.0	19.6	22.0	24.7	27.7	31.1	31.2	31.4	29.7	26.8	20.6	19.3
	5%	WB	14.1	15.8	16.9	19.4	22.1	24.8	25.4	25.1	23.6	21.0	17.0	16.4
		MCDB	15.9	18.8	20.7	23.6	27.3	30.2	30.8	30.4	28.8	24.0	19.0	17.9
	10%	WB	12.3	14.2	15.8	18.6	21.5	24.2	24.9	24.5	23.0	19.5	15.2	14.1
		MCDB	13.5	16.4	19.3	22.8	26.1	29.0	30.1	29.4	27.9	22.6	18.1	15.4
Mean Daily Temperature Range	5% DB	MDBR	10.7	10.9	11.8	12.2	10.9	10.8	10.2	10.7	11.5	12.2	12.0	9.6
		MCDBR	12.5	12.4	13.2	13.0	11.8	12.3	11.2	11.9	13.6	13.8	13.1	10.7
		MCWBR	9.2	8.2	7.2	6.0	4.8	4.6	4.0	4.2	4.5	6.5	7.9	8.2
	5% WB	MCDBR	10.5	10.8	11.1	9.9	9.9	10.5	10.2	10.1	10.5	10.8	9.6	9.7
		MCWBR	9.0	7.7	7.3	5.5	4.7	4.7	3.9	4.1	4.3	6.0	7.4	8.2
Clear-Sky Solar Irradiance	taub	0.315	0.322	0.359	0.392	0.429	0.457	0.500	0.498	0.428	0.368	0.335	0.315	
	taud	2.516	2.494	2.414	2.312	2.261	2.195	2.113	2.105	2.296	2.438	2.479	2.529	
	Ebn at Noon	897	928	915	894	861	833	795	789	833	863	862	874	
	Edh at Noon	83	94	111	128	137	146	158	156	123	99	85	78	
All-Sky Solar Radiation	RadAvg	2.49	2.99	4.16	5.27	5.93	6.42	6.12	5.67	4.92	3.92	2.83	2.14	
	RadStd	0.21	0.41	0.38	0.34	0.33	0.38	0.34	0.37	0.39	0.50	0.29	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page