

LAGO VISTA, TX, USA

WMO: 720542

Lat: 30.500N

Lon: 97.967W

Elev: 375

StdP: 96.90

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00166

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	-0.2	-12.3	1.4	3.7	-9.9	1.7	6.1	8.9	10.1	8.2	11.4	3.1	0	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.3	37.5	21.5	36.5	21.9	35.5	22.3	24.8	29.6	24.5	29.4	24.1	29.1	3.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.7	25.8	23.4	19.0	25.6	22.9	18.5	25.6	77.3	29.8	75.8	29.5	74.6	29.0	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	7.1	6.1	DB	-6.0	39.9	2.3	1.4	-7.7	40.9	-9.0	41.7	-10.3	42.4	-12.0	43.4	(4)
(5)			WB	-7.6	25.6	2.1	0.8	-9.1	26.2	-10.3	26.7	-11.5	27.1	-13.0	27.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	10.5	12.8	16.9	20.6	24.1	28.0	29.4	29.9	26.6	21.3	15.7	11.4	(6)	
	DBStd	7.97	5.37	6.16	4.99	3.75	3.25	1.96	1.76	1.93	2.93	4.52	5.18	5.32	(7)	
	HDD10.0	170	59	38	10	0	0	0	0	0	0	1	14	48	(8)	
	HDD18.3	879	245	168	84	21	4	0	0	0	1	26	108	222	(9)	
	CDD10.0	4053	76	118	224	319	438	539	600	617	498	351	183	91	(10)	
	CDD18.3	1722	3	14	40	91	183	289	342	359	249	117	28	7	(11)	
	CDH23.3	17712	20	68	233	624	1519	3161	4166	4518	2416	852	114	21	(12)	
(13)	CDH26.7	8360	1	12	37	169	572	1514	2208	2487	1092	253	14	1	(13)	
(14)	Wind	WSAvg	3.2	3.3	3.5	3.6	3.7	3.5	3.2	3.0	2.9	2.6	3.0	3.1	3.2	(14)
(15) Precipitation	PrecAvg	866	61	50	69	75	100	87	57	51	81	98	75	62	(15)	
	PrecMax	1401	194	171	173	186	345	248	201	193	268	396	285	328	(16)	
	PrecMin	403	0	2	0	13	3	6	0	0	5	0	0	4	(17)	
	PrecStd	251	49	42	41	45	71	63	51	52	57	94	69	64	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.9	28.1	29.8	32.6	35.1	37.8	38.5	39.1	37.3	33.0	28.6	25.7	(19)	
		MCWB	15.3	15.1	17.4	18.9	22.1	21.2	21.8	21.8	20.3	20.0	20.9	17.4	(20)	
	2%	DB	22.9	25.4	27.5	30.5	32.7	36.0	37.3	37.6	35.2	31.1	26.3	23.0	(21)	
		MCWB	14.3	15.5	17.0	19.2	21.6	22.0	21.7	21.8	21.5	21.6	18.2	17.4	(22)	
	5%	DB	20.9	23.0	26.1	28.6	31.4	34.7	36.1	37.0	33.6	29.7	24.7	21.3	(23)	
		MCWB	14.2	16.1	16.9	19.3	21.4	22.5	22.0	22.0	21.6	20.5	18.0	16.8	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	18.7	21.2	24.1	27.1	30.1	32.9	35.0	35.9	32.4	27.7	22.7	19.8	(25)	
		MCWB	13.1	16.2	16.6	18.3	21.2	22.6	22.4	22.3	21.5	19.3	18.0	16.0	(26)	
	0.4%	WB	19.0	20.6	21.0	23.2	24.7	25.5	25.1	25.2	25.1	24.5	22.9	20.9	(27)	
		MCDB	21.1	22.6	24.2	27.4	29.3	30.1	31.3	30.2	28.0	27.5	25.7	22.5	(28)	
	2%	WB	17.8	19.6	20.2	22.2	23.9	24.7	24.6	24.5	24.5	23.8	21.7	19.5	(29)	
		MCDB	20.4	21.7	23.4	26.2	28.4	29.4	30.3	29.9	28.1	26.7	23.8	21.6	(30)	
(31) Mean Daily Temperature Range	5%	WB	16.2	18.6	19.5	21.4	23.3	24.2	24.1	24.1	24.0	23.0	20.4	18.1	(31)	
		MCDB	18.8	20.6	22.8	25.3	27.8	29.3	29.6	29.8	28.0	26.1	22.6	20.4	(32)	
	10%	WB	14.7	17.2	18.7	20.7	22.7	23.9	23.9	23.8	23.6	22.2	19.1	16.6	(33)	
		MCDB	17.8	19.9	22.2	24.6	27.2	29.0	29.3	29.6	27.7	25.8	21.8	18.9	(34)	
	5% DB	MDBR	10.6	10.3	10.9	10.7	10.1	10.3	10.9	11.3	10.2	10.3	9.8	9.5	(35)	
		MCDBR	13.0	11.4	12.1	12.3	11.5	11.8	12.2	12.4	11.7	10.8	10.2	10.9	(36)	
(37) Clear-Sky Solar Irradiance	5% WB	MCWBR	7.3	6.7	5.6	5.4	3.9	2.6	2.5	2.6	3.1	4.0	5.2	7.1	(37)	
		MCDBR	10.3	9.0	9.8	9.5	9.1	9.5	10.5	10.9	9.4	9.0	8.6	9.8	(38)	
	Edh at Noon	MCWBR	8.0	7.5	6.3	5.2	3.7	2.7	2.6	2.5	2.7	4.9	6.5	8.2	(39)	
		MCDBR	8.0	7.5	6.3	5.2	3.7	2.7	2.6	2.5	2.7	4.9	6.5	8.2	(39)	
(40) All-Sky Solar Radiation	taub		0.314	0.324	0.348	0.387	0.425	0.414	0.426	0.416	0.393	0.364	0.344	0.312	(40)	
	taud		2.525	2.505	2.447	2.357	2.301	2.376	2.382	2.390	2.403	2.472	2.464	2.540	(41)	
	Ebn at Noon		921	943	937	906	869	873	861	868	878	886	876	906	(42)	
	Edh at Noon		87	97	110	125	133	122	121	119	113	99	92	82	(43)	
(44)	RadAvg		3.06	3.57	4.58	5.49	5.80	6.66	6.70	6.33	5.20	4.26	3.22	2.70	(44)	
	RadStd		0.33	0.60	0.42	0.50	0.55	0.47	0.54	0.34	0.48	0.61	0.39	0.36	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+80

Nomenclature: See separate page