

CARSON, NV, USA

WMO: 720549

Lat: 39.192N

Lon: 119.734W

Elev: 1432

StdP: 85.26

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 00171

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.1	-9.1	-18.9	0.8	3.4	-17.3	1.0	3.3	10.6	7.3	9.0	6.6	0.4	330	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	34.7	14.6	33.0	14.2	32.3	14.0	16.3	30.2	15.6	29.1	15.0	28.3	4.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	10.7	18.9	10.2	9.2	19.2	8.9	8.4	19.2	50.9	29.6	48.6	28.6	46.5	28.7	18.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.9	7.1	-16.1	37.0	2.5	1.7	-17.9	38.2	-19.4	39.2	-20.7	40.2	-22.5	41.4		
(5)			-16.1	17.8	2.8	0.6	-18.1	18.2	-19.8	18.6	-21.4	18.9	-23.4	19.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	1.8	3.0	6.8	9.8	13.3	19.1	22.9	21.9	17.8	11.1	5.4	1.1		
	DBStd	8.40	4.34	4.76	3.64	3.75	3.53	3.75	2.52	2.13	3.61	3.70	4.30	4.68		
	HDD10.0	1078	253	199	110	48	11	2	0	0	3	30	146	276		
	HDD18.3	2948	511	430	358	256	159	34	1	1	49	226	389	533		
	CDD10.0	1519	1	2	11	42	113	274	400	370	236	63	7	1		
	CDD18.3	347	0	0	0	0	2	57	142	113	32	1	0	0		
	CDH23.3	6161	0	0	2	24	156	1122	2154	1831	803	69	0	0		
	CDH26.7	2762	0	0	0	2	27	475	1082	865	295	17	0	0		
(14) Wind	WSAvg	2.4	1.8	2.3	2.7	3.0	2.8	2.8	2.3	2.1	2.1	2.1	2.0	2.1		
(15) Precipitation	PrecAvg	341	61	51	46	22	20	13	6	7	8	21	28	59		
	PrecMax	646	167	117	166	64	67	50	21	31	55	102	75	195		
	PrecMin	161	11	10	6	5	2	0	0	0	0	2	1	6		
	PrecStd	112	42	29	38	14	16	15	5	9	11	24	20	49		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	19.0	22.6	26.3	28.9	35.2	37.3	35.1	33.0	28.9	21.4	15.3		
		MCWB	7.0	7.5	8.7	11.4	12.2	14.8	15.5	14.2	13.8	12.3	8.6	6.1		
	2%	DB	13.0	17.2	19.7	23.0	27.4	33.0	35.0	33.9	31.3	24.9	19.0	13.0		
		MCWB	5.4	6.2	7.9	9.5	11.3	14.3	15.0	14.0	12.9	10.6	8.1	5.7		
	5%	DB	12.1	14.2	17.6	22.0	25.0	32.0	33.7	32.7	29.9	22.7	17.1	12.0		
		MCWB	5.0	5.0	6.8	9.0	10.4	13.5	14.8	13.7	12.5	9.4	6.9	5.1		
	10%	DB	9.7	12.3	15.1	18.9	22.7	29.1	32.4	32.0	28.0	20.9	13.8	9.0		
		MCWB	4.1	4.6	5.9	8.0	9.8	12.6	14.5	13.5	12.1	8.8	5.4	4.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	8.6	9.6	12.0	13.0	16.6	17.5	16.5	15.8	13.2	10.1	8.3		
		MCDB	13.7	16.4	20.5	24.5	25.2	32.3	30.3	29.2	26.3	23.4	18.9	13.2		
	2%	WB	6.7	7.1	8.3	10.6	12.2	15.3	16.7	15.6	14.7	11.9	8.7	6.8		
		MCDB	11.8	14.7	18.1	21.2	24.3	29.7	30.5	28.6	26.8	22.3	17.1	11.2		
	5%	WB	5.4	5.9	7.3	9.5	11.3	14.4	16.0	14.9	13.7	10.8	7.3	5.6		
		MCDB	10.5	13.1	16.5	19.6	22.9	28.4	29.8	28.4	26.3	19.6	15.3	10.4		
	10%	WB	4.2	4.8	6.4	8.5	10.4	13.5	15.3	14.3	12.8	9.7	6.3	4.4		
		MCDB	8.6	11.4	14.1	17.8	20.9	27.0	28.7	28.4	26.1	18.3	13.0	9.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	13.7	13.2	14.5	14.7	17.5	18.4	18.9	18.5	16.9	14.5	11.5		
		MCDBR	16.2	17.7	18.3	19.5	19.3	20.5	19.5	20.1	21.7	20.8	19.1	14.6		
		MCWBR	9.4	9.1	8.9	8.8	7.7	6.8	5.9	6.3	7.8	9.2	9.9	8.2		
		MCDBR	13.6	16.2	16.5	17.2	17.2	18.6	17.8	17.7	18.4	16.7	17.1	12.2		
	5% WB	MCWBR	8.2	8.9	8.1	8.0	6.8	6.4	5.3	5.8	6.6	7.7	9.2	7.5		
(40) Clear-Sky Solar Irradiance	taub		0.260	0.280	0.284	0.301	0.315	0.319	0.320	0.316	0.300	0.290	0.264	0.260		
	taud		2.555	2.512	2.525	2.485	2.480	2.487	2.516	2.498	2.550	2.570	2.603	2.558		
	Ebn at Noon		936	955	982	976	962	954	950	949	951	931	926	910		
	Edh at Noon		72	86	95	105	108	108	104	103	91	80	68	67		
(44) All-Sky Solar Radiation	RadAvg		2.37	3.26	4.62	6.05	7.16	8.24	8.04	7.29	5.98	4.25	2.78	2.03		
	RadStd		0.31	0.37	0.39	0.48	0.58	0.48	0.41	0.33	0.24	0.29	0.18	0.27		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+97	+44

Nomenclature: See separate page