

HEBER VALLEY, UT, USA

WMO: 720565

Lat: 40.482N

Lon: 111.429W

Elev: 5637

StdP: 11.94

Time Zone: -7.00 (NAM)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.0	0.6	-10.6	3.8	-6.1	-4.5	5.3	4.0	21.9	37.2	18.7	39.4	1.2	120	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.7	93.3	58.5	90.9	57.9	89.6	57.3	61.4	83.2	60.2	82.0	59.2	80.9	8.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.2	80.0	64.6	54.2	77.2	64.1	52.2	71.7	64.0	30.2	82.3	29.3	81.6	28.4	82.2	65.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.0	15.6	-15.0	97.9	5.9	0.9	-19.3	98.6	-22.7	99.1	-26.0	99.7	-30.3	100.3		
(5)			-15.5	63.3	5.8	1.1	-19.7	64.1	-23.1	64.7	-26.3	65.3	-30.5	66.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	22.2	28.0	38.7	43.9	50.9	62.8	70.5	67.6	58.9	46.8	35.8	25.7		
	DBStd	17.45	9.75	9.60	7.07	6.47	6.15	5.89	4.06	3.83	6.68	7.70	8.57	9.19		
	HDD50	3438	863	616	353	198	66	2	0	0	12	147	426	755		
	HDD65	7239	1328	1036	814	632	438	107	9	18	199	563	875	1220		
	CDD50	2010	0	0	4	16	93	385	635	546	281	49	1	0		
	CDD65	336	0	0	0	0	0	40	179	99	18	0	0	0		
	CDH74	8481	0	0	0	19	158	1825	3281	2332	831	35	0	0		
	CDH80	3858	0	0	0	1	22	772	1727	1068	262	6	0	0		
(14) Wind	WSAvg	3.8	1.9	3.4	4.4	5.5	5.0	4.7	3.7	3.7	4.0	3.8	3.3	2.4		
(15) Precipitation	PrecAvg	17.2	2.0	1.7	1.5	1.5	1.5	1.0	0.8	1.0	1.3	1.7	1.7	1.7		
	PrecMax	29.4	9.6	5.5	3.3	4.3	4.7	4.1	3.2	3.3	6.3	5.6	4.2	6.2		
	PrecMin	8.3	0.0	0.2	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	4.6	1.7	1.1	0.8	0.8	1.0	0.9	0.7	0.7	1.1	1.3	1.0	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	58.7	70.1	77.0	82.4	95.2	97.2	94.9	91.0	79.0	64.1	52.0		
		MCWB	37.0	41.5	46.8	50.8	53.1	58.4	59.4	58.4	57.5	51.8	45.8	40.0		
	2%	DB	43.2	52.1	64.1	70.5	79.0	90.8	94.9	91.1	86.2	72.4	61.3	46.3		
		MCWB	34.9	40.2	44.2	47.2	51.6	56.4	59.1	57.8	56.3	49.8	43.2	37.5		
	5%	DB	38.5	46.2	59.5	66.0	73.4	88.2	91.5	89.9	82.2	69.5	56.6	42.8		
		MCWB	33.1	36.9	41.8	46.1	49.6	55.8	58.6	57.4	54.2	48.7	41.5	35.2		
	10%	DB	36.0	43.0	54.4	61.5	70.1	84.5	90.3	87.5	79.2	63.8	52.2	37.2		
		MCWB	32.0	35.0	39.7	43.8	48.9	55.0	58.3	57.2	53.3	47.0	39.9	33.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.5	43.0	47.6	51.1	54.3	60.4	63.4	62.3	60.8	54.7	47.3	41.5		
		MCDB	45.6	53.8	67.3	73.9	79.7	86.3	85.2	83.4	79.8	72.7	62.6	48.9		
	2%	WB	36.2	40.5	45.1	48.5	52.4	58.5	62.0	60.4	58.9	51.8	44.5	38.8		
		MCDB	41.7	50.3	63.6	67.6	75.6	84.3	83.8	82.3	77.1	67.0	58.9	45.5		
	5%	WB	34.0	38.0	43.0	46.6	50.9	57.0	61.0	59.4	56.9	50.1	42.4	36.1		
		MCDB	37.5	45.7	58.0	63.9	71.5	81.8	82.7	80.8	74.9	64.8	55.2	41.1		
	10%	WB	32.3	35.6	40.7	44.7	49.7	55.8	60.0	58.4	55.3	48.2	40.3	33.7		
		MCDB	34.8	41.4	53.4	60.0	68.4	81.3	81.7	79.5	72.7	61.6	51.3	37.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.1	23.4	25.7	28.0	31.1	39.7	38.7	37.9	36.7	31.5	26.5	20.6		
		MCDBR	23.4	25.9	35.0	39.7	41.4	46.4	42.8	43.5	43.8	40.2	34.9	23.2		
		MCWBR	16.7	15.3	17.4	19.0	17.2	16.3	13.4	14.6	17.0	19.3	19.4	15.4		
	5% WB	MCDBR	20.6	23.0	33.2	35.8	37.5	41.3	36.4	35.7	35.3	33.7	32.4	20.7		
		MCWBR	15.0	13.6	16.9	17.9	16.5	15.3	11.6	12.1	13.5	16.3	18.1	14.2		
(40) Clear-Sky Solar Irradiance	taub		0.249	0.263	0.281	0.322	0.318	0.315	0.346	0.342	0.301	0.282	0.256	0.246		
	taud		2.407	2.388	2.438	2.377	2.467	2.513	2.453	2.461	2.562	2.585	2.563	2.472		
	Ebn at Noon		295	306	311	302	304	304	293	292	300	297	293	289		
	Edh at Noon		25	30	32	37	35	33	35	34	28	25	22	22		
(44) All-Sky Solar Radiation	RadAvg		694	953	1411	1752	2045	2454	2341	2025	1689	1175	769	576		
	RadStd		58	91	102	118	180	199	121	108	126	98	86	64		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page