

HEBER VALLEY, UT, USA

WMO: 720565

Lat: 40.482N

Lon: 111.429W

Elev: 1718

StdP: 82.32

Time Zone: -7.00 (NAM)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.1	-17.5	-23.6	0.5	-21.2	-20.3	0.8	-15.5	9.8	2.9	8.4	4.1	0.5	120	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	34.1	14.7	32.7	14.4	32.0	14.1	16.3	28.5	15.7	27.8	15.1	27.2	3.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.9	11.4	18.1	12.3	11.0	17.9	11.2	10.2	17.8	52.3	27.9	50.4	27.5	48.3	27.9	18.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.1	7.0	-26.1	36.6	3.3	0.5	-28.5	37.0	-30.4	37.3	-32.2	37.6	-34.6	38.0		
(5)			-26.4	17.4	3.2	0.6	-28.7	17.8	-30.6	18.2	-32.4	18.5	-34.7	18.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-5.5	-2.2	3.7	6.6	10.5	17.1	21.4	19.8	15.0	8.2	2.1	-3.5	(6)
(7)		DBStd	9.70	5.42	5.34	3.93	3.59	3.42	3.27	2.26	2.13	3.71	4.28	4.76	5.10	(7)
(8)		HDD10.0	1910	479	342	196	110	37	1	0	0	7	82	237	419	(8)
(9)		HDD18.3	4022	738	576	452	351	243	59	5	10	111	313	486	678	(9)
(10)		CDD10.0	1117	0	0	2	9	52	214	353	303	156	27	1	0	(10)
(11)		CDD18.3	187	0	0	0	0	0	22	99	55	10	0	0	0	(11)
(12)		CDH23.3	4712	0	0	0	11	88	1014	1823	1296	462	19	0	0	(12)
(13)		CDH26.7	2143	0	0	0	1	12	429	959	593	146	3	0	0	(13)
(14)	Wind	WSAvg	1.7	0.9	1.5	2.0	2.5	2.2	2.1	1.6	1.6	1.8	1.7	1.5	1.1	(14)
(15)	Precipitation	PrecAvg	438	51	42	37	37	37	26	21	26	32	43	43	43	(15)
(16)		PrecMax	748	244	139	83	108	120	103	82	85	161	141	106	157	(16)
(17)		PrecMin	210	0	5	6	6	0	0	0	0	1	1	0	1	(17)
(18)		PrecStd	118	44	29	20	21	25	23	19	18	28	33	26	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	14.8	21.2	25.0	28.0	35.1	36.2	34.9	32.8	26.1	17.8	11.1	(19)
MCWB			2.8	5.3	8.2	10.4	11.7	14.6	15.2	14.7	14.2	11.0	7.6	4.4	(20)	
2%		DB	6.2	11.2	17.8	21.4	26.1	32.7	35.0	32.8	30.1	22.5	16.3	8.0	(21)	
		MCWB	1.6	4.5	6.8	8.5	10.9	13.6	15.1	14.3	13.5	9.9	6.2	3.1	(22)	
5%		DB	3.6	7.9	15.3	18.9	23.0	31.2	33.0	32.2	27.9	20.8	13.7	6.0	(23)	
		MCWB	0.6	2.7	5.4	7.8	9.8	13.2	14.8	14.1	12.4	9.3	5.3	1.8	(24)	
10%		DB	2.2	6.1	12.5	16.4	21.2	29.1	32.4	30.8	26.2	17.7	11.2	2.9	(25)	
		MCWB	0.0	1.7	4.3	6.5	9.4	12.8	14.6	14.0	11.9	8.3	4.4	0.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.6	6.1	8.7	10.6	12.4	15.8	17.5	16.8	16.0	12.6	8.5	5.3	(27)
MCDWB			7.5	12.1	19.6	23.3	26.5	30.1	29.6	28.5	26.5	22.6	17.0	9.4	(28)	
2%		WB	2.3	4.7	7.3	9.1	11.3	14.7	16.7	15.8	14.9	11.0	6.9	3.8	(29)	
		MCDWB	5.4	10.2	17.6	19.8	24.2	29.1	28.8	27.9	25.1	19.4	14.9	7.5	(30)	
5%		WB	1.1	3.4	6.1	8.1	10.5	13.9	16.1	15.2	13.9	10.1	5.8	2.3	(31)	
		MCDWB	3.1	7.6	14.4	17.7	21.9	27.7	28.2	27.1	23.8	18.2	12.9	5.1	(32)	
10%		WB	0.1	2.0	4.8	7.0	9.8	13.2	15.5	14.7	13.0	9.0	4.6	0.9	(33)	
		MCDWB	1.6	5.2	11.9	15.5	20.2	27.4	27.6	26.4	22.6	16.5	10.7	2.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.9	13.0	14.3	15.6	17.3	22.0	21.5	20.4	17.5	14.7	11.4	(35)	
MCDBR			13.0	14.4	19.5	22.0	23.0	25.8	23.8	24.1	24.3	22.3	19.4	12.9	(36)	
MCWBR			9.3	8.5	9.7	10.5	9.6	9.0	7.4	8.1	9.4	10.7	10.8	8.5	(37)	
5% WB		MCDWB	11.4	12.8	18.4	19.9	20.9	22.9	20.2	19.9	19.6	18.7	18.0	11.5	(38)	
		MCWBR	8.3	7.6	9.4	9.9	9.1	8.5	6.4	6.7	7.5	9.0	10.1	7.9	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub		0.249	0.263	0.281	0.322	0.318	0.315	0.346	0.342	0.301	0.282	0.256	0.246	(40)
taud		2.407	2.388	2.438	2.377	2.467	2.513	2.453	2.461	2.562	2.585	2.563	2.472	(41)		
Ebn at Noon		931	965	979	951	957	957	923	920	945	935	923	910	(42)		
Edh at Noon		79	95	102	117	109	105	110	106	89	78	68	69	(43)		
(44)	All-Sky Solar Radiation	RadAvg		2.19	3.00	4.45	5.52	6.45	7.74	7.38	6.38	5.32	3.70	2.42	1.82	(44)
(45)		RadStd		0.18	0.29	0.32	0.37	0.57	0.63	0.38	0.34	0.40	0.31	0.27	0.20	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page