

RUSK COUNTY AP, TX, USA

WMO: 720577

Lat: 32.150N

Lon: 94.850W

Elev: 443

StdP: 14.46

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00175

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.9	27.9	10.5	9.6	34.8	15.6	12.3	36.7	18.0	54.9	16.4	55.4	2.5	0	0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.1	99.6	72.4	97.3	72.7	94.9	73.6	78.3	87.8	77.5	87.2	77.0	86.5	5.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.1	138.5	81.0	75.3	134.8	80.2	74.7	132.0	80.0	42.0	88.2	41.3	87.4	40.6	86.5	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.4	14.1	12.2		DB	17.9	100.9	4.1	3.4	14.9	103.3	12.5	105.3	10.2	107.2	7.2	109.6
				WB	16.7	79.5	3.8	1.7	14.0	80.7	11.8	81.7	9.7	82.6	7.0	83.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.0	47.0	51.0	58.2	65.4	73.1	80.8	82.7	83.2	77.7	66.8	55.9	49.5
	DBStd	15.03	9.38	10.54	9.46	7.57	6.76	4.06	3.39	4.50	5.25	7.91	9.61	9.38
	HDD50	493	170	106	35	3	0	0	0	0	0	2	49	128
	HDD65	2182	561	404	250	87	19	0	0	0	74	299	488	
	CDD50	6339	78	134	289	464	715	923	1015	1028	831	523	226	113
	CDD65	2553	3	12	39	97	270	473	550	563	381	131	26	8
	CDH74	26541	11	52	242	816	2477	5060	6156	6549	3772	1252	130	24
	CDH80	12522	0	4	28	169	929	2462	3131	3545	1819	419	16	0
Wind	WSAvg	4.7	4.9	5.6	5.9	6.1	5.5	4.3	3.6	3.4	3.2	3.9	4.6	4.8
Precipitation	PrecAvg	46.7	4.1	3.7	3.9	3.9	4.2	4.5	3.1	2.8	3.8	4.2	4.0	4.0
	PrecMax	67.0	7.7	9.3	8.3	11.2	9.3	14.0	12.0	7.6	9.7	12.8	11.5	9.5
	PrecMin	29.7	0.6	0.0	0.7	0.9	0.2	0.3	0.2	0.0	1.5	0.0	0.5	0.4
	PrecStd	10.0	2.1	2.3	2.0	2.3	2.4	3.5	2.5	2.0	2.0	3.0	2.6	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.5	79.2	83.1	88.4	92.9	99.8	100.0	104.4	99.0	91.1	82.4	77.2
		MCWB	58.9	64.4	64.4	68.3	72.5	71.9	72.8	71.7	69.8	71.9	69.2	65.8
	2%	DB	71.8	75.0	80.3	84.1	90.4	97.2	98.6	100.4	95.4	88.0	77.6	72.9
		MCWB	60.5	62.5	64.2	67.2	71.4	72.1	73.0	72.4	72.2	70.9	65.5	65.0
	5%	DB	67.9	71.8	77.0	81.5	88.1	94.6	95.4	98.7	92.8	85.3	74.0	69.9
		MCWB	59.5	62.4	63.0	65.6	71.3	73.7	74.1	73.0	72.5	69.2	64.9	64.0
	10%	DB	63.9	68.2	73.0	79.0	85.7	91.2	92.9	95.1	90.2	81.5	71.9	66.4
		MCWB	56.2	60.4	61.5	65.0	70.3	74.2	75.0	73.7	72.4	66.8	64.7	60.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.3	68.3	69.2	73.2	76.4	79.2	79.2	79.3	77.8	76.5	72.1	70.2
		MCDB	70.4	74.1	76.5	79.3	86.0	88.0	88.9	88.8	86.6	84.5	78.3	73.2
	2%	WB	64.1	66.3	67.7	71.2	74.8	77.8	78.2	78.2	76.7	75.1	69.9	67.6
		MCDB	68.3	71.4	74.2	78.3	84.4	86.6	88.2	88.0	85.6	82.7	74.4	71.2
	5%	WB	61.8	64.2	66.1	69.5	73.5	77.0	77.5	77.4	75.9	73.5	67.7	64.8
		MCDB	65.8	69.3	72.6	76.9	82.9	85.9	87.6	87.3	84.7	80.3	72.5	69.1
	10%	WB	58.0	61.9	64.5	68.3	72.5	76.2	76.8	76.7	75.0	71.6	65.4	61.6
		MCDB	62.7	66.9	70.9	75.5	81.5	85.1	86.5	86.3	83.5	76.6	70.6	65.9
Mean Daily Temperature Range	5% DB	MDBR	21.4	20.2	21.9	23.0	21.1	20.0	20.0	21.1	22.2	23.8	22.2	19.4
		MCDBR	26.0	22.4	23.2	24.6	22.4	24.1	23.6	25.9	25.8	25.8	22.4	22.3
		MCWBR	16.0	13.1	10.9	10.8	7.5	5.6	4.8	5.4	7.4	10.0	12.5	15.7
	5% WB	MCDBR	18.5	18.9	18.3	19.1	19.0	17.8	19.0	19.5	20.0	19.2	18.1	20.1
		MCWBR	14.0	13.5	11.8	10.6	7.6	6.0	5.7	5.5	6.6	9.2	13.0	16.0
Clear-Sky Solar Irradiance	taub	0.323	0.340	0.360	0.399	0.431	0.451	0.466	0.461	0.419	0.362	0.350	0.329	
	taud	2.508	2.468	2.423	2.318	2.281	2.265	2.261	2.266	2.342	2.477	2.463	2.503	
	Ebn at Noon	286	291	292	283	273	266	262	262	269	279	272	277	
	Edh at Noon	27	31	35	41	43	43	43	43	38	31	29	26	
All-Sky Solar Radiation	RadAvg	875	980	1369	1700	1850	1996	2020	1896	1610	1301	948	762	
	RadStd	80	164	127	107	138	163	148	148	145	178	113	98	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page