

RUSK COUNTY AP, TX, USA

WMO: 720577

Lat: 32.150N

Lon: 94.850W

Elev: 135

StdP: 99.71

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00175

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.0	-2.3	-11.9	1.4	1.6	-9.1	1.8	2.6	8.0	12.7	7.3	13.0	1.1	0	0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.7	37.6	22.4	36.3	22.6	34.9	23.1	25.7	31.0	25.3	30.7	25.0	30.3	2.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.5	19.8	27.2	24.1	19.3	26.8	23.7	18.9	26.6	79.7	31.2	78.1	30.8	76.5	30.3	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.3	5.5	DB	-7.9	38.3	2.3	1.9	-9.5	39.6	-10.8	40.7	-12.1	41.8	-13.8	43.1	(4)
(5)			WB	-8.5	26.4	2.1	0.9	-10.0	27.0	-11.2	27.6	-12.4	28.1	-13.9	28.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	8.3	10.5	14.6	18.5	22.8	27.1	28.2	28.4	25.4	19.4	13.3	9.7	(6)	
	DBStd	8.35	5.21	5.85	5.25	4.21	3.75	2.25	1.88	2.50	2.92	4.40	5.34	5.21	(7)	
	HDD10.0	274	94	59	19	2	0	0	0	0	0	1	27	71	(8)	
	HDD18.3	1212	312	224	139	48	11	0	0	0	0	41	166	271	(9)	
	CDD10.0	3522	43	74	161	258	397	513	564	571	462	291	126	63	(10)	
	CDD18.3	1418	2	7	22	54	150	263	306	313	212	73	14	4	(11)	
	CDH23.3	14745	6	29	134	453	1376	2811	3420	3638	2096	696	72	13	(12)	
(13)	CDH26.7	6957	0	2	16	94	516	1368	1739	1969	1011	233	9	0	(13)	
(14)	Wind	WSAvg	2.1	2.2	2.5	2.7	2.7	2.5	1.9	1.6	1.5	1.4	1.8	2.1	2.2	(14)
(15) Precipitation	PrecAvg	1187	104	93	100	100	106	115	80	70	96	106	102	102	(15)	
	PrecMax	1703	195	236	212	284	236	356	304	192	247	326	292	241	(16)	
	PrecMin	755	15	0	19	23	5	7	6	0	39	0	12	10	(17)	
	PrecStd	255	54	58	50	58	61	88	64	51	51	75	66	62	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	26.2	28.4	31.3	33.8	37.7	37.8	40.2	37.2	32.8	28.0	25.1	(19)	
		MCWB	14.9	18.0	18.0	20.2	22.5	22.2	22.7	22.0	21.0	22.1	20.6	18.8	(20)	
	2%	DB	22.1	23.9	26.8	28.9	32.5	36.2	37.0	38.0	35.2	31.1	25.3	22.7	(21)	
		MCWB	15.9	17.0	17.9	19.6	21.9	22.3	22.8	22.4	22.3	21.6	18.6	18.3	(22)	
	5%	DB	19.9	22.1	25.0	27.5	31.1	34.8	35.2	37.1	33.8	29.6	23.4	21.0	(23)	
		MCWB	15.3	16.9	17.2	18.7	21.8	23.1	23.4	22.8	22.5	20.7	18.3	17.8	(24)	
	10%	DB	17.7	20.1	22.8	26.1	29.8	32.9	33.8	35.0	32.3	27.5	22.2	19.1	(25)	
		MCWB	13.4	15.8	16.4	18.3	21.3	23.4	23.9	23.1	22.4	19.3	18.1	15.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	20.2	20.7	22.9	24.7	26.2	26.2	26.3	25.5	24.7	22.3	21.2	(27)	
		MCDB	21.3	23.4	24.7	26.3	30.0	31.1	31.6	31.6	30.3	29.2	25.7	22.9	(28)	
	2%	WB	17.8	19.1	19.8	21.8	23.8	25.4	25.7	25.7	24.8	23.9	21.0	19.8	(29)	
		MCDB	20.1	21.9	23.4	25.7	29.1	30.3	31.2	31.1	29.8	28.2	23.5	21.8	(30)	
	5%	WB	16.6	17.9	18.9	20.9	23.1	25.0	25.3	25.2	24.4	23.1	19.9	18.2	(31)	
		MCDB	18.8	20.7	22.6	24.9	28.3	29.9	30.9	30.7	29.3	26.8	22.5	20.6	(32)	
	10%	WB	14.4	16.6	18.1	20.1	22.5	24.6	24.9	24.8	23.9	22.0	18.6	16.4	(33)	
		MCDB	17.1	19.4	21.6	24.2	27.5	29.5	30.3	30.2	28.6	24.8	21.5	18.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	11.2	12.1	12.8	11.7	11.1	11.1	11.7	12.4	13.2	12.3	10.8	(35)	
		MCDBR	14.4	12.4	12.9	13.7	12.4	13.4	13.1	14.4	14.3	14.3	12.4	12.4	(36)	
		MCWBR	8.9	7.3	6.1	6.0	4.2	3.1	2.7	3.0	4.1	5.5	7.0	8.7	(37)	
	5% WB	MCDBR	10.3	10.5	10.2	10.6	10.5	9.9	10.6	10.8	11.1	10.7	10.0	11.2	(38)	
		MCWBR	7.8	7.5	6.5	5.9	4.2	3.3	3.2	3.0	3.7	5.1	7.2	8.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.323	0.340	0.360	0.399	0.431	0.451	0.466	0.461	0.419	0.362	0.350	0.329	(40)	
	taud		2.508	2.468	2.423	2.318	2.281	2.265	2.261	2.266	2.342	2.477	2.463	2.503	(41)	
	Ebn at Noon		901	917	920	892	862	839	825	825	849	880	859	873	(42)	
	Edh at Noon		86	99	111	129	135	137	137	134	119	97	90	83	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.76	3.09	4.32	5.36	5.83	6.29	6.37	5.98	5.08	4.10	2.99	2.40	(44)	
	RadStd		0.25	0.52	0.40	0.34	0.44	0.51	0.47	0.47	0.46	0.56	0.36	0.31	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page