

PLATTEVILLE, WI, USA

WMO: 720586

Lat: 42.689N

Lon: 90.444W

Elev: 1024

StdP: 14.16

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00183

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-2.6	-14.6	2.6	-6.5	-9.8	3.4	-2.1	27.1	23.6	24.9	22.9	6.9	270	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	89.3	74.7	86.2	73.3	83.6	72.1	78.3	84.6	76.5	82.6	74.6	80.5	12.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.7	144.4	82.3	74.6	134.4	80.0	72.8	126.2	78.3	42.6	84.2	40.6	82.8	38.8	80.3	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	21.0	18.9	-14.9	93.2	5.8	2.4	-19.1	95.0	-22.5	96.4	-25.8	97.7	-30.0	99.5		
(5)			-15.4	81.7	5.7	1.9	-19.5	83.0	-22.8	84.1	-26.0	85.2	-30.2	86.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	18.9	22.8	36.4	48.0	60.7	69.8	72.5	70.1	64.1	51.1	37.6	25.7
	DBStd	20.94	12.29	11.86	11.77	9.24	8.89	5.83	5.28	5.11	7.78	9.12	10.22	11.24
	HDD50	3574	965	763	443	144	14	0	0	0	4	97	389	755
	HDD65	6835	1430	1183	888	514	191	20	6	13	108	441	822	1219
	CDD50	2941	0	1	21	84	346	593	698	623	426	130	18	1
	CDD65	724	0	0	1	3	58	163	239	170	81	9	0	0
	CDH74	5796	0	0	7	54	530	1318	1982	1234	603	67	1	0
	CDH80	1575	0	0	0	8	136	387	589	293	153	9	0	0
	WSAvg	8.8	9.5	9.8	9.9	11.2	9.8	8.2	6.3	5.9	7.1	8.6	9.7	9.2
	PrecAvg	38.6	1.3	1.5	2.1	3.9	4.6	5.7	4.7	4.5	3.8	2.5	2.3	1.7
(15) Precipitation	PrecMax	48.4	2.8	3.1	4.7	7.0	9.0	10.9	8.9	11.1	7.5	6.3	7.2	4.3
	PrecMin	31.2	0.4	0.1	0.5	1.4	1.0	1.0	1.7	1.5	1.0	0.5	0.2	0.3
	PrecStd	5.0	0.6	0.8	1.4	1.7	1.8	2.4	2.0	2.2	1.6	1.5	1.8	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.2	58.4	73.8	80.6	89.4	91.1	95.1	90.0	89.7	80.9	69.8	57.0
		MCWB	43.0	52.3	60.8	62.1	70.6	74.9	73.9	72.4	73.8	63.5	59.0	55.5
	2%	DB	40.8	48.4	64.5	73.7	83.7	88.0	89.4	86.1	84.4	75.0	63.0	48.1
		MCWB	37.9	44.7	56.4	60.0	67.8	74.0	77.3	74.2	72.5	63.3	55.5	45.6
	5%	DB	37.0	42.2	59.1	68.4	80.3	84.3	85.8	83.1	80.9	70.4	57.3	43.3
		MCWB	35.4	39.2	51.1	55.8	65.2	70.8	74.5	73.2	69.3	61.3	51.9	40.6
	10%	DB	34.5	37.6	53.4	63.8	76.3	81.4	82.5	80.9	77.2	66.0	52.1	39.0
		MCWB	33.5	35.6	46.4	53.0	63.6	69.6	72.4	71.0	67.6	59.7	47.0	37.0
	0.4%	WB	43.9	53.6	62.9	65.7	73.3	80.1	81.9	79.5	77.4	71.7	61.4	56.4
		MCDB	45.8	54.7	73.3	73.8	84.4	87.2	86.2	85.4	84.0	75.5	66.9	58.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.5	45.5	58.3	61.5	70.7	77.2	78.7	77.2	75.3	67.4	56.5	46.0
		MCDB	40.4	48.1	64.2	69.8	79.3	84.1	84.8	82.9	80.5	71.5	61.7	47.0
	5%	WB	35.6	39.5	52.4	58.4	68.4	74.3	76.7	75.0	72.6	63.4	52.2	41.1
		MCDB	37.0	42.1	58.0	67.3	76.3	80.9	83.1	80.3	77.4	67.7	56.8	43.0
	10%	WB	33.4	35.9	47.2	54.2	65.9	71.8	74.8	73.1	70.3	59.2	47.4	37.2
		MCDB	34.4	37.9	52.5	62.0	73.3	78.7	81.1	78.1	75.3	65.1	50.9	38.7
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	14.9	16.1	19.0	19.2	17.9	18.1	18.1	19.5	18.2	15.0	12.6
		MCDBR	14.6	18.3	23.4	26.9	23.6	21.2	20.6	19.6	22.4	23.3	21.4	16.1
		MCWBR	12.7	14.6	15.3	15.5	11.4	10.6	10.1	9.9	11.2	12.7	15.2	13.6
	5% WB	MCDBR	14.5	18.9	21.6	23.2	20.2	18.6	17.8	16.5	17.8	19.3	20.5	16.0
		MCWBR	12.7	15.3	15.7	15.0	11.4	11.1	10.3	9.8	10.7	14.7	15.8	14.3
(40) Clear-Sky Solar Irradiance	taub		0.278	0.302	0.326	0.369	0.397	0.418	0.427	0.408	0.377	0.334	0.293	0.277
	taud		2.390	2.328	2.398	2.303	2.281	2.260	2.233	2.287	2.351	2.471	2.513	2.434
	Ebn at Noon		275	285	291	285	278	272	267	269	270	271	269	266
	Edh at Noon		25	31	33	39	42	43	43	40	35	27	22	22
(44) All-Sky Solar Radiation	RadAvg		560	883	1197	1459	1723	1924	1929	1687	1395	904	596	436
	RadStd		68	94	127	119	123	152	118	114	112	113	46	38

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page