

PLATTEVILLE, WI, USA

WMO: 720586

Lat: 42.689N

Lon: 90.444W

Elev: 312

StdP: 97.63

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00183

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.1	-19.2	-25.9	0.4	-21.4	-23.2	0.5	-18.9	12.1	-4.7	11.1	-5.1	3.1	270	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	31.8	23.7	30.1	22.9	28.7	22.3	25.7	29.2	24.7	28.1	23.7	27.0	5.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	20.6	28.0	23.7	19.2	26.7	22.6	18.0	25.7	81.1	29.0	76.6	28.2	72.4	26.8	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.4	8.4	DB	-26.0	34.0	3.2	1.4	-28.4	35.0	-30.3	35.8	-32.1	36.5	-34.5	37.5	(4)
(5)			WB	-26.3	27.6	3.2	1.0	-28.6	28.3	-30.5	28.9	-32.2	29.5	-34.5	30.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	-7.3	-5.1	2.4	8.9	15.9	21.0	22.5	21.2	17.8	10.6	3.1	-3.5		
	DBStd	11.64	6.83	6.59	6.54	5.14	4.94	3.24	2.93	2.84	4.32	5.07	5.68	6.25		
	HDD10.0	1986	536	424	246	80	8	0	0	0	2	54	216	419		
	HDD18.3	3797	794	657	493	286	106	11	3	7	60	245	457	677		
	CDD10.0	1634	0	1	12	47	192	329	388	346	237	72	10	1		
	CDD18.3	402	0	0	1	2	32	91	133	94	45	5	0	0		
	CDH23.3	3220	0	0	4	30	294	732	1101	686	335	37	1	0		
	CDH26.7	875	0	0	0	4	76	215	327	163	85	5	0	0		
(14) Wind	WSAvg	3.9	4.3	4.4	4.4	5.0	4.4	3.7	2.8	2.7	3.2	3.9	4.3	4.1		
(15) Precipitation	PrecAvg	981	34	39	54	98	118	144	119	115	96	64	59	42		
	PrecMax	1230	70	80	120	179	229	276	225	282	190	159	182	109		
	PrecMin	793	9	3	13	35	25	26	43	37	25	12	4	7		
	PrecStd	128	15	21	36	44	46	61	50	57	41	39	45	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	14.7	23.2	27.0	31.9	32.8	35.0	32.2	32.1	27.2	21.0	13.9		
		MCWB	6.1	11.3	16.0	16.7	21.4	23.8	23.3	22.4	23.2	17.5	15.0	13.1		
	2%	DB	4.9	9.1	18.0	23.2	28.7	31.1	31.9	30.1	29.1	23.9	17.2	9.0		
		MCWB	3.3	7.1	13.6	15.5	19.9	23.3	25.2	23.4	22.5	17.4	13.0	7.5		
	5%	DB	2.8	5.7	15.1	20.2	26.8	29.1	29.9	28.4	27.2	21.3	14.0	6.3		
		MCWB	1.9	4.0	10.6	13.2	18.4	21.5	23.6	22.9	20.7	16.3	11.0	4.8		
	10%	DB	1.4	3.1	11.9	17.7	24.6	27.5	28.0	27.2	25.1	18.9	11.1	3.9		
		MCWB	0.9	2.0	8.0	11.7	17.6	20.9	22.4	21.7	19.8	15.4	8.3	2.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	12.0	17.2	18.7	22.9	26.7	27.7	26.4	25.2	22.0	16.3	13.6		
		MCDB	7.7	12.6	22.9	23.2	29.1	30.7	30.1	29.7	28.9	24.2	19.4	14.5		
	2%	WB	3.6	7.5	14.6	16.4	21.5	25.1	25.9	25.1	24.0	19.7	13.6	7.8		
		MCDB	4.7	8.9	17.9	21.0	26.3	29.0	29.3	28.3	27.0	21.9	16.5	8.3		
	5%	WB	2.0	4.2	11.3	14.7	20.2	23.5	24.8	23.9	22.6	17.4	11.2	5.1		
		MCDB	2.8	5.6	14.4	19.6	24.6	27.1	28.4	26.8	25.2	19.8	13.8	6.1		
	10%	WB	0.8	2.2	8.4	12.3	18.8	22.1	23.8	22.8	21.3	15.1	8.6	2.9		
		MCDB	1.3	3.3	11.4	16.6	22.9	25.9	27.3	25.6	24.1	18.4	10.5	3.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	8.3	8.9	10.6	10.7	9.9	10.0	10.0	10.9	10.1	8.4	7.0		
		MCDBR	8.1	10.2	13.0	14.9	13.1	11.8	11.4	10.9	12.4	13.0	11.9	9.0		
	5% WB	MCWBR	7.0	8.1	8.5	8.6	6.3	5.9	5.6	5.5	6.2	7.0	8.5	7.6		
		MCWBR	8.1	10.5	12.0	12.9	11.2	10.3	9.9	9.2	9.9	10.7	11.4	8.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.278	0.302	0.326	0.369	0.397	0.418	0.427	0.408	0.377	0.334	0.293	0.277		
		taud	2.390	2.328	2.398	2.303	2.281	2.260	2.233	2.287	2.351	2.471	2.513	2.434		
	Ebn at Noon	Ebn at Noon	868	898	918	898	877	857	843	849	851	853	849	837		
		Edh at Noon	78	98	104	124	131	134	136	125	109	85	69	69		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.76	2.78	3.77	4.60	5.43	6.07	6.08	5.32	4.40	2.85	1.88	1.38		
	RadStd	RadStd	0.21	0.30	0.40	0.37	0.39	0.48	0.37	0.36	0.35	0.35	0.14	0.12		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page