

ABBEVILLE, LA, USA

WMO: 720587

Lat: 29.976N

Lon: 92.084W

Elev: 15

StdP: 101.14

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 00184

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.8	(c) 0.9	(d) -6.6	(e) 2.2	(f) 4.4	(g) -3.7	(h) 2.8	(i) 6.7	(j) 10.6	(k) 15.7	(l) 9.1	(m) 15.4	(n) 2.0	(o) 10	(p) 0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	34.9	26.0	33.7	25.7	32.8	25.8	29.3	31.3	27.9	30.7	27.4	30.1	2.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.8	25.4	31.3	27.4	23.4	28.8	27.0	22.7	28.6	96.3	30.8	89.6	30.7	86.3	30.5	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.8	(b) 7.8	(c) 7.0	(e) -3.9	(f) 35.9	(g) 2.8	(h) 1.2	(i) -5.9	(j) 36.8	(k) -7.5	(l) 37.6	(m) -9.1	(n) 38.2	(o) -11.1	(p) 39.1		
(4) 8.8	(5) 7.8	(6) 7.0	(7) -3.9	(8) 35.9	(9) 2.8	(10) 1.2	(11) -5.9	(12) 36.8	(13) -7.5	(14) 37.6	(15) -9.1	(16) 38.2	(17) -11.1	(18) 39.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.7	11.4	14.7	17.3	20.7	24.4	27.4	28.1	27.7	26.2	21.0	15.5	13.1	(6)
(7)		DBStd	7.01	5.57	5.31	4.50	3.19	2.91	1.79	1.38	1.56	2.05	4.12	4.86	5.07	(7)
(8)		HDD10.0	109	51	18	5	0	0	0	0	0	0	0	10	25	(8)
(9)		HDD18.3	747	224	123	74	16	2	0	0	0	0	21	111	176	(9)
(10)		CDD10.0	3998	93	148	232	320	448	523	560	549	487	342	175	121	(10)
(11)		CDD18.3	1594	8	20	42	86	192	273	302	291	237	104	26	14	(11)
(12)		CDH23.3	14656	12	48	188	548	1744	2861	3173	2896	2092	928	128	38	(12)
(13)		CDH26.7	5677	0	1	11	61	595	1259	1365	1234	861	280	11	0	(13)
(14)	Wind	WSAvg	2.6	3.2	3.5	3.3	3.4	2.8	2.1	1.6	1.6	1.6	2.2	2.6	3.0	(14)
(15)	Precipitation	PrecAvg	1547	134	97	106	114	99	180	167	138	145	123	123	115	(15)
(16)		PrecMax	2106	347	218	263	319	290	401	249	253	303	365	359	335	(16)
(17)		PrecMin	963	28	13	2	4	6	26	78	54	55	13	44	43	(17)
(18)		PrecStd	299	98	64	68	82	71	98	46	52	72	104	78	74	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	26.3	27.7	29.9	33.0	37.0	36.0	35.4	34.7	32.3	28.1	25.9	(19)
(20)			MCWB	20.4	21.9	21.4	20.9	24.2	25.1	28.6	26.7	24.2	23.9	22.8	22.0	(20)
(21)		2%	DB	22.9	24.9	27.0	27.9	32.3	34.8	34.3	34.3	33.3	31.1	26.3	24.6	(21)
(22)			MCWB	20.0	21.8	21.0	21.9	24.2	25.4	26.6	26.1	24.7	23.9	21.4	21.5	(22)
(23)		5%	DB	22.1	23.1	25.8	27.4	31.2	33.0	33.2	33.0	32.4	29.9	25.1	22.8	(23)
(24)			MCWB	19.6	20.9	20.8	21.6	23.8	25.5	26.5	26.4	25.0	23.5	20.0	21.1	(24)
(25)		10%	DB	20.1	22.3	24.0	26.4	30.1	32.3	32.5	32.3	31.3	28.0	23.4	21.2	(25)
(26)			MCWB	18.4	20.6	20.4	21.4	23.8	25.5	26.4	26.4	25.0	22.3	20.0	19.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	23.5	23.5	26.0	26.6	28.0	30.9	30.6	29.1	27.3	24.9	23.6	(27)
(28)			MCDWB	23.6	24.8	25.8	26.8	28.4	30.7	33.9	32.4	30.6	29.3	26.5	24.5	(28)
(29)		2%	WB	21.6	22.7	22.9	24.6	25.9	27.5	29.9	29.1	27.7	26.3	23.4	22.6	(29)
(30)			MCDWB	22.5	24.0	25.2	26.1	28.4	30.5	31.8	31.6	30.0	28.2	24.8	23.7	(30)
(31)		5%	WB	20.5	22.0	22.3	23.7	25.4	27.1	27.9	27.9	26.9	25.4	22.4	21.4	(31)
(32)			MCDWB	21.2	23.2	24.1	25.7	28.5	30.2	30.5	30.9	29.4	27.6	23.8	22.5	(32)
(33)		10%	WB	18.7	21.0	21.5	22.9	24.9	26.6	27.3	27.4	26.2	24.4	21.0	20.1	(33)
(34)			MCDWB	20.0	21.9	23.1	25.2	28.3	29.8	30.0	30.1	28.9	26.7	23.0	21.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.6	9.8	10.7	10.3	9.8	9.2	8.9	8.9	9.9	12.3	12.0	10.1	(35)
(36)			MCDBR	10.2	9.0	10.0	10.3	10.6	10.4	9.9	10.0	11.0	11.9	11.3	10.2	(36)
(37)			MCWBR	7.2	6.2	5.6	5.3	4.1	3.7	3.9	4.1	4.5	5.5	6.8	7.5	(37)
(38)		5% WB	MCDWB	8.5	7.8	8.2	8.1	9.0	8.8	8.7	8.8	9.0	9.4	9.6	9.5	(38)
(39)			MCWBR	7.4	6.3	5.7	5.6	4.1	4.0	4.4	4.7	4.7	5.5	7.5	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.342	0.357	0.379	0.422	0.450	0.471	0.491	0.484	0.445	0.382	0.360	0.352	(40)
(41)		taud		2.504	2.467	2.395	2.275	2.232	2.223	2.196	2.215	2.292	2.445	2.456	2.477	(41)
(42)		Ebn at Noon		892	908	907	874	847	825	806	809	831	868	862	859	(42)
(43)		Edh at Noon		90	101	116	135	142	143	146	142	127	102	93	89	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.93	3.43	4.70	5.70	6.30	6.18	5.85	5.54	5.08	4.52	3.40	2.63	(44)
(45)		RadStd		0.29	0.50	0.42	0.42	0.36	0.48	0.42	0.48	0.47	0.52	0.33	0.27	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+122	+82

Nomenclature: See separate page