

LANCASTER COUNTY AP, SC, USA

WMO: 720607

Lat: 34.717N

Lon: 80.850W

Elev: 148

StdP: 99.56

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00199

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.5	-4.9	-17.6	0.8	-1.3	-14.0	1.1	0.5	8.7	11.8	7.5	11.1	0.5	50	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	35.0	23.9	33.8	23.7	32.7	23.7	26.5	30.4	25.8	29.8	25.4	29.3	2.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.8	27.1	25.0	20.5	26.9	24.1	19.4	26.2	83.3	30.9	80.9	29.9	78.5	29.5	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	7.2	5.7	4.9	DB	-10.9	36.8	2.8	1.7	-12.9	38.0	-14.6	39.0	-16.1	39.9	-18.2	41.2
(5)				WB	-11.3	27.7	2.7	1.0	-13.2	28.4	-14.8	28.9	-16.3	29.5	-18.2	30.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	5.3	7.8	11.0	16.3	21.1	25.1	26.7	25.8	23.0	16.7	10.3	7.8
	DBStd	8.57	5.58	5.48	5.31	4.18	3.53	2.35	1.97	2.07	3.08	4.34	4.34	5.24
	HDD10.0	483	168	101	53	4	0	0	0	0	0	3	47	108
	HDD18.3	1698	406	297	233	87	19	0	0	0	4	83	241	328
	CDD10.0	2839	21	38	84	194	343	453	517	491	391	211	57	41
	CDD18.3	1013	0	2	6	26	103	204	259	232	144	32	2	2
	CDH23.3	9220	1	9	62	287	873	1946	2489	2052	1220	272	8	2
	CDH26.7	4004	0	0	6	62	296	907	1226	930	510	68	0	0
Wind	WSAvg	1.6	1.6	1.9	2.0	2.1	1.7	1.5	1.4	1.2	1.4	1.6	1.4	1.5
Precipitation	PrecAvg	1055	93	80	98	79	64	111	103	113	86	82	73	86
	PrecMax	1294	190	138	219	165	131	216	234	206	231	306	180	183
	PrecMin	770	26	41	21	23	23	23	41	20	0	0	11	34
	PrecStd	164	43	32	47	41	30	52	47	56	56	63	44	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.6	24.9	27.5	30.0	33.8	36.3	37.3	35.1	34.1	32.0	24.1	22.8
		MCWB	16.6	17.7	17.8	19.1	21.4	23.7	24.2	24.2	22.5	23.0	17.8	20.1
	2%	DB	18.9	22.4	25.1	28.0	32.1	34.1	35.1	33.9	32.8	27.9	22.4	20.3
		MCWB	15.0	15.8	16.0	18.8	21.5	23.5	24.3	24.0	22.2	20.8	16.6	17.9
	5%	DB	17.3	19.8	22.8	27.2	29.8	32.9	33.9	32.7	32.1	27.0	20.1	18.8
		MCWB	14.0	14.7	15.3	18.5	21.1	23.8	24.2	24.1	22.1	19.9	16.2	17.2
	10%	DB	14.8	17.5	20.1	24.8	27.9	32.1	32.6	32.1	29.9	24.1	18.0	17.3
		MCWB	11.8	13.6	14.0	17.2	20.8	23.5	24.2	24.0	22.0	19.4	14.7	15.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	19.4	19.8	23.1	24.7	26.4	27.8	27.5	26.0	24.9	20.6	22.0
		MCDB	20.5	21.7	22.7	25.4	28.1	31.0	30.7	29.6	28.9	26.6	21.9	22.3
	2%	WB	17.2	17.9	18.6	21.8	23.8	25.7	26.6	26.6	25.0	23.7	19.1	19.1
		MCDB	18.0	19.9	23.0	24.6	26.8	30.5	30.9	29.9	27.9	25.9	20.4	19.8
	5%	WB	14.9	16.5	17.4	20.4	23.0	25.2	25.8	25.8	24.0	22.5	17.7	17.6
		MCDB	16.1	19.6	19.9	23.7	26.1	29.9	30.1	29.3	27.5	24.8	18.7	17.9
	10%	WB	12.3	14.3	16.0	19.2	22.3	24.6	25.4	25.2	23.1	20.9	16.1	15.1
		MCDB	13.7	16.3	19.4	22.7	25.8	28.7	29.5	28.7	26.4	23.4	18.5	16.6
Mean Daily Temperature Range	5% DB	MDBR	11.8	12.3	13.1	13.9	12.1	12.1	11.6	11.1	11.8	12.9	13.1	11.1
		MCDBR	14.2	14.1	15.2	15.7	14.1	14.0	13.3	12.6	14.4	14.2	14.7	11.2
		MCWBR	10.1	8.8	7.8	7.1	5.8	5.2	4.3	4.7	5.0	7.1	9.3	8.0
	5% WB	MCDBR	11.2	11.4	12.0	11.5	11.1	12.2	11.4	10.8	11.5	10.5	10.2	9.1
		MCWBR	9.7	8.5	7.8	6.5	5.4	5.3	4.8	4.9	5.1	6.3	8.3	7.9
Clear-Sky Solar Irradiance	taub	0.316	0.326	0.363	0.411	0.468	0.494	0.548	0.523	0.440	0.389	0.338	0.315	
	taud	2.500	2.470	2.397	2.253	2.137	2.105	1.978	2.036	2.251	2.368	2.471	2.537	
	Ebn at Noon	892	921	909	876	826	802	756	767	820	836	857	872	
	Edh at Noon	84	96	112	136	155	160	180	167	129	105	86	77	
All-Sky Solar Radiation	RadAvg	2.69	3.33	4.41	5.53	6.09	6.43	6.04	5.51	4.72	3.90	2.97	2.33	
	RadStd	0.15	0.37	0.32	0.42	0.50	0.46	0.38	0.26	0.41	0.48	0.24	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (68 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+170	+117

Nomenclature: See separate page