

LOWCOUNTRY, SC, USA

WMO: 720609

Lat: 32.917N

Lon: 80.633W

Elev: 102

StdP: 14.64

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00201

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	29.6	9.0	8.7	36.8	13.8	11.2	39.2	20.7	61.3	18.9	57.0	2.2	300	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	96.6	75.8	93.4	75.4	91.0	75.2	81.1	85.5	79.8	84.9	78.7	84.7	7.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	153.6	81.6	78.9	150.3	81.5	77.2	142.3	81.0	44.5	83.9	43.4	86.9	42.4	82.7	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.6	15.1	12.5	DB	20.5	98.4	4.5	2.5	17.2	100.2	14.6	101.6	12.1	103.0	8.8	104.8
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	48.0	52.3	56.6	64.5	72.4	79.1	81.5	80.8	76.5	66.5	55.5	50.9
	DBStd	13.93	10.03	9.23	8.97	6.74	5.57	4.09	3.46	3.34	4.45	7.62	8.24	8.81
	HDD50	409	162	75	40	1	0	0	0	0	0	1	32	98
	HDD65	2109	533	365	285	89	12	0	0	0	1	78	305	441
	CDD50	6049	98	140	244	437	695	874	976	955	795	511	196	128
	CDD65	2274	5	10	24	75	242	424	511	490	346	123	19	5
	CDH74	20975	25	84	244	767	2103	4096	5117	4604	2849	934	125	27
	CDH80	8610	0	6	38	174	754	1856	2421	2022	1101	227	10	1
Wind	WSAvg	4.7	5.0	5.5	5.8	5.8	4.9	4.4	4.4	3.9	3.9	4.2	4.1	4.6
Precipitation	PrecAvg	48.4	3.7	3.1	3.6	3.0	3.0	5.6	5.5	6.2	4.4	3.9	2.7	3.1
	PrecMax	57.9	8.1	8.3	6.2	7.5	6.5	9.7	8.7	12.8	6.9	12.9	5.5	9.3
	PrecMin	34.8	0.8	0.9	0.3	0.6	0.7	2.1	2.3	2.6	0.4	0.0	0.1	0.7
	PrecStd	6.9	2.0	1.6	1.9	1.8	1.7	2.4	1.7	2.4	1.9	3.1	1.7	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.2	81.0	84.0	88.0	95.3	97.4	98.9	97.3	93.2	88.5	81.5	78.5
		MCWB	63.9	65.2	64.3	69.4	73.1	75.5	75.8	76.9	74.0	73.0	69.3	68.3
	2%	DB	72.4	76.9	80.9	84.4	90.3	95.0	96.8	94.8	90.7	85.8	78.7	72.6
		MCWB	62.3	64.8	64.3	69.9	70.8	75.4	75.9	76.2	74.6	72.1	66.8	63.5
	5%	DB	68.3	72.4	76.9	81.6	87.8	91.2	94.5	91.2	89.6	81.9	73.2	69.9
		MCWB	60.1	61.2	62.4	67.8	71.1	74.9	76.3	76.0	74.8	70.1	65.3	63.3
	10%	DB	63.9	68.3	72.3	79.1	84.1	90.0	90.8	90.1	86.5	79.4	71.6	65.7
		MCWB	58.4	59.5	61.5	66.2	70.8	74.5	76.1	76.2	73.9	69.1	64.7	60.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	68.5	70.2	80.7	80.7	81.9	82.1	80.8	78.0	73.6	71.6	
		MCDB	71.6	74.8	74.6	82.5	80.0	86.5	87.3	85.9	82.9	80.8	77.8	75.7
	2%	WB	64.9	66.4	67.9	73.7	74.9	79.1	80.8	81.1	78.7	75.9	71.7	67.5
		MCDB	69.8	73.5	73.9	78.8	83.3	85.2	86.3	85.6	83.2	81.8	75.3	71.8
	5%	WB	63.0	64.4	65.9	71.6	73.4	77.9	79.4	79.9	77.3	74.1	69.1	64.1
		MCDB	66.1	70.4	73.7	77.0	81.9	85.3	85.5	84.9	83.6	79.5	72.3	67.5
	10%	WB	60.5	62.1	63.7	69.2	72.4	77.0	78.4	78.8	76.2	72.4	65.5	62.0
		MCDB	64.3	67.0	69.6	75.1	80.3	85.0	85.3	84.4	83.2	77.1	71.4	65.5
Mean Daily Temperature Range	5% DB	MDBR	21.0	22.6	23.3	24.3	21.3	19.7	19.1	17.6	18.7	21.9	23.0	20.2
		MCDBR	24.5	25.7	26.4	27.0	25.4	21.9	21.9	19.9	20.8	21.9	24.2	23.9
		MCWBR	15.0	14.5	12.5	11.8	9.1	7.3	7.3	7.1	7.9	10.1	14.4	15.8
	5% WB	MCDBR	19.8	22.5	21.4	20.1	19.3	19.2	18.7	17.5	18.0	17.8	17.0	19.6
		MCWBR	14.6	14.6	11.6	10.3	8.1	7.6	7.7	7.4	8.1	9.8	12.4	15.0
Clear-Sky Solar Irradiance	taub	0.327	0.336	0.368	0.404	0.465	0.505	0.537	0.516	0.433	0.397	0.349	0.330	
	taud	2.516	2.485	2.418	2.309	2.179	2.112	2.043	2.098	2.326	2.391	2.490	2.540	
	Ebn at Noon	283	292	289	281	264	252	243	246	264	266	272	275	
	Edh at Noon	27	31	35	41	47	50	54	50	38	33	28	25	
All-Sky Solar Radiation	RadAvg	915	1120	1466	1859	1993	2024	1958	1772	1514	1306	1014	810	
	RadStd	48	113	125	122	140	142	125	107	128	145	72	68	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (43 neighbors)		+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+364	+256	

Nomenclature: See separate page