

LOWCOUNTRY, SC, USA

WMO: 720609

Lat: 32.917N

Lon: 80.633W

Elev: 31

StdP: 100.95

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00201

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.9	(c) -1.3	(d) -12.8	(e) 1.2	(f) 2.7	(g) -10.1	(h) 1.6	(i) 4.0	(j) 9.3	(k) 16.3	(l) 8.5	(m) 13.9	(n) 1.0	(o) 300	(p) 0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	35.9	24.3	34.1	24.1	32.8	24.0	27.3	29.7	26.6	29.4	26.0	29.3	3.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	27.6	26.0	21.5	27.5	25.1	20.3	27.2	85.7	28.8	83.0	30.5	80.8	28.2	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.8	(b) 6.7	(c) 5.6	(e) -6.4	(f) 36.9	(g) 2.5	(h) 1.4	(i) -8.2	(j) 37.9	(k) -9.7	(l) 38.7	(m) -11.1	(n) 39.5	(o) -12.9	(p) 40.5		
(4) 7.8	(5) 6.7	(6) 5.6	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	8.9	11.3	13.7	18.1	22.4	26.2	27.5	27.1	24.7	19.1	13.0	10.5
	DBStd	7.74	5.57	5.13	4.98	3.74	3.09	2.27	1.92	1.86	2.47	4.24	4.58	4.89
	HDD10.0	227	90	42	22	1	0	0	0	0	0	1	18	54
	HDD18.3	1172	296	203	158	49	7	0	0	0	1	43	169	245
	CDD10.0	3361	54	78	136	243	386	486	542	531	442	284	109	71
	CDD18.3	1263	3	6	13	42	134	236	284	272	192	68	11	3
	CDH23.3	11653	14	47	136	426	1168	2276	2843	2558	1583	519	69	15
	CDH26.7	4783	0	3	21	97	419	1031	1345	1123	612	126	6	1
Wind	WSAvg	2.1	2.2	2.5	2.6	2.6	2.2	1.9	2.0	1.7	1.8	1.9	1.8	2.0
Precipitation	PrecAvg	1229	95	80	91	76	75	141	140	157	112	100	68	80
	PrecMax	1470	205	210	157	190	166	246	221	324	174	328	139	236
	PrecMin	884	21	22	8	15	19	54	59	65	10	0	3	19
	PrecStd	174	52	40	47	46	43	60	44	60	48	78	44	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	27.2	28.9	31.1	35.1	36.4	37.2	36.3	34.0	31.4	27.5	25.8
		MCWB	17.7	18.4	18.1	20.8	22.8	24.2	24.3	24.9	23.4	22.8	20.7	20.2
	2%	DB	22.4	25.0	27.2	29.1	32.4	35.0	36.0	34.9	32.6	29.9	25.9	22.6
		MCWB	16.9	18.2	17.9	21.1	21.6	24.1	24.4	24.5	23.6	22.3	19.3	17.5
	5%	DB	20.1	22.4	25.0	27.6	31.0	32.9	34.7	32.9	32.0	27.7	22.9	21.0
		MCWB	15.6	16.2	16.9	19.9	21.7	23.9	24.6	24.5	23.8	21.2	18.5	17.4
	10%	DB	17.7	20.2	22.4	26.1	28.9	32.2	32.7	32.3	30.3	26.3	22.0	18.7
		MCWB	14.6	15.3	16.4	19.0	21.6	23.6	24.5	24.5	23.3	20.6	18.2	15.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	20.3	21.2	27.1	25.6	27.1	27.7	27.9	27.1	25.5	23.1	22.0
		MCDB	22.0	23.8	23.7	28.1	26.7	30.3	30.7	30.0	28.3	27.1	25.5	24.3
	2%	WB	18.3	19.1	20.0	23.2	23.9	26.1	27.1	27.3	25.9	24.4	22.1	19.7
		MCDB	21.0	23.0	23.3	26.0	28.5	29.6	30.2	29.8	28.4	27.7	24.0	22.1
	5%	WB	17.2	18.0	18.8	22.0	23.0	25.5	26.3	26.6	25.2	23.4	20.6	17.9
		MCDB	19.0	21.3	23.2	25.0	27.7	29.6	29.7	29.4	28.7	26.4	22.4	19.7
	10%	WB	15.8	16.7	17.6	20.7	22.4	25.0	25.8	26.0	24.6	22.4	18.6	16.7
		MCDB	17.9	19.5	20.9	24.0	26.8	29.4	29.6	29.1	28.5	25.0	21.9	18.6
Mean Daily Temperature Range	5% DB	MDBR	11.6	12.5	12.9	13.5	11.8	10.9	10.6	9.8	10.4	12.1	12.8	11.2
		MCDBR	13.6	14.3	14.7	15.0	14.1	12.2	12.1	11.0	11.6	12.2	13.5	13.3
		MCWBR	8.4	8.0	6.9	6.5	5.1	4.1	4.1	3.9	4.4	5.6	8.0	8.8
	5% WB	MCDBR	11.0	12.5	11.9	11.2	10.7	10.7	10.4	9.7	10.0	9.9	9.4	10.9
		MCWBR	8.1	8.1	6.5	5.7	4.5	4.2	4.3	4.1	4.5	5.4	6.9	8.4
Clear-Sky Solar Irradiance	taub	0.327	0.336	0.368	0.404	0.465	0.505	0.537	0.516	0.433	0.397	0.349	0.330	
	taud	2.516	2.485	2.418	2.309	2.179	2.112	2.043	2.098	2.326	2.391	2.490	2.540	
	Ebn at Noon	892	919	910	886	832	795	767	777	833	838	857	868	
	Edh at Noon	85	97	111	130	149	159	170	158	121	105	87	79	
All-Sky Solar Radiation	RadAvg	2.89	3.53	4.62	5.86	6.28	6.38	6.17	5.59	4.77	4.12	3.20	2.56	
	RadStd	0.15	0.35	0.39	0.38	0.44	0.45	0.40	0.34	0.40	0.46	0.23	0.21	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+202	+142

Nomenclature: See separate page