

CONWAY-HORRY COUNTY AP, SC, USA

WMO: 720613

Lat: 33.828N

Lon: 79.122W

Elev: 10

StdP: 101.20

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00204

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-2.4	-12.7	1.3	-0.5	-9.9	1.6	0.5	7.5	15.0	6.5	12.9	0.5	20	0.349

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	34.9	25.6	32.9	25.1	32.3	24.9	27.8	30.8	26.9	29.6	26.1	29.1	2.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.1	29.6	26.2	21.7	27.9	25.2	20.4	27.0	88.6	31.2	83.9	31.2	81.3	28.4	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
6.6	5.5	4.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-8.7	36.3	2.6	1.7	-10.6	37.5	-12.1	38.5	-13.5	39.5	-15.4	40.7		
			-9.4	27.9	2.7	0.5	-11.4	28.2	-12.9	28.5	-14.4	28.8	-16.3	29.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	7.3	9.6	12.0	17.2	21.6	25.5	26.7	26.1	23.8	18.0	11.8	9.7
	DBStd	7.95	5.57	5.09	5.14	3.90	3.15	2.49	1.88	1.82	2.49	4.10	4.41	5.03
	HDD10.0	327	121	65	39	1	0	0	0	0	0	1	29	70
	HDD18.3	1401	343	247	203	66	11	0	0	0	1	56	202	272
	CDD10.0	3056	37	54	103	217	358	465	519	498	414	250	82	60
	CDD18.3	1088	1	3	8	31	110	215	261	240	164	46	5	4
	CDH23.3	9484	6	27	86	311	938	2001	2479	2037	1209	347	28	14
	CDH26.7	3638	0	1	11	59	294	852	1107	825	427	61	1	0
Wind	WSAvg	1.6	1.5	1.8	1.9	2.1	1.7	1.6	1.6	1.3	1.5	1.4	1.4	1.4
Precipitation	PrecAvg	1298	106	88	102	75	101	133	170	165	134	79	68	83
	PrecMax	1743	217	238	274	219	302	358	392	406	518	239	154	289
	PrecMin	951	24	4	16	2	30	10	41	10	4	0	19	16
	PrecStd	206	53	48	57	48	55	77	84	89	95	61	39	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	26.2	27.8	30.1	34.1	36.2	36.4	35.0	32.7	30.9	26.2	25.2
		MCWB	18.4	18.6	18.4	21.3	22.8	26.2	25.3	26.3	24.9	23.9	20.2	20.8
	2%	DB	21.3	23.0	26.1	27.9	31.4	34.1	35.0	32.9	32.1	27.9	23.7	22.5
		MCWB	17.2	17.5	17.7	20.3	22.4	25.2	25.6	25.7	24.6	22.2	18.8	19.1
	5%	DB	18.9	21.3	23.0	27.1	30.0	32.6	32.9	32.3	31.0	27.1	22.2	21.0
		MCWB	15.6	16.4	16.4	19.9	22.5	24.6	25.3	25.5	24.2	21.6	18.3	18.9
	10%	DB	17.1	18.7	21.3	25.1	27.8	31.3	32.2	31.2	29.8	25.2	20.2	18.7
		MCWB	14.5	15.1	15.8	18.7	21.7	24.3	25.3	25.0	24.1	20.6	17.2	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.8	20.5	20.4	23.7	25.6	28.7	29.0	28.9	26.7	26.0	22.3	21.9
		MCDB	22.2	22.9	23.8	27.0	28.9	33.9	33.2	32.1	28.7	27.0	24.3	24.1
	2%	WB	18.3	19.3	19.4	22.5	24.4	27.4	27.7	27.6	26.0	24.7	20.9	20.7
		MCDB	20.4	22.9	23.9	25.7	28.5	30.5	30.7	29.6	28.5	26.7	22.1	21.9
	5%	WB	17.0	17.7	18.3	21.3	23.5	26.3	26.6	26.7	25.4	23.2	19.4	18.9
		MCDB	18.1	19.6	21.9	24.7	27.3	29.5	29.8	29.0	28.4	25.5	21.4	20.4
	10%	WB	14.8	15.9	17.3	20.3	22.8	25.3	25.9	26.0	24.8	22.2	17.8	17.1
		MCDB	16.4	18.0	19.6	23.5	26.2	28.8	29.5	28.7	28.1	24.3	19.1	18.2
Mean Daily Temperature Range	5% DB	MDBR	11.8	12.4	13.3	13.4	11.9	11.1	10.6	9.8	10.3	12.1	13.0	11.2
		MCDBR	14.9	14.7	15.3	15.1	14.0	12.3	12.0	11.2	12.0	12.9	14.1	13.0
		MCWBR	10.4	9.3	8.0	7.8	6.2	4.8	4.5	4.7	5.5	7.1	9.3	9.3
	5% WB	MCDBR	12.5	13.5	12.6	12.3	11.1	11.3	10.6	9.6	10.1	9.7	11.6	11.7
		MCWBR	10.2	10.2	7.3	7.2	5.8	5.3	4.9	4.7	5.3	6.1	8.7	9.3
Clear-Sky Solar Irradiance	taub	0.323	0.331	0.366	0.399	0.464	0.486	0.533	0.507	0.430	0.396	0.349	0.326	
	taud	2.517	2.493	2.417	2.309	2.184	2.166	2.054	2.118	2.329	2.391	2.481	2.540	
	Ebn at Noon	891	920	909	889	832	809	769	783	833	835	850	866	
	Edh at Noon	84	95	111	129	148	150	167	155	120	104	86	78	
All-Sky Solar Radiation	RadAvg	2.75	3.40	4.55	5.77	6.25	6.45	6.15	5.53	4.73	3.97	3.05	2.44	
	RadStd	0.16	0.34	0.39	0.39	0.45	0.42	0.38	0.29	0.37	0.44	0.24	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+177	+127

Nomenclature: See separate page