

LINCOLN, CA, USA

WMO: 720614

Lat: 38.909N

Lon: 121.351W

Elev: 122

StdP: 14.63

Time Zone: -8.00 (NAP)

Period: 09-19

WBAN: 00205

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.9	30.3	19.0	14.4	49.0	22.9	17.3	51.1	26.3	52.3	23.7	53.7	2.9	80	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.1	101.6	66.7	98.9	66.2	95.5	65.2	69.6	95.2	68.2	93.8	66.9	91.9	5.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	80.9	73.4	59.2	75.3	74.0	57.1	69.8	72.0	33.6	95.2	32.4	93.1	31.3	91.5	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	17.6	15.3	DB	23.2	105.8	3.3	2.0	20.8	107.2	18.9	108.4	17.0	109.6	14.6	111.0	(4)
(5)			WB	22.7	71.9	3.3	1.7	20.3	73.1	18.4	74.1	16.6	75.1	14.2	76.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	46.4	49.8	53.9	58.5	64.6	73.5	78.4	76.6	72.0	62.5	51.7	45.7		
	DBStd	12.51	4.54	4.79	4.74	5.71	5.59	6.40	4.35	4.06	5.46	5.29	5.52	5.27		
	HDD50	408	128	59	18	4	0	0	0	0	0	0	44	155		
	HDD65	2752	575	426	344	205	75	9	0	0	9	113	398	598		
	CDD50	4496	18	53	139	259	453	706	879	823	661	387	96	22		
	CDD65	1366	0	0	0	10	63	265	414	358	221	35	0	0		
	CDH74	20032	0	0	37	365	1270	3939	5757	4743	3097	798	26	0		
	CDH80	10839	0	0	2	87	496	2222	3455	2698	1631	248	0	0		
(14) Wind	WSAvg	6.0	5.0	6.6	6.7	6.4	7.1	6.7	6.9	6.4	5.6	5.2	4.7	5.3		
(15) Precipitation	PrecAvg	24.5	4.7	4.2	3.5	1.9	1.1	0.3	0.0	0.0	0.1	1.3	2.4	5.0		
	PrecMax	40.1	12.8	12.0	11.3	6.7	4.5	1.6	0.1	0.6	0.5	4.3	5.3	11.4		
	PrecMin	9.8	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.6		
	PrecStd	7.0	3.4	2.9	3.2	1.5	1.1	0.5	0.0	0.1	0.2	1.1	1.5	3.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.9	72.0	78.9	87.7	94.9	105.7	105.6	104.1	100.1	91.3	77.3	64.0		
		MCWB	50.4	56.8	59.6	61.9	63.1	68.9	67.5	66.8	65.0	61.6	58.6	53.9		
	2%	DB	63.1	68.0	73.3	81.9	90.2	100.1	100.5	99.2	96.9	86.3	72.9	61.1		
		MCWB	50.5	54.7	56.3	60.9	62.0	67.3	66.6	66.0	64.7	60.6	56.1	51.8		
	5%	DB	59.4	63.8	71.6	78.9	86.1	96.9	99.0	96.6	93.0	81.7	69.6	58.9		
		MCWB	50.9	53.1	56.8	59.8	60.8	65.7	66.4	65.6	63.7	58.5	54.8	51.2		
	10%	DB	55.4	61.2	66.5	72.9	81.3	91.4	96.6	93.0	90.1	78.8	63.8	55.3		
		MCWB	49.7	51.8	54.5	57.4	59.4	63.7	65.9	65.0	63.1	57.8	52.5	49.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.4	58.9	61.8	66.5	66.1	71.6	72.0	70.1	68.3	65.8	61.3	57.8		
		MCDB	60.9	65.0	75.3	82.5	88.7	96.6	98.2	95.6	93.4	78.7	74.4	61.6		
	2%	WB	54.0	57.1	59.3	63.0	64.1	69.4	70.0	68.4	66.6	63.1	58.9	55.5		
		MCDB	58.1	64.3	69.6	77.1	84.9	94.9	96.0	94.3	91.8	79.5	69.1	59.5		
	5%	WB	52.4	55.2	57.4	60.6	62.1	67.8	68.3	67.1	65.5	61.5	56.7	53.8		
		MCDB	55.9	62.0	66.8	75.1	81.8	92.7	94.5	92.8	89.5	76.7	64.5	55.9		
	10%	WB	50.9	53.6	55.8	58.9	60.4	65.9	66.6	65.8	64.0	59.7	54.6	51.9		
		MCDB	54.8	59.3	64.8	72.1	78.9	88.3	92.5	90.3	86.4	74.3	61.2	54.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	21.1	22.5	25.9	28.7	32.7	34.1	33.5	32.7	30.0	24.3	19.8		
		MCDBR	26.0	27.2	31.8	34.6	37.8	39.0	37.7	36.9	38.7	36.4	32.8	22.8		
		MCWBR	16.0	15.8	16.6	16.5	14.1	12.4	12.9	12.8	13.7	15.1	16.8	13.9		
	5% WB	MCDBR	18.5	21.9	26.0	31.0	34.1	36.7	35.7	34.4	35.0	29.4	25.3	13.8		
		MCWBR	12.8	13.6	14.5	15.8	13.7	12.2	13.0	12.5	12.9	12.8	14.2	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.326	0.351	0.358	0.374	0.366	0.364	0.347	0.357	0.349	0.328	0.338		
	taud		2.506	2.505	2.419	2.399	2.376	2.407	2.405	2.442	2.425	2.443	2.492	2.441		
	Ebn at Noon		271	286	288	292	287	288	288	291	282	272	266	253		
	Edh at Noon		25	28	34	36	38	37	37	35	33	30	25	25		
(44) All-Sky Solar Radiation	RadAvg		687	1000	1425	1898	2321	2616	2613	2338	1886	1321	837	606		
	RadStd		124	134	161	174	153	113	81	77	69	93	66	103		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (44 neighbors)	+0.74	N/A	-2.00	N/A	N/A	N/A	N/A	-200	+250	+81

Nomenclature: See separate page