

PAMPA MESA VISTA, TX, USA

WMO: 720626

Lat: 35.883N

Lon: 101.033W

Elev: 2773

StdP: 13.28

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 00213

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	15.6	-0.1	6.0	19.3	3.1	7.1	24.1	29.1	58.3	26.6	54.8	7.2	10	0.598

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.7	102.3	66.7	99.3	67.0	97.0	67.5	72.5	87.8	71.4	87.3	70.5	86.3	14.2	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.5	116.1	76.2	67.9	113.7	75.8	66.0	106.3	75.3	38.0	87.8	37.0	87.1	36.2	87.0	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.7	25.9	23.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			-1.1	74.3	3.1	1.6	-3.4	75.5	-5.2	76.5	-7.0	77.4	-9.2	78.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.3	38.4	39.9	50.6	58.0	66.4	78.6	81.1	79.7	72.6	58.9	48.1	38.2
	DBStd	17.93	9.78	11.70	10.20	9.27	8.92	6.21	5.69	5.32	6.82	9.32	9.54	9.51
	HDD50	1390	375	317	113	32	4	0	0	0	0	29	144	376
	HDD65	3915	826	704	457	245	94	1	1	0	19	229	509	830
	CDD50	4786	14	34	132	271	511	857	964	922	677	306	87	11
	CDD65	1834	0	1	11	34	136	407	499	457	246	41	2	0
	CDH74	23854	4	59	291	710	2000	5227	6483	5519	2762	693	103	3
	CDH80	12653	0	16	90	275	942	2896	3786	3090	1298	242	18	0
Wind	WSAvg	10.2	8.7	9.6	10.9	12.6	11.4	12.1	9.9	8.9	9.6	9.8	9.8	8.9
Precipitation	PrecAvg	21.0	0.6	0.6	0.9	1.9	3.1	2.9	2.9	2.8	1.7	1.5	0.9	0.9
	PrecMax	41.1	1.9	1.5	4.5	8.5	9.9	6.2	8.6	5.2	4.7	5.1	4.6	3.8
	PrecMin	11.8	0.0	0.0	0.0	0.0	0.5	0.1	0.6	0.4	0.0	0.0	0.0	0.1
	PrecStd	5.3	0.5	0.5	1.0	1.9	1.8	1.7	1.7	1.3	1.2	1.5	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.8	81.2	88.1	91.5	99.4	106.4	106.5	104.4	99.0	91.2	82.1	72.0
		MCWB	49.3	52.6	56.7	57.4	59.9	65.4	67.1	67.8	65.6	60.2	54.5	49.4
	2%	DB	68.0	73.0	81.8	88.0	94.5	100.4	102.3	100.0	95.1	86.3	77.0	64.1
		MCWB	47.3	49.3	55.4	56.6	60.2	65.5	67.6	68.0	66.2	60.4	52.6	46.6
	5%	DB	61.3	67.8	76.6	81.9	90.0	97.2	99.4	97.4	91.0	81.7	71.5	60.8
		MCWB	44.1	47.8	52.9	56.2	60.3	67.2	67.5	68.7	66.1	59.4	52.0	45.0
	10%	DB	55.2	60.9	70.2	77.1	85.8	93.9	96.9	94.7	88.1	77.1	64.4	54.5
		MCWB	41.5	44.2	50.6	55.7	60.9	67.8	68.4	68.2	65.5	58.0	49.1	42.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	55.5	61.5	65.1	70.4	73.2	75.0	73.7	71.1	68.7	58.4	53.4
		MCDB	71.6	75.4	75.3	75.7	80.6	89.7	88.0	88.3	86.1	78.6	68.0	61.1
	2%	WB	47.6	50.9	58.8	61.7	68.2	71.7	72.7	72.2	69.7	65.5	55.5	49.0
		MCDB	65.7	70.6	73.1	74.8	79.2	88.6	87.3	87.7	84.3	75.3	69.6	63.6
	5%	WB	44.9	48.2	55.7	59.5	66.3	70.8	71.4	71.1	68.7	63.1	53.4	45.9
		MCDB	60.5	66.1	71.3	71.8	78.4	87.3	87.0	87.1	82.9	72.9	67.1	57.4
	10%	WB	42.3	45.3	52.6	57.4	64.0	69.7	70.4	70.0	67.7	60.6	50.8	43.1
		MCDB	55.0	61.0	68.6	72.9	76.9	85.7	86.3	86.1	81.6	72.9	64.7	54.6
Mean Daily Temperature Range	5% DB	MDBR	28.1	27.5	30.1	28.9	28.3	26.9	25.7	26.9	26.2	28.2	28.4	25.3
		MCDBR	35.1	38.4	37.5	37.7	35.3	30.8	30.2	30.3	30.9	35.0	35.7	33.1
		MCWBR	18.7	18.7	16.2	16.0	13.9	9.2	7.4	8.0	9.0	14.5	16.8	18.1
	5% WB	MCDBR	34.3	37.8	33.3	27.8	27.7	25.5	24.9	26.8	24.4	25.4	31.1	30.5
MCWBR		18.5	19.3	15.2	13.7	13.7	8.9	7.9	8.5	8.2	13.1	16.3	17.5	
Clear-Sky Solar Irradiance	taub		0.260	0.268	0.299	0.331	0.348	0.384	0.388	0.377	0.345	0.306	0.279	0.261
	taud		2.584	2.576	2.489	2.415	2.431	2.376	2.399	2.394	2.465	2.558	2.558	2.587
	Ebn at Noon		305	313	309	302	296	284	282	284	289	294	294	298
	Edh at Noon		23	27	32	36	36	38	37	37	33	27	24	22
All-Sky Solar Radiation	RadAvg		951	1202	1589	1969	2198	2355	2293	2041	1742	1309	1013	825
	RadStd		84	118	118	120	169	148	102	105	85	154	101	60

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+196	N/A

Nomenclature: See separate page