

CRYSTAL RIVER, FL, USA

WMO: 720655

Lat: 28.867N

Lon: 82.567W

Elev: 10

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00235

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 30.0	(c) 34.1	(d) 19.0	(e) 14.3	(f) 39.4	(g) 25.0	(h) 19.1	(i) 40.8	(j) 18.3	(k) 60.5	(l) 16.5	(m) 58.9	(n) 0.9	(o) 30	(p) 0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.4	(c) 93.3	(d) 78.7	(e) 91.4	(f) 77.6	(g) 90.6	(h) 77.3	(i) 81.9	(j) 90.5	(k) 80.7	(l) 88.7	(m) 79.6	(n) 87.1	(o) 6.0	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.3	86.4	78.9	149.8	85.5	77.3	142.1	83.2	45.6	91.5	44.0	89.2	43.0	86.7	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.3	(b) 12.6	(c) 11.1	(e) 25.4	(f) 95.8	(g) 4.9	(h) 1.8	(i) 21.9	(j) 97.1	(k) 19.0	(l) 98.2	(m) 16.2	(n) 99.2	(o) 12.6	(p) 100.5		
(4) 15.3	(5) 12.6	(6) 11.1	(7) 25.4	(8) 95.8	(9) 4.9	(10) 1.8	(11) 21.9	(12) 97.1	(13) 19.0	(14) 98.2	(15) 16.2	(16) 99.2	(17) 12.6	(18) 100.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.5	55.6	60.4	62.5	69.9	75.3	80.1	81.1	81.7	80.1	73.3	64.5	60.9		
	DBStd	10.96	9.34	8.90	7.65	4.83	4.53	2.50	2.18	2.18	2.38	6.39	7.50	9.27		
	HDD50	104	52	19	8	0	0	0	0	0	0	0	3	22		
	HDD65	939	314	175	135	14	3	0	0	0	0	16	98	184		
	CDD50	7592	225	311	397	597	786	903	965	983	902	723	439	361		
	CDD65	2950	21	47	59	161	323	453	500	518	452	274	84	58		
	CDH74	27299	154	311	501	1412	3242	4510	4882	5092	4012	2246	584	353		
	CDH80	10678	11	41	64	333	1276	2008	2148	2217	1705	741	98	36		
(14) Wind	WSAvg	3.8	4.3	4.1	4.6	4.5	4.0	3.3	2.6	2.9	3.3	3.9	3.8	3.8		
(15) Precipitation	PrecAvg	51.3	3.0	2.7	3.5	2.5	2.9	7.6	8.1	8.1	6.5	2.8	1.7	2.3		
	PrecMax	65.2	6.9	8.7	7.7	5.4	13.0	18.2	14.1	13.4	16.2	6.9	6.6	11.0		
	PrecMin	37.1	0.7	0.4	0.1	0.2	0.3	1.1	4.4	5.3	2.2	0.1	0.2	0.3		
	PrecStd	7.2	1.5	1.9	2.2	1.3	2.7	3.8	2.4	2.0	3.2	1.6	1.3	2.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.8	84.1	84.4	89.9	92.9	95.2	96.7	95.3	93.0	91.1	86.4	82.4		
		MCWB	69.2	70.2	66.8	72.0	74.3	78.4	80.0	79.2	77.6	78.1	74.4	71.6		
	2%	DB	79.0	81.2	81.6	86.3	90.5	92.9	92.9	92.9	91.1	89.5	82.2	81.2		
		MCWB	67.5	69.2	67.2	70.0	73.5	78.4	79.2	79.8	76.8	76.1	70.9	70.7		
	5%	DB	74.9	78.8	79.5	83.6	89.5	90.9	90.8	90.9	90.3	86.5	80.7	78.8		
		MCWB	65.9	67.9	66.4	69.5	73.2	77.6	78.0	78.7	76.8	74.2	69.4	68.8		
	10%	DB	71.8	73.4	77.0	81.4	87.6	89.8	89.9	90.1	88.5	84.1	77.4	75.0		
		MCWB	64.1	65.2	65.5	68.2	72.9	77.3	77.9	78.5	76.5	72.5	67.2	67.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.4	72.6	72.0	75.3	78.4	82.5	83.4	83.5	81.4	80.9	75.4	74.3		
		MCDB	78.7	79.9	78.2	82.5	88.2	91.9	94.1	92.6	89.1	89.2	83.1	80.2		
	2%	WB	69.7	70.8	70.5	73.6	77.0	81.0	81.1	82.0	79.9	78.2	73.5	72.9		
		MCDB	75.0	77.4	76.7	80.9	85.9	90.1	89.3	90.5	87.6	85.1	79.6	78.5		
	5%	WB	67.5	69.5	69.2	72.1	75.8	79.3	79.9	80.8	78.5	76.6	72.1	71.2		
		MCDB	73.2	75.2	75.6	80.5	84.4	88.3	87.7	88.5	86.2	83.6	77.2	75.9		
	10%	WB	65.3	67.9	67.3	70.6	74.8	78.1	78.8	79.5	77.8	75.1	70.0	69.6		
		MCDB	70.7	74.2	74.4	78.4	83.2	86.7	86.4	86.0	85.5	81.6	74.7	73.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	23.4	22.2	23.5	22.6	22.0	17.9	17.0	16.4	17.6	20.8	22.6	22.1		
		MCDBR	24.5	23.1	25.1	25.5	24.3	20.9	19.4	18.2	19.3	20.3	22.6	22.0		
	5% WB	MCWBR	14.7	12.5	12.7	10.8	9.7	8.8	7.9	7.4	7.5	8.6	11.9	12.5		
		MCWBR	20.5	20.0	20.7	20.3	20.6	18.6	17.4	16.8	17.0	16.9	18.1	18.7		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.352	0.367	0.389	0.426	0.457	0.490	0.469	0.423	0.389	0.353	0.340		
	taud		2.512	2.484	2.438	2.350	2.303	2.291	2.201	2.273	2.378	2.448	2.494	2.537		
	Ebn at Noon		285	291	292	287	276	265	256	261	271	275	278	280		
	Edh at Noon		29	32	36	40	42	43	46	43	37	33	29	27		
(44) All-Sky Solar Radiation	RadAvg		1080	1291	1658	1995	2120	1900	1792	1730	1582	1450	1182	990		
	RadStd		74	102	144	117	128	140	120	112	115	100	66	83		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-11	-97	+284	+205

Nomenclature: See separate page