

CRYSTAL RIVER, FL, USA

WMO: 720655

Lat: 28.867N

Lon: 82.567W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00235

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	1.2	-7.2	2.0	4.1	-3.9	2.7	4.9	8.2	15.9	7.4	15.0	0.4	30	0.314

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	34.0	26.0	33.0	25.3	32.6	25.2	27.7	32.5	27.0	31.5	26.4	30.6	2.7	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	30.2	26.0	21.4	29.7	25.2	20.3	28.5	88.1	33.1	84.5	31.8	82.1	30.4	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.8	5.6	4.9	-3.7	35.4	2.7	1.0	-5.6	36.2	-7.2	36.8	-8.8	37.3	-10.8	38.1		
(5)			-4.6	28.1	2.6	1.0	-6.4	28.8	-7.9	29.3	-9.3	29.9	-11.2	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.4	13.1	15.8	17.0	21.1	24.1	26.7	27.3	27.6	26.7	23.0	18.1	16.1		
	DBStd	6.09	5.19	4.94	4.25	2.69	2.51	1.39	1.21	1.21	1.32	3.55	4.17	5.15		
	HDD10.0	58	29	11	4	0	0	0	0	0	0	0	2	12		
	HDD18.3	522	174	97	75	8	2	0	0	0	0	9	54	102		
	CDD10.0	4218	125	173	221	332	437	502	536	546	501	402	244	201		
	CDD18.3	1639	12	26	33	89	179	252	278	288	251	152	47	32		
	CDH23.3	15166	86	173	278	784	1801	2506	2712	2829	2229	1248	324	196		
(13)	CDH26.7	5932	6	23	36	185	709	1116	1193	1232	947	412	54	20		
(14)	Wind	WSAvg	1.7	1.9	1.8	2.0	2.0	1.8	1.5	1.2	1.3	1.5	1.8	1.7		
(15) Precipitation	PrecAvg	1302	76	68	90	63	73	193	205	206	165	72	44	58		
	PrecMax	1655	174	221	196	138	330	462	359	340	412	176	167	280		
	PrecMin	943	18	11	3	6	8	29	113	134	56	3	5	8		
	PrecStd	182	39	47	56	32	69	96	62	51	82	40	34	64		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.6	28.9	29.1	32.1	33.8	35.1	36.0	35.2	33.9	32.8	30.2	28.0		
		MCWB	20.7	21.2	19.3	22.2	23.5	25.8	26.7	26.2	25.4	25.6	23.6	22.0		
	2%	DB	26.1	27.3	27.5	30.1	32.5	33.8	33.8	33.8	32.8	32.0	27.9	27.3		
		MCWB	19.7	20.7	19.6	21.1	23.1	25.8	26.2	26.5	24.9	24.5	21.6	21.5		
	5%	DB	23.9	26.0	26.4	28.7	32.0	32.7	32.7	32.7	32.4	30.3	27.1	26.0		
		MCWB	18.8	19.9	19.1	20.8	22.9	25.3	25.6	26.0	24.9	23.4	20.8	20.5		
	10%	DB	22.1	23.0	25.0	27.5	30.9	32.1	32.2	32.3	31.4	28.9	25.2	23.9		
		MCWB	17.8	18.4	18.6	20.1	22.7	25.2	25.5	25.8	24.7	22.5	19.6	19.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	22.5	22.2	24.1	25.8	28.0	28.5	28.6	27.4	27.2	24.1	23.5		
		MCDB	25.9	26.6	25.6	28.1	31.2	33.3	34.5	33.6	31.7	31.8	28.4	26.8		
	2%	WB	21.0	21.6	21.4	23.1	25.0	27.2	27.3	27.8	26.6	25.7	23.1	22.7		
		MCDB	23.9	25.2	24.8	27.2	30.0	32.3	31.9	32.5	30.9	29.5	26.4	25.8		
	5%	WB	19.7	20.8	20.7	22.3	24.3	26.3	26.6	27.1	25.8	24.8	22.3	21.8		
		MCDB	22.9	24.0	24.2	26.9	29.1	31.3	30.9	31.4	30.1	28.7	25.1	24.4		
	10%	WB	18.5	19.9	19.6	21.4	23.8	25.6	26.0	26.4	25.4	23.9	21.1	20.9		
		MCDB	21.5	23.4	23.5	25.8	28.4	30.4	30.2	30.0	29.7	27.6	23.7	22.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	12.3	13.0	12.6	12.2	10.0	9.5	9.1	9.8	11.6	12.6	12.3		
		MCDBR	13.6	12.9	13.9	14.2	13.5	11.6	10.8	10.1	10.7	11.3	12.6	12.2		
	5% WB	MCWBR	8.2	6.9	7.1	6.0	5.4	4.9	4.4	4.1	4.2	4.8	6.6	7.0		
		MCWBR	11.4	11.1	11.5	11.3	11.4	10.3	9.7	9.3	9.4	9.4	10.1	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.352	0.367	0.389	0.426	0.457	0.490	0.469	0.423	0.389	0.353	0.340		
	taud		2.512	2.484	2.438	2.350	2.303	2.291	2.201	2.273	2.378	2.448	2.494	2.537		
	Ebn at Noon		900	917	922	906	869	836	808	824	854	866	877	884		
	Edh at Noon		90	101	112	126	133	134	146	135	118	103	91	85		
(44) All-Sky Solar Radiation	RadAvg		3.40	4.07	5.23	6.29	6.68	5.99	5.65	5.45	4.99	4.57	3.73	3.12		
	RadStd		0.23	0.32	0.45	0.37	0.40	0.44	0.38	0.35	0.36	0.32	0.21	0.26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	-6	-54	+158	+114

Nomenclature: See separate page