

WEST GEORGIA, GA, USA

WMO: 720674

Lat: 33.633N

Lon: 85.150W

Elev: 1162

StdP: 14.09

Time Zone: -5.00 (NAE)

Period: 10-19

WBAN: 00249

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 20.9	(c) 25.4	(d) -9.3	(e) 3.5	(f) 48.1	(g) 1.4	(h) 6.2	(i) 38.1	(j) 18.7	(k) 37.5	(l) 16.8	(m) 36.7	(n) 5.7	(o) 330	(p) 0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 18.7	(c) 93.0	(d) 74.4	(e) 91.0	(f) 74.0	(g) 89.8	(h) 73.6	(i) 78.2	(j) 86.4	(k) 77.2	(l) 85.2	(m) 76.2	(n) 84.4	(o) 4.7	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	144.9	81.2	75.0	137.3	80.2	73.5	130.3	79.0	42.7	86.9	41.5	84.2	40.4	84.8	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 15.8	(b) 12.9	(c) 11.4	(d) DB	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A
(a) 15.8	(b) 12.9	(c) 11.4	(d) WB	(e) 15.4	(f) 79.4	(g) 3.6	(h) 1.4	(i) 12.7	(j) 80.4	(k) 10.6	(l) 81.2	(m) 8.6	(n) 82.0	(o) 5.9	(p) 83.0	(q) 81.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	42.3	47.7	54.0	61.8	69.2	76.1	78.8	78.0	73.5	62.7	52.2	47.1
	DBStd	14.46	9.78	9.90	8.64	6.67	6.20	3.78	3.21	3.57	5.14	7.50	7.84	9.04
	HDD50	730	277	151	59	4	0	0	0	0	0	6	65	168
	HDD65	2796	703	486	350	137	38	0	0	0	5	132	389	556
	CDD50	5120	39	88	184	358	594	783	893	869	704	399	130	79
	CDD65	1712	0	3	11	40	167	333	428	405	259	60	4	2
	CDH74	15034	0	9	109	491	1511	2859	3871	3457	2186	514	27	0
	CDH80	5797	0	0	10	64	442	1148	1684	1450	884	112	3	0
Wind	WSAvg	3.8	4.8	5.1	5.4	4.5	3.2	2.8	2.6	2.6	2.6	3.5	4.1	4.4
Precipitation	PrecAvg	51.3	5.0	5.2	5.7	4.1	3.7	4.3	5.2	3.6	3.8	3.1	4.4	4.1
	PrecMax	65.6	9.0	8.3	9.8	7.2	11.8	8.4	15.2	7.2	10.9	9.9	9.9	7.7
	PrecMin	29.2	2.2	2.2	1.7	1.7	0.6	1.5	1.2	0.8	0.6	0.8	1.1	2.5
	PrecStd	9.6	1.7	1.9	2.3	1.7	2.5	1.8	3.3	1.6	2.6	2.2	2.3	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.6	75.3	81.4	84.8	89.8	95.2	95.2	95.2	93.3	87.9	77.6	72.3
		MCWB	60.6	64.2	62.8	65.3	70.6	74.2	75.2	75.3	71.2	70.8	60.6	65.5
	2%	DB	65.0	71.0	77.3	81.7	87.3	91.3	92.7	92.0	91.0	82.4	72.5	68.5
		MCWB	56.5	61.2	61.5	64.5	69.7	74.1	75.7	74.5	71.2	67.1	58.7	63.0
	5%	DB	61.4	66.7	73.0	79.6	85.0	89.9	90.7	90.2	88.9	79.5	69.0	65.9
		MCWB	56.2	59.3	59.9	63.7	69.3	73.9	75.5	73.8	71.2	65.9	59.8	61.1
	10%	DB	58.1	63.7	69.4	77.0	82.1	86.5	88.5	88.0	85.8	76.6	66.2	62.7
		MCWB	52.9	57.5	58.1	62.5	68.3	73.2	75.3	73.9	71.5	64.3	57.5	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.4	66.0	66.2	70.7	73.9	78.7	80.1	79.7	75.6	73.3	68.8	69.3
		MCDB	66.8	71.1	74.3	78.2	81.4	87.5	89.4	88.2	84.1	79.9	70.3	70.3
	2%	WB	61.0	63.5	64.4	68.4	72.6	77.3	78.3	78.1	74.6	71.9	66.1	65.8
		MCDB	63.7	67.7	71.1	76.0	81.1	86.3	86.7	85.5	83.1	79.1	68.8	67.6
	5%	WB	57.9	62.1	63.1	66.5	71.4	75.9	77.3	77.0	73.7	69.8	62.8	61.3
		MCDB	60.5	65.9	69.3	74.9	80.8	85.0	85.7	84.1	81.9	74.7	66.1	63.7
	10%	WB	53.4	59.7	61.0	64.8	70.3	74.6	76.3	75.9	72.7	67.6	59.5	57.6
		MCDB	56.2	63.0	67.6	72.8	79.0	83.3	84.8	83.3	81.1	73.2	62.8	61.1
Mean Daily Temperature Range	5% DB	MDBR	19.3	19.3	21.3	24.1	21.8	19.4	18.7	18.5	20.9	22.4	21.5	17.6
		MCDBR	22.9	22.4	26.5	27.3	25.2	23.6	21.5	22.1	25.9	25.7	22.9	19.2
		MCWBR	16.2	14.3	12.8	12.1	10.0	8.1	7.0	6.9	8.7	11.2	14.0	14.2
	5% WB	MCDBR	18.7	18.8	21.1	22.2	21.0	19.8	19.2	18.2	20.3	18.2	19.0	17.5
	MCWBR	16.2	14.1	12.0	11.1	9.0	8.3	7.0	6.5	7.8	9.5	14.4	15.0	
Clear-Sky Solar Irradiance	taub	0.313	0.316	0.350	0.387	0.455	0.480	0.528	0.528	0.422	0.365	0.336	0.315	
	taud	2.524	2.509	2.436	2.315	2.160	2.138	2.016	2.004	2.298	2.447	2.468	2.532	
	Ebn at Noon	287	298	294	286	266	258	245	243	267	276	275	279	
	Edh at Noon	26	30	35	41	48	49	55	55	39	31	28	25	
All-Sky Solar Radiation	RadAvg	845	1016	1367	1743	1913	1947	1872	1727	1501	1269	944	718	
	RadStd	53	129	121	114	162	156	133	102	144	164	100	74	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+200

Nomenclature: See separate page