

NAMPA, ID, USA

WMO: 720734

Lat: 43.581N

Lon: 116.523W

Elev: 2537

StdP: 13.40

Time Zone: -7.00 (NAM)

Period: 10-19

WBAN: 00264

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.7	13.6	1.3	6.5	11.9	7.1	8.7	18.2	18.6	39.4	16.7	37.9	2.1	140	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.1	97.3	63.1	94.7	62.8	91.3	61.5	66.1	87.9	64.5	86.9	63.5	85.9	6.8	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.8	87.3	67.1	57.3	77.1	67.5	55.2	71.3	67.2	32.0	86.6	30.9	86.5	30.1	87.2	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.1	16.8	14.8	DB	3.2	103.0	7.5	3.3	-2.2	105.3	-6.6	107.3	-10.7	109.1	-16.2	111.4
			WB	2.7	68.6	7.2	1.7	-2.5	69.8	-6.7	70.8	-10.7	71.7	-15.9	72.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	30.4	37.2	45.1	50.6	59.3	67.5	76.1	73.7	63.9	51.4	39.3	31.3
	DBStd	16.89	9.06	7.06	6.02	6.19	6.67	7.18	5.07	5.14	6.55	7.03	8.40	8.77
	HDD50	2189	607	360	173	65	9	0	0	0	2	63	329	581
	HDD65	5495	1072	777	616	432	197	55	2	6	96	425	772	1045
	CDD50	3012	0	3	22	85	297	525	810	736	420	106	7	1
	CDD65	843	0	0	0	1	20	130	347	277	65	3	0	0
	CDH74	12319	0	0	0	67	463	1926	4830	3817	1146	70	0	0
	CDH80	6115	0	0	0	14	115	862	2686	1992	430	16	0	0
	WSAvg	5.7	4.2	6.2	6.9	7.3	6.9	6.6	5.8	5.0	4.8	4.7	5.2	5.4
	PrecAvg	10.6	1.4	0.9	1.0	1.1	1.3	0.7	0.2	0.2	0.3	0.7	1.2	1.4
(15) Precipitation	PrecMax	15.4	3.4	2.2	3.2	2.0	4.1	1.9	0.9	0.6	1.2	2.4	2.1	3.8
	PrecMin	5.5	0.1	0.1	0.1	0.5	0.0	0.2	0.0	0.0	0.0	0.0	0.4	0.4
	PrecStd	2.6	0.8	0.6	0.8	0.5	1.0	0.5	0.2	0.2	0.4	0.6	0.6	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	61.4	70.3	81.5	88.3	99.2	100.3	100.0	92.8	81.7	64.0	55.5
		MCWB	45.7	48.7	52.3	56.7	58.9	65.6	64.5	64.0	62.0	58.2	50.9	46.0
	2%	DB	46.4	56.8	64.3	74.6	82.4	93.0	98.9	95.4	89.6	74.7	59.4	50.3
		MCWB	41.8	45.9	48.6	53.8	57.8	63.0	63.3	62.9	60.4	54.7	48.4	44.8
	5%	DB	44.9	53.8	61.3	69.7	79.3	89.7	95.4	93.1	84.8	69.7	55.2	46.2
		MCWB	40.6	44.8	48.1	51.2	57.2	60.9	62.8	61.9	59.5	52.9	46.4	42.7
	10%	DB	41.3	49.5	57.2	64.2	75.1	84.3	92.9	90.6	81.4	64.4	52.2	42.9
		MCWB	37.8	42.7	46.2	48.9	55.0	59.5	62.2	61.5	58.1	51.0	45.2	39.5
	0.4%	WB	45.8	50.3	54.5	59.1	62.2	68.1	67.8	66.3	66.9	60.1	53.9	49.5
		MCDB	47.9	56.5	61.4	73.8	73.3	93.3	93.9	86.8	76.1	72.0	59.1	53.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	43.7	48.3	51.9	55.8	60.1	65.2	66.0	65.0	64.2	57.3	50.6	46.1
		MCDB	46.0	54.8	59.7	68.2	75.0	88.2	90.2	88.5	77.6	67.4	58.3	48.8
	5%	WB	41.3	45.7	50.1	53.2	58.7	63.0	64.5	63.9	62.0	54.8	48.0	43.7
		MCDB	43.5	50.5	58.4	64.9	74.0	83.5	88.3	87.8	79.1	66.5	54.5	47.3
	10%	WB	38.8	43.2	48.1	50.9	57.1	60.9	63.6	62.7	59.6	52.6	45.5	39.9
		MCDB	41.2	48.4	56.5	62.7	71.4	79.2	87.5	86.1	79.1	63.2	50.2	41.8
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	16.4	21.0	23.1	25.0	26.8	31.1	31.6	29.0	24.6	18.8	13.1
		MCDBR	15.9	22.3	26.7	33.4	32.4	36.1	35.2	35.5	35.3	30.7	23.2	15.2
		MCWBR	11.6	12.7	14.4	15.7	12.0	11.7	10.5	11.0	13.0	14.1	13.5	10.8
	5% WB	MCDBR	15.6	18.6	21.4	28.1	27.1	31.4	32.5	32.8	29.9	25.4	21.6	13.8
		MCWBR	12.6	12.1	12.8	14.2	10.4	10.0	10.0	10.4	11.1	12.7	13.3	10.7
(40) Clear-Sky Solar Irradiance	taub		0.264	0.272	0.288	0.311	0.331	0.328	0.337	0.340	0.317	0.290	0.273	0.265
	taud		2.573	2.592	2.565	2.485	2.448	2.487	2.468	2.441	2.507	2.578	2.577	2.564
	Ebn at Noon		284	299	305	304	298	298	294	290	290	287	277	272
	Edh at Noon		20	24	28	33	35	34	34	34	29	24	20	19
(44) All-Sky Solar Radiation	RadAvg		500	823	1241	1735	2114	2398	2455	2119	1646	1079	629	413
	RadStd		70	108	121	137	142	121	84	89	87	78	52	59

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page