

NAMPA, ID, USA

WMO: 720734

Lat: 43.581N

Lon: 116.523W

Elev: 773

StdP: 92.37

Time Zone: -7.00 (NAM)

Period: 10-19

WBAN: 00264

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.0	-10.2	-17.0	0.9	-11.2	-13.8	1.2	-7.7	8.3	4.1	7.5	3.3	0.9	140	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	36.3	17.3	34.8	17.1	32.9	16.4	18.9	31.1	18.1	30.5	17.5	29.9	3.0	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	12.5	19.5	14.1	11.0	19.7	12.9	10.2	19.6	56.6	30.3	54.1	30.3	52.0	30.6	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	8.5	7.5	6.6	DB	-16.0	39.4	4.2	1.8	-19.0	40.7	-21.4	41.8	-23.7	42.8	-26.8	44.1
(5)				WB	-16.3	20.4	4.0	0.9	-19.1	21.0	-21.5	21.6	-23.7	22.1	-26.6	22.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-0.9	2.9	7.3	10.4	15.2	19.7	24.5	23.2	17.7	10.8	4.0	-0.4	(6)
(7)		DBStd	9.38	5.03	3.92	3.34	3.44	3.70	3.99	2.82	2.85	3.64	3.91	4.67	4.87	(7)
(8)		HDD10.0	1216	337	200	96	36	5	0	0	1	35	183	323		(8)
(9)		HDD18.3	3053	596	432	342	240	109	31	1	3	53	236	429	581	(9)
(10)		CDD10.0	1673	0	2	12	47	165	292	450	409	233	59	4	1	(10)
(11)		CDD18.3	468	0	0	0	1	11	72	193	154	36	2	0	0	(11)
(12)		CDH23.3	6844	0	0	0	37	257	1070	2683	2121	637	39	0	0	(12)
(13)		CDH26.7	3397	0	0	0	8	64	479	1492	1107	239	9	0	0	(13)
(14)	Wind	WSAvg	2.6	1.9	2.8	3.1	3.2	3.1	3.0	2.6	2.2	2.1	2.1	2.3	2.4	(14)
(15)	Precipitation	PrecAvg	269	35	22	25	29	34	17	6	4	8	19	30	36	(15)
(16)		PrecMax	392	86	57	82	52	105	47	24	16	30	62	54	97	(16)
(17)		PrecMin	139	2	3	2	12	1	4	0	0	0	0	10	11	(17)
(18)		PrecStd	66	21	15	21	12	26	12	6	5	9	16	15	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	16.3	21.3	27.5	31.3	37.3	37.9	37.8	33.8	27.6	17.8	13.0	(19)
(20)		MCWB	7.6	9.3	11.3	13.7	14.9	18.7	18.1	17.8	16.6	14.6	10.5	7.8		(20)
(21)		2%	DB	8.0	13.8	17.9	23.7	28.0	33.9	37.1	35.2	32.0	23.7	15.2	10.2	(21)
(22)		MCWB	5.4	7.7	9.2	12.1	14.3	17.2	17.4	17.2	15.8	12.6	9.1	7.1		(22)
(23)		5%	DB	7.2	12.1	16.3	21.0	26.3	32.0	35.2	33.9	29.3	21.0	12.9	7.9	(23)
(24)		MCWB	4.8	7.1	8.9	10.7	14.0	16.1	17.1	16.6	15.3	11.6	8.0	6.0		(24)
(25)		10%	DB	5.2	9.7	14.0	17.9	24.0	29.0	33.9	32.6	27.4	18.0	11.2	6.1	(25)
(26)		MCWB	3.2	5.9	7.9	9.4	12.8	15.3	16.8	16.4	14.5	10.5	7.3	4.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	10.2	12.5	15.1	16.8	20.1	19.9	19.1	19.4	15.6	12.2	9.7	(27)
(28)		MCDWB	8.8	13.6	16.3	23.2	22.9	34.1	34.4	30.4	24.5	22.2	15.1	12.0		(28)
(29)		2%	WB	6.5	9.1	11.0	13.2	15.6	18.4	18.9	18.3	17.9	14.1	10.3	7.8	(29)
(30)		MCDWB	7.8	12.7	15.4	20.1	23.9	31.2	32.4	31.4	25.3	19.7	14.6	9.3		(30)
(31)		5%	WB	5.1	7.6	10.0	11.8	14.8	17.2	18.1	17.7	16.7	12.7	8.9	6.5	(31)
(32)		MCDWB	6.4	10.3	14.7	18.3	23.3	28.6	31.3	31.0	26.2	19.2	12.5	8.5		(32)
(33)		10%	WB	3.8	6.2	8.9	10.5	14.0	16.0	17.5	17.1	15.3	11.4	7.5	4.4	(33)
(34)		MCDWB	5.1	9.1	13.6	17.0	21.9	26.2	30.8	30.0	26.2	17.3	10.1	5.5		(34)
(35)	Mean Daily Temperature Range		MDBR	7.5	9.1	11.7	12.8	13.9	14.9	17.3	17.5	16.1	13.6	10.5	7.3	(35)
(36)		5% DB	MCDDBR	8.8	12.4	14.8	18.6	18.0	20.0	19.6	19.7	19.6	17.1	12.9	8.4	(36)
(37)			MCWBR	6.5	7.1	8.0	8.7	6.7	6.5	5.8	6.1	7.2	7.8	7.5	6.0	(37)
(38)			MCDDBR	8.7	10.3	11.9	15.6	15.0	17.4	18.1	18.2	16.6	14.1	12.0	7.7	(38)
(39)		5% WB	MCWBR	7.0	6.7	7.1	7.9	5.8	5.5	5.5	5.8	6.2	7.1	7.4	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.264	0.272	0.288	0.311	0.331	0.328	0.337	0.340	0.317	0.290	0.273	0.265	(40)	
(41)		taud	2.573	2.592	2.565	2.485	2.448	2.487	2.468	2.441	2.507	2.578	2.577	2.564	(41)	
(42)		Ebn at Noon	894	944	963	957	940	940	927	915	915	906	873	857	(42)	
(43)		Edh at Noon	64	75	87	103	110	106	107	106	92	75	63	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.57	2.59	3.91	5.47	6.67	7.56	7.74	6.68	5.19	3.40	1.98	1.30	(44)	
(45)		RadStd	0.22	0.34	0.38	0.43	0.45	0.38	0.27	0.28	0.28	0.25	0.17	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page