

NW FLORIDA BEACHES, FL, USA

WMO: 720735

Lat: 30.349N

Lon: 85.788W

Elev: 57

StdP: 14.67

Time Zone: -6.00 (NAC)

Period: 10-19

WBAN: 73805

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.9	32.8	14.9	11.7	38.3	20.2	15.2	38.9	23.5	58.4	20.8	53.6	5.0	340	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	93.9	76.6	92.3	76.7	90.9	76.7	80.6	87.5	80.0	87.1	79.2	86.5	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	151.0	83.7	78.1	146.1	83.3	77.2	141.7	82.9	44.2	87.7	43.3	86.6	42.6	86.5	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.3	17.1	15.5	DB	24.0	96.9	3.7	2.3	21.3	98.5	19.1	99.9	17.0	101.2	14.3	102.8
			WB	21.7	82.7	4.1	1.1	18.8	83.4	16.4	84.1	14.1	84.7	11.2	85.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.8	52.1	57.7	61.6	67.9	74.4	80.7	82.0	82.1	79.4	70.3	60.3	56.7
	DBStd	12.28	9.54	8.56	7.50	5.20	5.01	2.64	2.34	2.43	3.60	6.69	7.96	9.08
	HDD50	171	87	28	8	0	0	0	0	0	0	0	10	38
	HDD65	1326	412	226	154	32	5	0	0	0	0	30	183	284
	CDD50	7038	152	243	367	537	756	921	991	996	883	628	319	245
	CDD65	2717	12	20	48	119	296	471	526	531	433	193	42	26
	CDH74	25283	13	61	223	826	2804	4687	5425	5372	3833	1697	279	63
	CDH80	9723	0	1	16	104	1013	1959	2296	2191	1605	510	28	0
(14) Wind	WSAvg	6.1	6.9	7.1	7.3	7.0	6.1	5.6	4.9	4.7	4.9	5.7	6.2	6.7
(15) Precipitation	PrecAvg	55.8	4.6	4.4	5.4	3.8	2.9	5.2	6.2	6.6	5.7	3.3	3.4	4.2
	PrecMax	72.6	16.4	10.8	10.3	10.5	8.8	11.0	10.7	12.5	25.8	7.8	10.1	9.4
	PrecMin	39.5	1.5	1.0	0.1	0.8	0.2	0.7	3.0	3.1	0.4	0.5	0.2	1.3
	PrecStd	10.4	3.2	2.6	2.8	2.6	2.2	2.5	2.1	2.5	5.1	2.1	2.2	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.8	78.9	81.9	85.3	93.2	95.8	95.5	95.5	95.4	91.4	83.2	78.5
		MCWB	68.2	67.7	67.0	70.7	72.4	75.7	77.8	77.8	75.5	73.7	71.7	71.4
	2%	DB	73.3	76.0	79.1	82.8	90.2	92.9	93.0	93.0	92.5	87.8	79.8	75.9
		MCWB	67.9	66.6	66.8	69.3	72.8	76.8	77.6	77.5	75.7	71.1	70.7	69.5
	5%	DB	70.8	73.2	76.4	80.9	87.8	91.0	91.2	91.3	90.6	85.3	77.4	73.8
		MCWB	66.4	65.9	66.0	68.6	72.0	76.5	77.5	78.0	75.5	70.8	67.7	69.4
	10%	DB	68.0	70.7	74.1	78.9	85.8	89.1	89.7	89.7	88.6	82.7	74.5	71.5
		MCWB	63.5	65.7	65.2	68.2	71.8	76.2	77.6	78.0	75.3	70.2	66.3	67.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.2	71.1	72.1	75.7	77.4	80.4	81.6	82.3	80.3	78.3	76.7	74.3
		MCDB	73.3	74.8	76.3	80.9	86.6	88.5	88.5	88.9	86.0	83.4	79.6	76.0
	2%	WB	69.1	69.6	70.7	73.9	76.2	79.3	80.3	81.1	79.1	76.9	73.5	72.7
		MCDB	71.8	72.9	74.6	78.2	84.5	87.5	87.8	87.7	85.9	82.0	76.4	74.2
	5%	WB	67.2	68.4	69.2	72.7	75.2	78.4	79.6	80.2	78.1	75.1	71.0	70.4
		MCDB	69.9	71.8	73.0	77.1	83.0	86.3	87.5	86.9	85.5	80.3	74.9	72.8
	10%	WB	64.5	66.6	67.6	71.1	74.2	77.8	78.9	79.4	77.2	73.3	68.4	67.9
		MCDB	67.6	70.1	72.2	76.2	81.9	85.6	86.6	86.1	84.7	79.5	73.6	70.6
(35) Mean Daily Temperature Range	5% DB	MDBR	20.6	19.6	21.1	20.5	21.4	16.6	15.9	15.5	18.1	23.0	23.6	19.7
		MCDBR	17.6	18.9	21.0	21.6	23.3	19.3	18.1	18.1	20.5	23.8	23.7	18.4
		MCWBR	12.5	12.1	11.2	10.5	9.4	6.9	6.7	7.0	7.3	10.3	13.9	13.4
	5% WB	MCDBR	14.7	16.4	16.1	16.0	18.8	16.5	16.3	15.3	17.1	17.5	18.5	15.1
		MCWBR	12.2	12.6	11.0	10.2	8.4	7.0	6.9	6.6	7.1	10.0	13.5	12.9
(40) Clear-Sky Solar Irradiance	taub		0.333	0.347	0.366	0.394	0.437	0.467	0.501	0.495	0.436	0.383	0.354	0.342
	taud		2.536	2.498	2.445	2.372	2.284	2.256	2.178	2.189	2.331	2.460	2.479	2.522
	Ebn at Noon		286	291	292	285	272	263	253	253	266	275	275	276
	Edh at Noon		28	31	35	39	43	44	47	46	39	32	29	27
(44) All-Sky Solar Radiation	RadAvg		992	1192	1594	1918	2106	1954	1850	1722	1607	1434	1119	878
	RadStd		71	149	121	154	134	151	118	129	102	131	93	87

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	-180	+301	+187

Nomenclature: See separate page