

PICKENS COUNTY AP, SC, USA

WMO: 720744

Lat: 34.817N

Lon: 82.700W

Elev: 309

StdP: 97.67

Time Zone: -5.00 (NAE)

Period: 10-19

WBAN: 00271

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.3	-4.9	-16.1	1.0	-0.8	-13.3	1.2	0.6	9.0	9.2	8.1	8.9	0.8	70	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	34.9	23.8	33.7	23.9	32.5	24.0	28.9	29.6	26.0	30.6	25.2	30.3	2.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.7	26.2	29.4	24.9	20.8	27.4	23.9	19.5	26.8	96.4	29.4	82.3	31.4	78.7	30.2	34.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.0	5.1	DB	-11.4	36.6	2.9	2.3	-13.5	38.3	-15.2	39.7	-16.8	41.0	-18.9	42.6	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	5.1	8.1	11.1	15.9	20.4	24.3	26.1	25.2	22.8	16.2	9.9	7.5	(6)	
	DBStd	8.26	5.13	5.15	4.90	3.84	3.55	2.20	2.02	2.02	2.92	4.22	4.17	4.62	(7)	
	HDD10.0	467	166	89	47	3	0	0	0	0	0	3	52	106	(8)	
	HDD18.3	1728	411	288	227	92	24	0	0	0	4	92	254	336	(9)	
	CDD10.0	2688	13	36	83	179	324	428	498	472	383	194	48	29	(10)	
	CDD18.3	907	0	1	3	18	89	178	240	214	137	25	1	1	(11)	
	CDH23.3	8656	1	6	79	259	951	1674	2306	1852	1222	296	10	1	(12)	
	CDH26.7	3686	0	0	14	42	344	728	1143	807	529	77	1	0	(13)	
(14) Wind	WSAvg	1.8	1.8	2.2	2.3	2.4	1.7	1.5	1.5	1.3	1.5	1.7	1.4	1.7	(14)	
(15) Precipitation	PrecAvg	1435	125	128	145	111	96	129	129	142	120	95	91	134	(15)	
	PrecMax	1763	224	220	263	258	217	263	257	379	398	213	157	248	(16)	
	PrecMin	1010	48	70	46	51	34	24	68	39	17	0	41	76	(17)	
	PrecStd	248	50	40	53	51	46	61	59	78	79	60	34	44	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.6	24.1	28.8	29.4	34.0	35.5	37.3	36.2	34.8	32.0	24.5	21.9	(19)	
		MCWB	13.8	16.8	17.1	18.9	21.8	23.3	25.1	22.7	22.0	23.2	15.3	15.3	(20)	
	2%	DB	18.0	21.8	25.9	27.9	32.2	33.9	35.1	33.7	33.2	28.6	22.1	19.5	(21)	
		MCWB	13.1	14.7	15.9	18.5	21.4	23.4	24.6	24.5	22.2	19.7	14.7	16.8	(22)	
	5%	DB	16.0	19.5	23.0	26.3	30.3	32.4	33.9	32.4	31.8	26.5	20.0	17.7	(23)	
		MCWB	11.7	13.7	14.7	17.3	21.4	23.7	24.8	24.6	22.6	18.6	14.0	14.8	(24)	
	10%	DB	13.6	17.3	20.9	24.8	28.6	31.0	32.4	31.2	30.0	24.6	17.9	15.6	(25)	
		MCWB	10.3	13.1	13.7	16.2	21.0	23.3	25.0	24.3	22.1	18.0	13.7	12.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.4	19.0	19.0	21.4	24.9	27.4	31.7	31.1	25.5	24.4	19.5	19.5	(27)	
		MCDB	18.3	22.1	24.2	25.5	29.6	33.0	32.4	32.1	29.2	28.0	21.9	20.3	(28)	
	2%	WB	15.1	17.6	17.8	20.2	23.5	25.5	29.1	28.9	24.6	22.8	17.8	17.7	(29)	
		MCDB	17.2	19.4	22.3	24.7	27.8	31.0	29.8	29.6	29.0	25.7	19.5	18.1	(30)	
	5%	WB	12.8	15.7	16.7	19.4	22.5	24.6	26.3	25.8	23.9	21.4	16.6	15.5	(31)	
		MCDB	14.1	18.2	21.2	23.8	27.2	29.9	31.2	29.3	28.2	24.2	17.8	17.1	(32)	
	10%	WB	11.1	13.7	15.2	18.4	21.7	23.9	25.4	25.0	23.0	19.8	14.7	13.4	(33)	
		MCDB	12.6	16.1	19.1	22.3	26.7	29.0	30.7	29.6	27.1	22.6	16.8	14.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	12.7	13.8	14.2	13.8	12.6	12.2	11.3	12.4	14.6	13.9	11.4	(35)	
		MCDBR	15.9	15.1	17.5	16.4	16.5	14.9	14.6	13.5	15.6	16.6	16.5	13.3	(36)	
	5% WB	MCWBR	10.4	9.5	8.8	7.4	6.8	5.8	4.9	4.7	5.6	8.2	9.9	8.9	(37)	
		MCWBR	10.3	11.8	13.8	13.0	12.9	13.0	13.0	11.3	11.9	12.0	10.6	9.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.310	0.319	0.355	0.393	0.455	0.479	0.523	0.517	0.415	0.378	0.334	0.307	(40)	
		taud	2.512	2.483	2.411	2.305	2.162	2.133	2.035	2.036	2.304	2.388	2.471	2.551	(41)	
	Ebn at Noon		900	929	917	893	838	814	775	772	843	848	860	883	(42)	
		Edh at Noon	82	95	111	129	151	155	170	167	122	103	85	75	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.65	3.27	4.34	5.42	5.99	6.30	5.93	5.49	4.72	3.93	2.95	2.28	(44)	
	RadStd		0.16	0.38	0.29	0.38	0.45	0.45	0.39	0.27	0.42	0.44	0.28	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	+0.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+165	+112

Nomenclature: See separate page