

COLEMAN, TX, USA

WMO: 720771

Lat: 31.841N

Lon: 99.404W

Elev: 1697

StdP: 13.82

Time Zone: -6.00 (NAC)

Period: 10-19

WBAN: 00276

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.8	25.8	7.0	8.4	31.2	11.6	10.6	37.8	27.8	50.0	25.7	47.3	9.5	10	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.1	102.3	70.1	100.2	69.8	98.5	69.8	75.3	89.7	74.3	88.6	73.4	87.6	9.9	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	125.5	79.2	70.8	121.0	78.7	69.8	116.9	78.1	39.8	89.0	38.9	89.3	38.2	87.7	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.2	20.6	18.6	DB	14.5	105.7	4.4	1.9	11.4	107.1	8.8	108.2	6.4	109.2	3.2	110.6	(4)
(5)			WB	12.7	76.9	4.1	1.4	9.8	77.9	7.4	78.7	5.1	79.4	2.1	80.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	46.7	51.6	59.3	66.9	73.6	81.6	84.6	84.4	78.1	67.3	56.1	48.5		
	DBStd	15.70	9.35	11.49	9.65	8.21	7.61	4.70	3.91	4.73	5.81	9.09	9.55	9.48		
	HDD50	517	171	107	32	3	0	0	0	0	0	9	51	144		
	HDD65	2158	569	385	223	74	20	0	0	0	1	84	288	514		
	CDD50	6591	68	152	320	509	732	949	1072	1068	844	545	234	98		
	CDD65	2758	1	11	47	130	287	499	607	603	395	154	21	3		
	CDH74	33530	42	176	541	1546	3105	6042	8031	7800	4344	1597	243	63		
	CDH80	17816	5	37	158	642	1483	3295	4706	4586	2233	609	52	10		
(14) Wind	WSAvg	8.4	8.5	9.4	9.4	9.9	9.6	8.8	7.4	6.8	6.8	7.8	8.4	8.1		
(15) Precipitation	PrecAvg	27.7	1.3	1.5	1.6	2.2	4.1	3.3	1.8	2.6	3.7	2.8	1.5	1.3		
	PrecMax	38.7	8.1	4.7	5.2	7.1	11.2	8.2	5.8	10.0	13.5	9.8	4.8	4.4		
	PrecMin	18.0	0.0	0.1	0.0	0.1	0.6	0.6	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	5.9	1.8	1.1	1.3	1.6	2.9	2.0	1.5	2.1	3.0	2.5	1.3	1.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	84.9	88.8	98.6	101.5	104.3	104.5	106.0	100.2	93.8	85.5	81.2		
		MCWB	58.0	60.4	62.2	63.8	68.3	70.3	69.5	69.6	67.8	67.5	65.0	57.9		
	2%	DB	73.0	79.2	84.3	91.3	96.8	100.3	101.7	102.4	97.1	90.1	80.7	74.1		
		MCWB	53.6	58.8	61.6	63.0	69.5	70.2	69.9	70.4	68.5	68.6	61.4	56.4		
	5%	DB	68.0	74.8	80.4	87.2	92.3	97.3	99.5	100.3	94.4	86.6	76.2	68.8		
		MCWB	52.1	57.6	60.2	63.9	67.6	70.1	70.0	70.4	69.2	66.8	60.7	54.3		
	10%	DB	63.3	69.9	75.5	82.7	88.4	94.5	97.2	97.9	91.7	83.2	72.0	64.3		
		MCWB	49.7	55.3	59.7	63.1	67.3	70.6	70.5	70.5	68.8	65.0	58.6	53.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.8	65.8	67.6	71.1	75.3	76.7	76.9	75.4	74.3	72.2	69.0	64.5		
		MCDB	72.7	74.8	79.0	82.1	87.1	90.6	91.5	92.1	87.4	83.0	78.9	71.5		
	2%	WB	57.2	63.5	65.9	69.3	73.5	75.1	75.3	74.4	73.2	71.0	66.0	61.2		
		MCDB	67.3	72.7	77.6	81.0	85.4	88.8	90.0	90.6	86.0	83.4	73.0	67.5		
	5%	WB	54.1	61.1	64.2	67.9	72.1	73.9	74.1	73.5	72.3	69.8	63.7	58.4		
		MCDB	64.3	69.7	74.0	79.5	83.9	87.7	88.6	89.1	84.5	81.6	70.9	65.1		
	10%	WB	51.1	58.3	62.4	66.3	70.8	73.0	73.1	72.7	71.4	68.4	61.8	55.2		
		MCDB	62.6	67.2	71.5	77.0	82.4	86.7	87.7	88.1	83.0	79.2	69.3	62.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.2	24.9	25.7	26.2	23.6	23.4	24.1	23.4	22.7	24.7	24.0	22.2		
		MCDBR	32.0	31.4	30.3	32.1	29.4	27.7	26.5	27.1	26.9	28.2	28.5	29.2		
	5% WB	MCWBR	17.2	15.9	13.7	13.8	9.3	7.3	7.1	6.7	7.6	11.5	14.4	15.7		
		MCWBR	28.6	27.3	23.6	24.3	23.0	23.0	23.0	22.8	21.1	22.8	22.0	23.2		
(40) Clear-Sky Solar Irradiance	taub		0.295	0.305	0.327	0.370	0.402	0.408	0.420	0.410	0.382	0.349	0.317	0.299		
	taud		2.536	2.512	2.467	2.363	2.339	2.356	2.376	2.389	2.405	2.487	2.506	2.529		
	Ebn at Noon		298	304	303	292	282	279	274	276	281	284	286	289		
	Edh at Noon		27	30	34	39	40	40	39	38	36	30	27	25		
(44) All-Sky Solar Radiation	RadAvg		1007	1219	1575	1905	1987	2215	2184	2002	1681	1351	1059	897		
	RadStd		106	168	125	154	195	171	157	141	134	203	132	110		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page