

COLEMAN, TX, USA

WMO: 720771

Lat: 31.841N

Lon: 99.404W

Elev: 517

StdP: 95.26

Time Zone: -6.00 (NAC)

Period: 10-19

WBAN: 00276

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.2	-3.5	-13.9	1.2	-0.5	-11.3	1.5	3.2	12.4	10.0	11.5	8.5	4.2	10	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	39.1	21.2	37.9	21.0	36.9	21.0	24.0	32.1	23.5	31.4	23.0	30.9	4.4	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	17.9	26.2	21.6	17.3	25.9	21.0	16.7	25.6	74.8	31.7	72.6	31.8	70.9	30.9	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.2	8.3	-9.7	41.0	2.4	1.0	-11.5	41.7	-12.9	42.3	-14.2	42.9	-16.0	43.7		
(5)			-10.7	24.9	2.3	0.8	-12.4	25.5	-13.7	25.9	-15.0	26.4	-16.6	26.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.2	8.2	10.9	15.2	19.4	23.1	27.6	29.2	29.1	25.6	19.6	13.4	9.2
	DBStd	8.72	5.19	6.38	5.36	4.56	4.23	2.61	2.17	2.63	3.23	5.05	5.30	5.27
	HDD10.0	287	95	59	18	2	0	0	0	0	0	5	28	80
	HDD18.3	1199	316	214	124	41	11	0	0	0	1	47	160	286
	CDD10.0	3662	38	84	178	283	407	527	596	593	469	303	130	54
	CDD18.3	1532	1	6	26	72	159	277	337	335	219	86	12	2
	CDH23.3	18628	23	98	301	859	1725	3357	4462	4333	2413	887	135	35
	CDH26.7	9898	3	21	88	357	824	1831	2614	2548	1241	338	29	6
Wind	WSAvg	3.8	3.8	4.2	4.2	4.4	4.3	4.0	3.3	3.0	3.0	3.5	3.8	3.6
Precipitation	PrecAvg	704	33	37	40	56	103	85	46	65	93	71	37	32
	PrecMax	984	206	120	133	180	285	209	148	255	344	248	123	112
	PrecMin	458	0	2	0	2	16	15	0	0	1	0	0	0
	PrecStd	149	46	29	32	41	73	51	37	53	75	64	32	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	29.4	31.6	37.0	38.6	40.1	40.3	41.1	37.9	34.3	29.7	27.3
		MCWB	14.4	15.8	16.8	17.6	20.2	21.3	20.9	20.9	19.9	19.7	18.3	14.4
	2%	DB	22.8	26.2	29.1	32.9	36.0	38.0	38.7	39.1	36.2	32.3	27.1	23.4
		MCWB	12.0	14.9	16.5	17.2	20.8	21.2	21.1	21.3	20.3	20.4	16.3	13.5
	5%	DB	20.0	23.8	26.9	30.7	33.5	36.3	37.5	37.9	34.7	30.3	24.6	20.5
		MCWB	11.2	14.2	15.7	17.7	19.8	21.2	21.1	21.3	20.7	19.3	16.0	12.4
	10%	DB	17.4	21.1	24.2	28.2	31.3	34.7	36.2	36.6	33.2	28.4	22.2	17.9
		MCWB	9.9	13.0	15.4	17.3	19.6	21.4	21.4	21.4	20.4	18.3	14.8	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	18.8	19.8	21.7	24.1	24.8	25.0	24.1	23.5	22.3	20.6	18.0
		MCDB	22.6	23.8	26.1	27.9	30.6	32.5	33.1	33.4	30.8	28.3	26.0	21.9
	2%	WB	14.0	17.5	18.8	20.7	23.1	23.9	24.0	23.6	22.9	21.7	18.9	16.2
		MCDB	19.6	22.6	25.3	27.2	29.7	31.5	32.2	32.5	30.0	28.5	22.8	19.7
	5%	WB	12.3	16.2	17.9	20.0	22.3	23.3	23.4	23.0	22.4	21.0	17.6	14.7
		MCDB	17.9	21.0	23.4	26.4	28.8	31.0	31.5	31.7	29.2	27.6	21.6	18.4
	10%	WB	10.6	14.6	16.9	19.1	21.6	22.8	22.8	22.6	21.9	20.2	16.6	12.9
		MCDB	17.0	19.5	21.9	25.0	28.0	30.4	30.9	31.2	28.4	26.2	20.7	17.1
Mean Daily Temperature Range	5% DB	MDBR	13.4	13.8	14.3	14.6	13.1	13.0	13.4	13.0	12.6	13.7	13.3	12.3
		MCDBR	17.8	17.4	16.8	17.8	16.3	15.4	14.7	15.0	14.9	15.7	15.8	16.2
		MCWBR	9.6	8.8	7.6	7.7	5.1	4.1	3.9	3.7	4.2	6.4	8.0	8.7
	5% WB	MCDBR	15.9	15.1	13.1	13.5	12.8	12.8	12.8	12.7	11.7	12.6	12.2	12.9
		MCWBR	9.9	9.4	6.7	6.8	4.9	4.2	3.8	3.6	3.5	5.4	7.9	8.7
Clear-Sky Solar Irradiance	taub	0.295	0.305	0.327	0.370	0.402	0.408	0.420	0.410	0.382	0.349	0.317	0.299	
	taud	2.536	2.512	2.467	2.363	2.339	2.356	2.376	2.389	2.405	2.487	2.506	2.529	
	Ebn at Noon	938	958	955	920	888	878	865	871	886	896	902	912	
	Edh at Noon	84	94	106	123	127	125	122	119	112	96	86	80	
All-Sky Solar Radiation	RadAvg	3.18	3.84	4.96	6.01	6.26	6.98	6.88	6.31	5.30	4.26	3.34	2.83	
	RadStd	0.34	0.53	0.39	0.48	0.61	0.54	0.49	0.44	0.42	0.64	0.42	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page