

COURTLAND 2 WSW, AL, USA

WMO: 720774

Lat: 34.6602N

Lon: 87.3462W

Elev: 575

StdP: 14.39

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 63868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.6	21.9	N/A	N/A	N/A	N/A	N/A	N/A	22.3	52.2	20.1	51.6	4.4	350	0.393

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	94.1	N/A	91.9	N/A	90.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	7.2	260

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.7	16.3	14.2	11.6	97.0	4.7	3.4	8.2	99.5	5.4	101.5	2.8	103.4	-0.7	105.9		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	40.2	44.9	52.7	60.9	69.4	77.1	79.2	78.7	73.0	61.7	50.2	45.1
	DBStd	15.79	10.94	10.65	9.66	7.71	6.53	3.93	3.74	4.05	5.89	8.33	8.65	9.78
	HDD50	973	342	208	87	11	0	0	0	0	0	8	100	217
	HDD65	3173	769	567	391	167	38	0	0	0	10	163	450	618
	CDD50	5055	38	64	171	337	602	812	904	891	691	372	106	67
	CDD65	1779	0	3	10	43	175	362	439	426	251	63	5	2
	CDH74	16598	0	8	97	409	1538	3508	4221	3998	2188	604	26	1
	CDH80	6616	0	0	10	54	477	1493	1815	1766	842	155	4	0
Wind	WSAvg	5.6	6.6	7.0	7.0	6.8	5.6	4.9	4.6	4.1	4.1	4.9	5.3	6.2
Precipitation	PrecAvg	56.9	5.8	5.5	5.5	4.9	4.5	4.3	4.9	4.0	3.7	3.1	4.4	6.1
	PrecMax	76.2	11.2	10.8	10.2	11.3	12.4	12.2	8.0	7.2	9.5	9.3	8.2	16.7
	PrecMin	34.6	2.8	3.0	1.3	1.5	0.5	1.2	2.1	0.6	0.4	0.0	1.8	2.1
	PrecStd	9.4	2.1	2.2	1.9	2.3	2.8	2.4	1.7	1.6	2.2	2.1	1.4	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.6	75.1	81.5	84.3	90.1	95.1	96.3	98.5	94.0	88.5	77.3	72.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	65.9	70.4	76.7	81.6	87.4	92.1	93.2	94.5	91.2	84.3	72.5	68.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	62.3	67.0	72.7	79.1	85.2	90.3	91.1	91.4	88.4	80.6	69.2	65.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	58.3	62.7	69.1	75.8	82.7	88.1	89.0	89.0	85.2	77.0	66.0	61.6
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range	5% DB	MDBR	18.5	19.6	21.2	22.1	20.2	20.0	18.0	18.8	20.7	22.6	22.5	18.1
		MCDBR	20.9	23.2	25.5	25.4	23.4	22.8	20.8	22.4	23.9	26.4	25.5	20.2
	5% WB	MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDWR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub		0.319	0.326	0.365	0.400	0.442	0.470	0.512	0.524	0.429	0.375	0.339	0.318
	taud		2.488	2.468	2.383	2.280	2.206	2.158	2.066	2.021	2.275	2.409	2.453	2.510
	Ebn at Noon		282	292	288	281	269	261	249	243	263	271	271	275
	Edh at Noon		27	30	36	42	46	48	52	54	40	32	28	25
All-Sky Solar Radiation	RadAvg		779	944	1310	1691	1864	1984	1895	1754	1524	1220	890	665
	RadStd		62	118	119	115	144	156	104	98	133	160	93	65

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (29 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+239	+171

Nomenclature: See separate page