

HARRISON COUNTY AP, TX, USA

WMO: 720943

Lat: 32.521N

Lon: 94.308W

Elev: 357

StdP: 14.51

Time Zone: -6.00 (NAC)

Period: 11-19

WBAN: 00431

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	28.1	9.4	9.0	39.4	15.0	11.9	38.6	20.2	51.4	18.4	52.7	2.7	350	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.4	99.6	73.3	97.1	73.0	95.0	74.6	80.1	90.6	78.9	89.7	77.9	88.5	5.8	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.1	143.0	86.5	76.0	137.5	84.7	75.0	132.8	83.3	43.7	90.5	42.6	89.9	41.5	88.9	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.8	14.6	12.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	16.8	80.8	5.1	2.0	13.1	82.3	10.2	83.5	7.3	84.6	3.6	86.1	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	46.5	51.1	57.5	64.2	72.2	79.7	82.7	83.3	78.1	66.3	54.6	49.3	(6)
	DBStd	15.10	9.41	9.87	9.11	7.54	6.18	3.92	3.82	4.76	5.36	8.74	9.62	9.25	(7)
	HDD50	515	182	99	36	5	0	0	0	0	0	3	59	131	(8)
	HDD65	2277	575	400	261	101	17	0	0	0	1	95	334	493	(9)
	CDD50	6189	74	129	268	432	687	892	1015	1034	844	507	198	109	(10)
	CDD65	2476	2	10	28	77	239	442	550	569	395	134	23	7	(11)
	CDH74	25716	10	44	192	569	1964	4508	6286	6863	3998	1173	93	16	(12)
	CDH80	12818	0	3	28	100	688	2204	3409	3899	2040	432	15	0	(13)
(14) Wind	WSAvg	4.1	4.8	5.0	5.3	5.3	4.5	3.8	3.4	3.3	2.6	3.5	4.1	4.0	(14)
(15) Precipitation	PrecAvg	49.0	4.0	4.1	4.3	4.4	4.6	4.9	2.9	2.6	3.9	4.2	4.3	4.9	(15)
	PrecMax	74.9	14.3	9.1	10.2	17.1	11.4	12.6	7.8	6.9	10.6	12.0	11.0	16.7	(16)
	PrecMin	32.0	0.4	0.3	0.6	0.7	0.9	0.2	0.1	0.0	1.0	0.0	0.5	0.6	(17)
	PrecStd	10.2	2.7	2.2	2.3	3.4	2.8	3.3	1.9	1.8	2.4	2.6	2.2	3.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	78.3	84.5	86.3	90.4	99.1	100.5	107.9	99.1	93.3	82.3	75.8	(19)
		MCWB	60.2	62.0	65.6	70.8	72.8	72.4	74.9	74.9	69.0	70.6	70.8	66.3	(20)
	2%	DB	71.1	75.0	78.7	82.4	89.2	95.5	99.1	101.6	95.7	89.0	76.2	72.8	(21)
		MCWB	61.0	62.4	64.3	69.1	73.3	73.7	74.4	73.9	72.6	70.8	66.0	64.5	(22)
	5%	DB	67.8	70.9	75.4	79.3	86.3	93.2	96.3	98.3	93.5	85.5	72.8	70.1	(23)
		MCWB	59.4	62.0	62.3	65.7	71.9	75.2	74.7	73.2	73.5	71.3	65.4	63.9	(24)
	10%	DB	64.1	68.0	72.5	77.0	85.0	90.3	93.8	95.2	90.5	80.6	70.2	65.9	(25)
		MCWB	56.4	61.0	61.1	65.2	71.4	74.9	76.3	74.9	73.2	66.6	64.2	60.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.2	68.1	68.5	73.5	77.9	80.5	81.0	81.7	80.1	77.2	71.6	69.1	(27)
		MCDB	71.1	73.8	76.0	80.7	87.3	89.4	91.2	91.4	90.8	87.4	79.5	73.5	(28)
	2%	WB	63.5	66.3	67.5	71.4	75.9	79.2	79.7	80.0	78.3	75.1	69.2	67.3	(29)
		MCDB	67.9	71.6	73.3	78.6	84.5	89.2	90.8	90.7	89.0	83.6	73.7	71.4	(30)
	5%	WB	61.6	64.4	66.2	70.0	74.5	77.7	78.5	78.5	77.0	73.0	67.6	65.1	(31)
		MCDB	66.2	69.2	72.6	76.7	82.9	87.3	89.8	89.2	86.9	80.2	71.8	69.5	(32)
	10%	WB	57.2	62.1	64.5	68.4	73.0	76.5	77.6	77.4	75.5	70.8	65.0	62.0	(33)
		MCDB	63.1	66.9	70.6	74.7	81.1	86.0	88.9	88.0	85.3	76.9	69.6	65.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.0	19.0	21.9	21.7	20.1	19.3	20.0	21.4	22.2	22.7	21.2	18.7	(35)
		MCDBR	26.3	22.6	24.1	23.6	21.9	23.0	23.3	26.2	25.1	25.9	21.8	22.3	(36)
		MCWBR	16.7	14.3	12.4	11.9	9.6	7.6	6.3	6.6	8.6	11.4	14.4	15.9	(37)
	5% WB	MCDBR	20.4	18.2	19.8	19.2	18.2	18.9	19.8	20.8	20.0	20.4	17.7	19.6	(38)
		MCWBR	16.8	13.9	13.7	11.6	9.4	8.2	7.7	7.7	8.7	10.7	13.8	15.8	(39)
(40) Clear-Sky Solar Irradiance	taub		0.326	0.339	0.360	0.395	0.428	0.455	0.470	0.466	0.416	0.361	0.348	0.330	(40)
	taud		2.507	2.475	2.426	2.328	2.291	2.259	2.250	2.253	2.355	2.485	2.475	2.504	(41)
	Ebn at Noon		284	291	292	284	274	265	261	260	270	279	273	275	(42)
	Edh at Noon		27	31	35	40	42	43	44	43	37	30	28	26	(43)
(44) All-Sky Solar Radiation	RadAvg		862	966	1361	1696	1855	1986	2002	1878	1602	1287	934	748	(44)
	RadStd		79	159	125	106	140	161	150	158	143	174	108	97	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page