

HARRISON COUNTY AP, TX, USA

WMO: 720943

Lat: 32.521N

Lon: 94.308W

Elev: 109

StdP: 100.02

Time Zone: -6.00 (NAC)

Period: 11-19

WBAN: 00431

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.7	(c) -2.2	(d) -12.5	(e) 1.3	(f) 4.1	(g) -9.5	(h) 1.7	(i) 3.7	(j) 9.0	(k) 10.8	(l) 8.2	(m) 11.5	(n) 1.2	(o) 350	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	37.5	23.0	36.2	22.8	35.0	23.7	26.7	32.6	26.0	32.1	25.5	31.4	2.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.1	20.4	30.3	24.4	19.6	29.3	23.9	19.0	28.5	83.8	32.5	81.1	32.2	78.6	31.6	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.5	6.5	5.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-8.5	27.1	2.8	1.1	-10.5	27.9	-12.1	28.6	-13.7	29.2	-15.8	30.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	8.1	10.6	14.2	17.9	22.3	26.5	28.2	28.5	25.6	19.0	12.6	9.6
	DBStd	8.39	5.23	5.49	5.06	4.19	3.43	2.18	2.12	2.64	2.98	4.86	5.34	5.14
	HDD10.0	286	101	55	20	3	0	0	0	0	0	2	33	73
	HDD18.3	1265	319	222	145	56	9	0	0	0	1	53	186	274
	CDD10.0	3438	41	72	149	240	382	496	564	574	469	282	110	61
	CDD18.3	1376	1	6	16	43	133	246	306	316	219	74	13	4
	CDH23.3	14287	6	24	107	316	1091	2504	3492	3813	2221	652	52	9
	CDH26.7	7121	0	2	16	56	382	1224	1894	2166	1133	240	8	0
Wind	WSAvg	1.9	2.1	2.2	2.4	2.4	2.0	1.7	1.5	1.5	1.2	1.6	1.8	1.8
Precipitation	PrecAvg	1245	102	104	108	113	118	124	74	67	100	107	109	124
	PrecMax	1902	364	230	260	435	290	319	199	176	269	306	279	424
	PrecMin	814	10	8	14	19	22	5	2	0	26	0	13	14
	PrecStd	260	69	55	59	86	71	84	47	46	62	65	56	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	25.7	29.2	30.2	32.4	37.3	38.1	42.2	37.3	34.1	27.9	24.3
		MCWB	15.7	16.6	18.7	21.6	22.7	22.5	23.9	23.8	20.6	21.4	21.6	19.1
	2%	DB	21.7	23.9	25.9	28.0	31.8	35.3	37.3	38.7	35.4	31.7	24.6	22.7
		MCWB	16.1	16.9	17.9	20.6	23.0	23.1	23.6	23.3	22.6	21.6	18.9	18.0
	5%	DB	19.9	21.6	24.1	26.3	30.2	34.0	35.7	36.8	34.2	29.7	22.7	21.1
		MCWB	15.2	16.7	16.8	18.7	22.2	24.0	23.7	22.9	23.0	21.9	18.5	17.7
	10%	DB	17.8	20.0	22.5	25.0	29.5	32.4	34.3	35.1	32.5	27.0	21.2	18.8
		MCWB	13.6	16.1	16.2	18.4	21.9	23.9	24.6	23.8	22.9	19.2	17.9	15.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.0	20.1	20.3	23.0	25.5	26.9	27.2	27.6	26.7	25.1	22.0	20.6
		MCDB	21.7	23.2	24.4	27.0	30.7	31.9	32.9	33.0	32.7	30.8	26.4	23.0
	2%	WB	17.5	19.1	19.7	21.9	24.4	26.2	26.5	26.7	25.7	23.9	20.7	19.6
		MCDB	20.0	22.0	23.0	25.9	29.1	31.8	32.7	32.6	31.7	28.6	23.2	21.9
	5%	WB	16.5	18.0	19.0	21.1	23.6	25.4	25.8	25.8	25.0	22.8	19.8	18.4
		MCDB	19.0	20.7	22.6	24.8	28.3	30.7	32.1	31.8	30.5	26.8	22.1	20.8
	10%	WB	14.0	16.7	18.0	20.2	22.8	24.7	25.3	25.2	24.2	21.6	18.3	16.7
		MCDB	17.3	19.4	21.4	23.7	27.3	30.0	31.6	31.1	29.6	24.9	20.9	18.6
Mean Daily Temperature Range	5% DB	MDBR	11.7	10.6	12.2	12.1	11.2	10.7	11.1	11.9	12.3	12.6	11.8	10.4
		MCDBR	14.6	12.6	13.4	13.1	12.2	12.8	12.9	14.6	13.9	14.4	12.1	12.4
		MCWBR	9.3	8.0	6.9	6.6	5.3	4.2	3.5	3.7	4.8	6.3	8.0	8.8
	5% WB	MCDBR	11.3	10.1	11.0	10.6	10.1	10.5	11.0	11.5	11.1	11.3	9.8	10.9
		MCWBR	9.3	7.7	7.6	6.4	5.2	4.6	4.3	4.3	4.8	5.9	7.7	8.8
Clear-Sky Solar Irradiance	taub	0.326	0.339	0.360	0.395	0.428	0.455	0.470	0.466	0.416	0.361	0.348	0.330	
	taud	2.507	2.475	2.426	2.328	2.291	2.259	2.250	2.253	2.355	2.485	2.475	2.504	
	Ebn at Noon	895	917	919	895	864	836	822	821	850	880	860	868	
	Edh at Noon	86	98	111	127	133	137	138	136	118	96	89	82	
All-Sky Solar Radiation	RadAvg	2.72	3.05	4.29	5.35	5.85	6.26	6.31	5.92	5.05	4.06	2.94	2.36	
	RadStd	0.25	0.50	0.39	0.33	0.44	0.51	0.47	0.50	0.45	0.55	0.34	0.30	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page