

HEART OF GEORGIA, GA, USA

WMO: 720962

Lat: 32.214N

Lon: 83.128W

Elev: 306

StdP: 14.53

Time Zone: -5.00 (NAE)

Period: 11-19

WBAN: 00337

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.4	30.0	10.7	9.6	44.1	16.7	13.0	44.8	18.1	60.5	16.0	53.5	1.2	310	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	96.4	73.1	94.9	73.7	93.2	74.0	80.7	88.3	79.9	87.6	78.9	86.2	5.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	152.9	82.9	78.1	147.8	81.9	77.3	143.6	81.2	44.5	88.7	43.6	87.5	42.6	86.0	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.8	12.2	10.7	20.9	99.6	3.2	2.6	18.6	101.4	16.7	102.9	14.9	104.4	12.6	106.3		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	50.0	55.1	59.5	66.9	74.3	80.3	83.0	81.9	78.0	68.3	56.6	54.2
	DBStd	13.40	9.73	9.11	8.88	6.36	5.56	3.45	2.62	2.96	4.30	7.06	8.42	8.45
	HDD50	268	122	46	22	0	0	0	0	0	0	0	27	51
	HDD65	1720	473	294	214	56	7	0	0	0	0	50	278	348
	CDD50	6625	122	189	317	506	752	908	1024	990	841	567	226	183
	CDD65	2602	8	18	45	112	294	458	559	525	391	152	26	14
	CDH74	26287	50	133	445	1241	3137	4720	5946	5233	3600	1490	218	74
	CDH80	11859	2	16	84	373	1404	2283	2977	2490	1693	499	34	4
Wind	WSAvg	3.6	4.1	4.1	4.6	4.4	3.6	3.4	3.1	3.0	3.1	3.5	3.4	3.6
Precipitation	PrecAvg	47.4	4.7	4.3	4.9	3.5	3.1	4.6	5.3	4.3	3.5	2.5	2.9	3.5
	PrecMax	63.2	10.3	9.4	10.9	7.7	7.9	11.3	9.6	9.9	17.4	9.5	9.3	8.5
	PrecMin	35.7	0.6	0.8	0.0	0.3	0.2	0.6	1.3	1.0	0.1	0.0	0.2	0.8
	PrecStd	6.4	2.3	2.2	2.6	2.3	1.9	2.5	2.1	2.1	3.1	2.4	2.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	82.5	85.8	90.2	95.8	98.4	98.3	97.3	95.5	91.4	83.9	80.2
		MCWB	66.7	68.0	66.0	69.3	72.7	74.2	73.5	73.1	74.0	73.8	69.5	69.7
	2%	DB	74.8	78.2	82.4	86.9	92.9	95.5	96.4	95.4	93.5	88.2	79.9	76.1
		MCWB	65.7	65.8	66.0	68.5	72.0	72.7	72.6	74.4	73.6	72.6	67.1	67.2
	5%	DB	70.2	74.3	79.4	84.3	90.5	93.1	94.8	93.5	91.5	85.8	76.1	72.9
		MCWB	62.6	63.4	65.5	67.2	71.5	72.9	73.8	74.9	73.7	70.7	66.3	67.5
	10%	DB	66.5	70.8	75.4	81.7	87.9	90.9	92.9	91.4	89.5	82.7	72.6	69.2
		MCWB	60.1	61.6	62.7	65.8	70.6	73.8	75.0	75.4	72.5	69.8	65.8	64.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.8	69.9	70.7	74.8	76.6	81.2	81.7	82.2	81.0	77.3	75.4	74.4
		MCDB	71.8	74.6	76.9	80.4	84.1	87.3	88.3	89.0	89.4	80.9	76.6	75.8
	2%	WB	66.8	67.9	69.2	72.3	75.4	79.5	80.4	80.8	79.3	75.3	72.8	71.6
		MCDB	72.4	72.7	74.8	78.7	85.3	88.1	88.0	88.6	86.3	81.6	74.6	74.4
	5%	WB	64.7	65.5	67.7	70.9	74.3	78.3	79.5	79.9	78.1	74.0	70.0	69.0
		MCDB	68.9	71.2	74.8	77.6	84.4	86.3	87.4	87.6	84.9	81.1	72.4	70.9
	10%	WB	61.2	62.4	66.0	69.1	73.1	77.2	78.5	78.7	77.0	72.5	66.5	65.8
		MCDB	65.1	66.5	73.0	76.2	83.2	84.8	85.7	85.6	83.3	79.1	69.9	67.9
Mean Daily Temperature Range	5% DB	MDBR	22.7	23.3	24.3	24.9	24.4	21.0	20.4	19.7	21.6	25.2	25.4	21.5
		MCDBR	24.2	26.1	26.6	28.5	27.3	23.8	22.6	21.8	24.7	26.8	28.0	24.1
		MCWBR	15.2	15.8	12.6	11.1	8.8	8.0	7.7	8.4	8.9	11.8	15.8	16.2
	5% WB	MCDBR	20.4	22.3	21.7	20.9	23.5	20.3	18.8	19.4	19.4	21.6	17.3	17.5
		MCWBR	15.2	15.4	11.8	10.7	8.7	7.9	7.4	7.8	7.9	10.6	13.8	13.7
Clear-Sky Solar Irradiance	taub	0.324	0.328	0.356	0.385	0.429	0.476	0.514	0.510	0.421	0.376	0.347	0.326	
	taud	2.512	2.493	2.442	2.353	2.265	2.200	2.094	2.102	2.341	2.439	2.469	2.524	
	Ebn at Noon	285	295	293	287	274	260	249	248	269	274	274	278	
	Edh at Noon	27	30	35	39	43	46	51	50	38	32	28	26	
All-Sky Solar Radiation	RadAvg	931	1121	1469	1828	2008	1973	1939	1757	1542	1326	1029	804	
	RadStd	50	119	121	129	141	140	106	95	136	139	79	78	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (37 neighbors)	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+324	+218	

Nomenclature: See separate page