

HEART OF GEORGIA, GA, USA

WMO: 720962

Lat: 32.214N

Lon: 83.128W

Elev: 93

StdP: 100.21

Time Zone: -5.00 (NAE)

Period: 11-19

WBAN: 00337

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.6	(c) -1.1	(d) -11.9	(e) 1.4	(f) 6.7	(g) -8.5	(h) 1.9	(i) 7.1	(j) 8.1	(k) 15.8	(l) 7.2	(m) 12.0	(n) 0.5	(o) 310	(p) 0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	35.8	22.8	34.9	23.1	34.0	23.3	27.1	31.3	26.6	30.9	26.0	30.1	2.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.2	(b) 21.8	(c) 28.3	(d) 25.6	(e) 21.1	(f) 27.7	(g) 25.2	(h) 20.5	(i) 27.3	(j) 85.7	(k) 31.5	(l) 83.4	(m) 30.9	(n) 81.1	(o) 30.0	(p) 28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.6	(b) 5.5	(c) 4.8	(e) -6.2	(f) 37.5	(g) 1.8	(h) 1.4	(i) -7.4	(j) 38.6	(k) -8.5	(l) 39.4	(m) -9.5	(n) 40.2	(o) -10.8	(p) 41.3		
(4) 6.6	(5) 5.5	(6) 4.8	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	10.0	12.9	15.3	19.4	23.5	26.8	28.4	27.7	25.6	20.2	13.7	12.4
	DBStd	7.44	5.41	5.06	4.93	3.53	3.09	1.92	1.46	1.65	2.39	3.92	4.68	4.70
	HDD10.0	149	68	26	12	0	0	0	0	0	0	0	15	28
	HDD18.3	956	263	163	119	31	4	0	0	0	0	28	154	193
	CDD10.0	3681	68	105	176	281	418	504	569	550	467	315	126	102
	CDD18.3	1446	4	10	25	62	163	254	311	292	217	84	14	8
	CDH23.3	14604	28	74	247	689	1743	2622	3303	2907	2000	828	121	41
	CDH26.7	6588	1	9	47	207	780	1268	1654	1383	941	277	19	2
Wind	WSAvg	1.6	1.8	1.9	2.1	2.0	1.6	1.5	1.4	1.3	1.4	1.5	1.5	1.6
Precipitation	PrecAvg	1203	120	110	124	89	79	118	135	110	89	63	73	90
	PrecMax	1605	262	238	277	195	200	288	243	251	441	242	235	215
	PrecMin	908	14	21	1	8	6	15	34	25	3	0	6	20
	PrecStd	162	59	56	67	58	49	64	54	53	78	61	54	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	28.0	29.9	32.3	35.4	36.9	36.8	36.3	35.3	33.0	28.9	26.8
		MCWB	19.3	20.0	18.9	20.7	22.6	23.4	23.1	22.8	23.3	23.2	20.8	20.9
	2%	DB	23.8	25.7	28.0	30.5	33.8	35.3	35.8	35.2	34.2	31.2	26.6	24.5
		MCWB	18.7	18.8	18.9	20.3	22.2	22.6	22.6	23.6	23.1	22.6	19.5	19.6
	5%	DB	21.2	23.5	26.3	29.0	32.5	33.9	34.9	34.2	33.0	29.9	24.5	22.7
		MCWB	17.0	17.4	18.6	19.5	21.9	22.7	23.2	23.8	23.2	21.5	19.1	19.7
	10%	DB	19.1	21.6	24.1	27.6	31.1	32.7	33.8	33.0	31.9	28.2	22.6	20.7
		MCWB	15.6	16.5	17.0	18.8	21.5	23.2	23.9	24.1	22.5	21.0	18.8	18.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	21.1	21.5	23.8	24.8	27.3	27.6	27.9	27.2	25.2	24.1	23.6
		MCDB	22.1	23.7	24.9	26.9	28.9	30.7	31.3	31.7	31.9	27.2	24.8	24.3
	2%	WB	19.3	20.0	20.7	22.4	24.1	26.4	26.9	27.1	26.3	24.0	22.6	22.0
		MCDB	22.4	22.6	23.8	26.0	29.6	31.2	31.1	31.4	30.2	27.5	23.7	23.6
	5%	WB	18.1	18.6	19.8	21.6	23.5	25.7	26.4	26.6	25.6	23.3	21.1	20.5
		MCDB	20.5	21.8	23.8	25.3	29.1	30.2	30.8	30.9	29.4	27.3	22.4	21.6
	10%	WB	16.2	16.9	18.9	20.6	22.8	25.1	25.8	26.0	25.0	22.5	19.2	18.8
		MCDB	18.4	19.2	22.8	24.6	28.4	29.3	29.9	29.8	28.5	26.1	21.1	19.9
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.9	13.5	13.8	13.6	11.7	11.4	10.9	12.0	14.0	14.1	11.9
		MCDBR	13.5	14.5	14.8	15.8	15.2	13.2	12.6	12.1	13.7	14.9	15.6	13.4
		MCWBR	8.4	8.8	7.0	6.2	4.9	4.4	4.3	4.7	5.0	6.5	8.8	9.0
	5% WB	MCDBR	11.3	12.4	12.1	11.6	13.1	11.3	10.5	10.8	10.8	12.0	9.6	9.7
		MCWBR	8.5	8.5	6.5	5.9	4.8	4.4	4.1	4.3	4.4	5.9	7.6	7.6
Clear-Sky Solar Irradiance	taub	0.324	0.328	0.356	0.385	0.429	0.476	0.514	0.510	0.421	0.376	0.347	0.326	
	taud	2.512	2.493	2.442	2.353	2.265	2.200	2.094	2.102	2.341	2.439	2.469	2.524	
	Ebn at Noon	900	930	924	905	863	819	785	783	847	865	863	876	
	Edh at Noon	86	96	109	124	137	146	161	158	120	101	89	81	
All-Sky Solar Radiation	RadAvg	2.94	3.53	4.63	5.76	6.33	6.22	6.11	5.54	4.86	4.18	3.24	2.54	
	RadStd	0.16	0.38	0.38	0.41	0.44	0.44	0.33	0.30	0.43	0.44	0.25	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+180	+121

Nomenclature: See separate page