

KEY WEST INTL, FL, USA

WMO: 722010

Lat: 24.5537N

Lon: 81.7879W

Elev: 5

StdP: 101.27

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12836

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 12.8	(c) 14.4	(d) 5.5	(e) 5.6	(f) 14.9	(g) 7.5	(h) 6.4	(i) 16.0	(j) 11.4	(k) 18.7	(l) 10.7	(m) 18.2	(n) 4.5	(o) 20	(p) 0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.6	(c) 32.6	(d) 26.3	(e) 32.2	(f) 26.3	(g) 31.7	(h) 26.2	(i) 27.4	(j) 30.8	(k) 27.0	(l) 30.6	(m) 26.8	(n) 30.4	(o) 4.1	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.8	29.4	26.0	21.4	29.4	25.7	21.0	29.3	86.1	31.0	84.9	30.7	83.6	30.4	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.7	8.7	8.0	10.1	33.9	2.1	1.6	8.6	35.0	7.4	35.9	6.2	36.8	4.7	38.0		
			6.9	27.8	2.2	0.5	5.3	28.2	4.1	28.5	2.8	28.8	1.2	29.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.7	20.9	22.0	23.2	25.1	27.0	28.6	29.4	29.4	28.7	27.1	24.4	22.5
	DBStd	3.65	3.32	3.08	2.63	1.82	1.41	1.15	1.11	1.15	1.15	1.77	2.28	3.02
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	35	17	8	3	0	0	0	0	0	0	0	1	6
	CDD10.0	5738	338	336	408	454	528	558	601	602	562	531	432	388
	CDD18.3	2731	96	111	153	204	269	308	343	344	312	273	183	136
	CDH23.3	27057	312	447	790	1494	2729	3792	4476	4554	3877	2822	1143	621
	CDH26.7	9117	7	18	59	199	681	1470	2036	2114	1557	801	143	33
Wind	WSAvg	4.3	4.7	4.5	4.7	4.8	4.4	4.0	3.7	3.7	3.8	4.5	4.7	4.5
Precipitation	PrecAvg	1015	50	41	44	48	86	125	89	138	158	122	62	51
	PrecMax	1598	448	124	246	269	328	366	297	343	469	548	703	284
	PrecMin	508	0	3	0	0	14	8	11	57	43	19	0	1
	PrecStd	236	76	30	44	47	72	88	55	68	77	99	106	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.5	28.1	28.8	30.0	31.3	32.4	33.2	33.3	32.6	31.6	30.0	28.4
		MCWB	23.7	23.8	24.5	24.7	25.6	26.2	26.3	26.3	26.2	26.3	25.1	24.5
	2%	DB	26.6	27.3	28.0	29.1	30.6	31.7	32.5	32.7	31.9	30.8	29.0	27.6
		MCWB	23.0	23.4	23.9	24.3	25.1	26.1	26.3	26.3	26.3	25.8	24.6	24.1
	5%	DB	25.9	26.6	27.4	28.5	30.0	31.2	32.0	32.2	31.5	30.3	28.2	26.9
		MCWB	22.5	23.0	23.3	24.0	24.8	26.0	26.2	26.3	26.1	25.5	24.1	23.6
	10%	DB	25.1	25.9	26.6	27.9	29.5	30.8	31.5	31.7	31.0	29.7	27.4	26.2
		MCWB	22.1	22.5	22.8	23.5	24.6	25.8	26.1	26.2	26.0	25.2	23.6	23.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.6	24.6	25.7	26.1	26.8	27.5	27.5	27.8	27.8	27.3	26.1	25.6
		MCDB	26.2	27.0	27.5	28.5	29.4	30.5	31.5	31.4	30.5	30.1	28.4	27.2
	2%	WB	23.9	24.0	24.7	25.4	26.1	26.9	27.1	27.2	27.3	26.7	25.4	25.0
		MCDB	25.8	26.4	26.9	28.0	29.1	30.2	31.1	31.2	30.4	29.7	28.0	26.7
	5%	WB	23.2	23.5	24.1	24.8	25.7	26.7	26.8	26.9	26.9	26.2	24.9	24.4
		MCDB	25.2	25.8	26.5	27.5	28.8	30.1	30.8	30.9	30.2	29.3	27.5	26.2
	10%	WB	22.6	23.0	23.6	24.3	25.2	26.4	26.6	26.7	26.6	25.8	24.3	23.8
		MCDB	24.7	25.2	26.0	27.1	28.5	29.9	30.6	30.7	30.0	28.9	26.9	25.7
Mean Daily Temperature Range	5% DB	MDBR	5.1	5.1	5.1	4.6	4.4	4.4	4.4	4.6	4.5	4.2	4.3	4.5
		MCDBR	4.8	4.7	4.9	4.6	4.7	4.6	4.5	4.8	4.7	4.3	4.3	4.2
		MCWBR	3.1	2.7	2.8	2.7	2.4	2.4	2.3	2.3	2.3	2.2	2.4	2.5
	5% WB	MCDBR	4.7	4.6	4.8	4.4	4.3	4.3	4.4	4.6	4.4	4.1	4.2	3.9
		MCWBR	3.5	2.9	3.1	3.0	2.5	2.5	2.4	2.4	2.4	2.3	2.6	2.8
Clear-Sky Solar Irradiance	taub	0.363	0.377	0.383	0.400	0.424	0.439	0.450	0.433	0.417	0.409	0.377	0.371	
	taud	2.549	2.514	2.476	2.407	2.395	2.421	2.394	2.463	2.478	2.485	2.522	2.549	
	Ebn at Noon	897	908	916	901	873	853	843	860	871	863	874	874	
	Edh at Noon	92	101	110	120	122	118	121	112	109	103	94	89	
All-Sky Solar Radiation	RadAvg	3.89	4.87	5.99	6.76	6.84	6.35	6.48	6.15	5.40	4.85	4.21	3.70	
	RadStd	0.31	0.36	0.26	0.29	0.58	0.50	0.31	0.22	0.29	0.33	0.23	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+0.89	N/A	N/A	N/A	N/A	N/A	-11	N/A	N/A
Regional (16 neighbors)	+0.34	+0.84	N/A	N/A	N/A	N/A	N/A	-15	+109	+90

Nomenclature: See separate page