

KEY WEST NAS, FL, USA

WMO: 722015

Lat: 24.583N

Lon: 81.683W

Elev: 6

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12850

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	54.8	57.6	40.3	36.8	58.7	45.0	44.1	61.3	25.9	67.4	24.0	66.8	10.4	10	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	91.5	79.4	90.7	79.4	90.0	79.3	82.0	87.8	81.0	87.6	80.4	87.4	9.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.4	158.0	85.4	79.2	151.3	84.9	78.4	147.4	85.0	45.4	87.8	44.5	87.8	43.8	87.6	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.4	19.5	18.1	DB	50.9	93.2	4.2	2.1	47.9	94.7	45.5	95.9	43.1	97.0	40.1	98.5
			WB	44.1	83.8	4.1	2.2	41.1	85.4	38.7	86.7	36.4	88.0	33.4	89.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.6	69.6	72.1	74.2	77.9	81.1	83.8	85.0	85.2	84.0	81.1	76.0	73.1
	DBStd	6.55	6.05	5.50	4.71	3.14	2.57	2.28	1.98	2.07	2.16	3.22	4.25	5.58
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	60	31	12	5	0	0	0	0	0	0	0	1	11
	CDD50	10447	609	620	749	838	964	1014	1084	1090	1020	963	781	715
	CDD65	5034	175	212	289	389	499	564	619	625	570	498	332	262
	CDH74	49634	606	927	1591	2955	5080	6892	7980	8172	7021	5080	2065	1265
	CDH80	17253	30	83	198	574	1461	2758	3601	3787	2859	1471	310	121
(14) Wind	WSAvg	9.7	10.3	10.1	10.8	11.1	10.2	8.7	8.2	8.0	8.1	10.0	10.4	10.1
(15) Precipitation	PrecAvg	39.2	1.9	1.9	1.5	1.7	3.9	5.3	3.8	5.0	6.5	4.6	1.8	1.9
	PrecMax	63.3	16.8	6.5	6.3	9.2	12.9	13.8	11.2	12.6	15.4	16.3	7.0	9.8
	PrecMin	22.7	0.0	0.2	0.0	0.0	0.5	0.1	0.7	1.8	1.5	0.6	0.0	0.0
	PrecStd	9.6	2.9	1.4	1.3	2.0	3.5	3.4	2.4	2.6	3.3	3.9	1.6	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.3	84.1	84.7	87.3	89.4	92.0	92.4	93.0	91.7	89.5	86.7	84.3
		MCWB	74.7	75.5	75.2	76.3	77.5	79.4	79.6	80.0	79.3	79.0	76.9	76.1
	2%	DB	81.0	82.2	83.5	85.7	88.2	90.5	91.3	91.7	90.5	88.3	84.7	82.8
		MCWB	73.6	74.4	74.2	75.6	77.2	79.3	79.2	79.7	79.4	78.5	76.1	75.3
	5%	DB	79.3	81.1	82.2	84.4	87.2	89.5	90.4	90.7	89.7	87.2	83.3	81.3
		MCWB	72.0	73.5	73.3	74.9	76.9	79.2	79.2	79.5	79.4	78.0	75.5	74.4
	10%	DB	77.6	79.5	81.1	83.3	86.0	88.3	89.6	89.9	88.5	85.9	81.7	79.7
		MCWB	71.3	72.4	72.6	74.3	76.3	78.6	79.2	79.4	78.9	77.1	74.5	73.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.9	77.4	78.3	79.4	82.2	82.1	83.2	82.5	83.5	81.6	78.9	78.3
		MCDB	80.7	81.6	82.4	83.6	85.6	87.7	88.1	89.2	87.7	85.3	83.4	81.3
	2%	WB	75.0	75.8	76.4	77.6	79.7	80.9	81.4	81.4	81.0	80.3	77.7	76.8
		MCDB	79.5	80.5	81.4	83.1	85.7	87.5	88.2	88.7	88.0	85.2	82.4	80.8
	5%	WB	73.7	74.8	75.3	76.4	78.3	80.2	80.4	80.5	80.2	79.4	76.8	75.8
		MCDB	77.8	79.4	80.5	82.3	84.7	87.2	87.8	88.2	87.5	85.0	81.5	79.9
	10%	WB	72.6	73.6	74.2	75.5	77.4	79.5	79.9	80.1	79.6	78.4	75.9	74.9
		MCDB	76.4	78.0	79.4	81.5	83.8	87.0	87.6	87.9	87.1	84.0	80.5	78.9
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	10.3	10.2	9.6	9.4	9.1	9.3	9.4	9.3	8.4	8.4	9.0
		MCDBR	10.8	10.1	10.2	9.9	9.8	9.5	9.5	9.9	9.8	8.7	8.7	9.2
		MCWBR	6.7	5.6	5.7	5.3	5.0	4.9	4.6	4.8	4.8	4.3	4.8	5.2
	5% WB	MCDBR	10.2	9.8	9.8	9.7	9.2	9.0	9.3	9.6	9.5	8.3	8.2	8.5
		MCWBR	7.5	6.1	6.2	6.0	5.6	5.4	5.3	5.1	5.4	4.8	5.1	5.9
(40) Clear-Sky Solar Irradiance	taub	0.363	0.377	0.383	0.400	0.424	0.440	0.450	0.434	0.418	0.409	0.377	0.371	(40)
	taud	2.549	2.514	2.475	2.407	2.395	2.419	2.393	2.462	2.475	2.486	2.521	2.548	(41)
	Ebn at Noon	285	288	291	286	277	270	267	273	276	274	277	277	(42)
	Edh at Noon	29	32	35	38	39	37	38	36	35	33	30	28	(43)
(44) All-Sky Solar Radiation	RadAvg	1237	1545	1902	2144	2170	2010	2049	1944	1710	1540	1336	1175	(44)
	RadStd	96	111	82	93	187	155	97	72	89	103	71	106	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	+0.61	+1.51	N/A	N/A	N/A	N/A	N/A	-27	+196	+162

Nomenclature: See separate page