

KEY WEST NAS, FL, USA

WMO: 722015

Lat: 24.583N

Lon: 81.683W

Elev: 2

StdP: 101.30

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12850

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	14.2	4.6	5.3	14.8	7.2	6.3	16.3	11.6	19.6	10.7	19.3	4.6	10	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	33.1	26.4	32.6	26.3	32.2	26.3	27.8	31.0	27.2	30.9	26.9	30.8	4.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	29.7	26.2	21.6	29.4	25.8	21.1	29.4	87.7	31.0	85.6	31.0	83.9	30.9	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
9.6	8.7	8.1	DB	10.5	34.0	2.3	1.1	8.8	34.8	7.5	35.5	6.2	36.1	4.5	37.0	37.0
			WB	6.7	28.8	2.3	1.2	5.1	29.7	3.7	30.4	2.4	31.1	0.8	32.0	32.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	20.9	22.3	23.4	25.5	27.3	28.8	29.4	29.5	28.9	27.3	24.5	22.8
	DBStd	3.64	3.36	3.06	2.62	1.74	1.43	1.27	1.10	1.15	1.20	1.79	2.36	3.10
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	33	17	7	3	0	0	0	0	0	0	0	1	6
	CDD10.0	5804	338	344	416	466	536	563	602	606	567	535	434	397
	CDD18.3	2797	97	118	161	216	277	313	344	347	317	277	184	146
	CDH23.3	27574	337	515	884	1642	2822	3829	4433	4540	3901	2822	1147	703
	CDH26.7	9585	17	46	110	319	812	1532	2001	2104	1588	817	172	67
Wind	WSAvg	4.3	4.6	4.5	4.8	5.0	4.6	3.9	3.6	3.6	3.6	4.5	4.7	4.5
Precipitation	PrecAvg	996	48	49	38	44	100	134	96	128	165	118	45	47
	PrecMax	1608	426	166	160	234	327	350	285	320	390	414	178	250
	PrecMin	577	0	5	0	0	12	2	18	45	39	15	0	1
	PrecStd	245	74	36	32	50	90	87	61	67	83	99	41	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	29.0	29.3	30.7	31.9	33.3	33.6	33.9	33.2	31.9	30.4	29.1
		MCWB	23.7	24.2	24.0	24.6	25.3	26.3	26.4	26.7	26.3	26.1	25.0	24.5
	2%	DB	27.2	27.9	28.6	29.8	31.2	32.5	32.9	33.1	32.5	31.3	29.3	28.2
		MCWB	23.1	23.5	23.5	24.2	25.1	26.3	26.2	26.5	26.3	25.8	24.5	24.1
	5%	DB	26.3	27.3	27.9	29.1	30.7	31.9	32.4	32.6	32.1	30.7	28.5	27.4
		MCWB	22.2	23.1	23.0	23.8	24.9	26.2	26.2	26.4	26.3	25.5	24.2	23.5
	10%	DB	25.3	26.4	27.3	28.5	30.0	31.3	32.0	32.2	31.4	30.0	27.6	26.5
		MCWB	21.8	22.4	22.5	23.5	24.6	25.9	26.2	26.4	26.1	25.1	23.6	23.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.9	25.2	25.7	26.3	27.9	27.8	28.4	28.1	28.6	27.5	26.0	25.7
		MCDB	27.0	27.5	28.0	28.7	29.8	31.0	31.2	31.8	31.0	29.6	28.5	27.4
	2%	WB	23.9	24.4	24.7	25.3	26.5	27.2	27.5	27.4	27.2	26.8	25.4	24.9
		MCDB	26.4	27.0	27.4	28.4	29.8	30.8	31.2	31.5	31.1	29.6	28.0	27.1
	5%	WB	23.2	23.8	24.1	24.7	25.7	26.8	26.9	27.0	26.8	26.3	24.9	24.4
		MCDB	25.4	26.4	27.0	27.9	29.3	30.7	31.0	31.2	30.8	29.5	27.5	26.6
	10%	WB	22.5	23.1	23.4	24.2	25.2	26.4	26.6	26.7	26.4	25.8	24.4	23.8
		MCDB	24.7	25.6	26.3	27.5	28.8	30.5	30.9	31.0	30.6	28.9	27.0	26.1
Mean Daily Temperature Range	5% DB	MDBR	5.7	5.7	5.7	5.3	5.2	5.1	5.1	5.2	5.2	4.6	4.7	5.0
		MCDBR	6.0	5.6	5.6	5.5	5.4	5.3	5.3	5.5	5.5	4.9	4.9	5.1
		MCWBR	3.7	3.1	3.1	3.0	2.8	2.7	2.6	2.6	2.6	2.4	2.7	2.9
	5% WB	MCDBR	5.7	5.5	5.5	5.4	5.1	5.0	5.1	5.3	5.3	4.6	4.5	4.7
		MCWBR	4.2	3.4	3.4	3.4	3.1	3.0	2.9	2.8	3.0	2.7	2.8	3.3
Clear-Sky Solar Irradiance	taub	0.363	0.377	0.383	0.400	0.424	0.440	0.440	0.450	0.434	0.418	0.409	0.377	0.371
	taud	2.549	2.514	2.475	2.407	2.395	2.419	2.393	2.393	2.462	2.475	2.486	2.521	2.548
	Ebn at Noon	897	908	916	901	873	852	843	860	870	863	874	874	874
	Edh at Noon	92	101	110	120	122	118	121	113	109	103	94	89	89
All-Sky Solar Radiation	RadAvg	3.90	4.87	6.00	6.76	6.84	6.34	6.46	6.13	5.39	4.86	4.21	3.71	3.71
	RadStd	0.30	0.35	0.26	0.29	0.59	0.49	0.31	0.23	0.28	0.33	0.23	0.33	0.33

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	+0.34	+0.84	N/A	N/A	N/A	N/A	N/A	-15	+109	+90	

Nomenclature: See separate page