

MIAMI NHC, FL, USA

WMO: 722020

Lat: 25.7552N

Lon: 80.3836W

Elev: 9

StdP: 101.22

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12839

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	11.5	0.1	3.8	13.2	2.8	4.6	14.1	9.7	24.0	9.0	23.1	3.2	330	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	33.3	25.4	32.7	25.4	32.2	25.3	26.9	30.4	26.6	30.4	26.3	30.2	4.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.3	28.6	25.5	20.8	28.5	25.2	20.3	28.5	84.2	30.5	82.5	30.3	81.3	30.2	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	8.1	7.4	6.0	34.9	2.2	0.9	4.4	35.6	3.1	36.1	1.9	36.6	0.2	37.3		
(5)			3.1	27.7	2.5	0.7	1.3	28.2	-0.2	28.7	-1.6	29.1	-3.4	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	20.2	21.5	22.8	24.8	26.8	28.2	28.9	29.0	28.3	26.7	23.7	21.9
	DBStd	3.87	3.84	3.43	2.97	2.08	1.49	1.35	1.17	1.15	1.21	1.94	2.54	3.59
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	62	27	13	6	0	0	0	0	0	0	0	2	14
	CDD10.0	5568	318	323	396	444	521	546	586	588	549	517	411	369
	CDD18.3	2589	87	103	143	194	263	296	327	329	299	259	163	125
	CDH23.3	24017	340	475	803	1389	2456	3242	3921	3934	3343	2468	1017	629
CDH26.7	7752	21	52	139	297	715	1194	1633	1627	1211	669	138	55	
Wind	WSAvg	3.5	3.6	3.7	4.1	4.2	3.9	3.2	3.1	2.9	3.1	3.7	3.6	3.5
Precipitation	PrecAvg	1514	49	53	58	79	151	239	154	199	230	175	78	50
	PrecMax	2209	192	172	167	268	471	568	324	423	620	550	352	250
	PrecMin	850	5	0	5	2	11	50	43	58	46	18	9	2
	PrecStd	304	43	42	42	66	109	122	67	91	112	120	64	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.4	29.5	31.0	31.8	33.2	33.9	34.0	34.0	33.5	32.3	30.2	29.1
		MCWB	22.5	22.1	23.0	22.7	24.0	25.3	25.5	25.5	25.4	25.2	23.9	23.5
	2%	DB	27.2	28.1	29.5	30.5	31.8	32.8	33.0	33.1	32.5	31.3	29.1	28.0
		MCWB	21.9	22.1	22.7	22.9	23.8	25.3	25.5	25.7	25.4	24.9	23.5	22.8
	5%	DB	26.3	27.2	28.2	29.4	30.8	32.0	32.5	32.5	31.8	30.5	28.2	27.2
		MCWB	21.3	21.8	22.1	22.5	23.7	25.2	25.5	25.7	25.4	24.6	23.0	22.4
	10%	DB	25.3	26.2	27.0	28.4	30.0	31.2	31.8	31.9	31.1	29.7	27.4	26.4
		MCWB	20.8	21.2	21.4	22.0	23.4	25.0	25.4	25.6	25.3	24.2	22.3	22.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.0	24.2	25.2	25.0	26.2	27.0	26.9	27.2	27.4	27.1	25.6	24.9
		MCDB	26.1	26.4	27.9	28.6	29.7	30.6	31.2	31.2	30.3	29.3	27.8	27.0
	2%	WB	23.0	23.4	24.1	24.3	25.4	26.4	26.6	26.8	26.8	26.3	24.8	24.2
		MCDB	25.6	25.9	27.3	27.8	29.2	30.4	31.0	30.9	30.1	29.1	27.2	26.5
	5%	WB	22.5	22.8	23.3	23.8	24.9	26.0	26.3	26.5	26.4	25.7	24.2	23.7
		MCDB	25.1	25.6	26.5	27.4	28.7	30.0	30.7	30.6	29.9	28.8	26.8	26.0
	10%	WB	21.7	22.1	22.6	23.1	24.4	25.6	25.8	26.2	26.0	25.3	23.7	22.9
		MCDB	24.4	25.1	25.9	27.0	28.2	29.7	30.2	30.3	29.5	28.5	26.4	25.3
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.7	7.6	7.1	6.7	6.5	6.5	6.4	6.1	5.8	6.6	6.9
		MCDBR	6.9	7.4	8.0	7.8	7.4	7.1	6.8	6.8	6.5	6.1	6.3	6.3
		MCWBR	3.5	3.1	3.4	3.2	2.9	2.8	2.7	2.6	2.5	2.3	2.8	3.1
	5% WB	MCDBR	6.5	6.5	7.4	7.0	6.9	6.8	6.5	6.4	6.2	5.6	5.7	5.7
		MCWBR	3.9	3.3	3.7	3.4	3.0	3.1	2.9	2.8	2.7	2.5	3.0	3.5
Clear-Sky Solar Irradiance	taub		0.364	0.375	0.388	0.398	0.426	0.458	0.463	0.455	0.432	0.415	0.381	0.373
	taud		2.524	2.503	2.456	2.414	2.381	2.348	2.327	2.378	2.440	2.454	2.497	2.516
	Ebn at Noon		890	905	909	902	871	836	832	840	855	852	863	864
	Edh at Noon		93	102	112	119	123	126	129	122	112	106	95	91
All-Sky Solar Radiation	RadAvg		3.70	4.47	5.47	6.18	6.20	5.62	5.78	5.58	4.92	4.54	3.91	3.44
	RadStd		0.24	0.25	0.25	0.29	0.50	0.49	0.25	0.29	0.25	0.31	0.18	0.25

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.32	+0.77	N/A	N/A	N/A	N/A	N/A	-16	+114	+93
(47)	Regional (29 neighbors)	+0.38	+0.88	N/A	N/A	N/A	N/A	N/A	-18	+131	+111

Nomenclature: See separate page