

FOLSOM FIELD, AL, USA

WMO: 722031

Lat: 34.269N

Lon: 86.858W

Elev: 963

StdP: 14.19

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 63839

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.6	21.5	2.5	6.5	26.7	8.6	8.9	28.3	18.7	57.0	16.8	52.8	4.7	0	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	93.1	74.4	91.2	75.1	89.8	74.6	79.1	87.7	77.6	87.5	76.5	85.9	4.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	145.5	83.1	75.2	137.1	80.9	73.6	129.6	80.5	43.3	88.1	41.7	87.7	40.6	85.0	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.4	13.5	11.8	DB	11.3	95.7	5.1	1.8	7.7	97.0	4.7	98.0	1.8	99.0	-1.8	100.2
(5)				WB	10.3	79.9	5.3	1.4	6.5	80.9	3.4	81.7	0.4	82.6	-3.4	83.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	40.8	45.4	52.0	60.3	68.2	76.1	78.3	77.3	72.8	61.8	51.2	44.7
	DBStd	15.36	11.25	10.27	9.80	7.64	6.87	3.97	3.59	4.10	5.85	8.38	8.76	9.59
	HDD50	957	330	194	96	11	1	0	0	0	0	10	90	225
	HDD65	3163	751	551	411	177	51	0	0	0	11	161	420	630
	CDD50	4911	44	65	160	321	566	783	878	847	685	376	125	61
	CDD65	1644	0	3	9	37	151	333	413	382	246	63	6	1
	CDH74	14296	0	6	69	325	1287	3027	3717	3243	2071	520	31	0
	CDH80	5776	0	0	7	34	384	1298	1689	1415	817	129	3	0
Wind	WSAvg	4.3	5.4	5.8	5.6	5.4	3.7	3.1	2.8	2.7	3.0	3.8	4.6	5.2
Precipitation	PrecAvg	56.5	5.7	5.5	5.7	4.8	5.0	4.3	4.3	3.9	4.1	3.4	4.6	5.6
	PrecMax	67.0	9.4	11.1	8.7	9.1	11.2	11.7	8.0	6.3	7.4	8.1	9.5	12.1
	PrecMin	30.2	2.7	2.4	1.3	1.9	0.5	1.3	1.5	0.8	0.4	0.0	2.3	1.3
	PrecStd	8.7	2.0	2.3	1.8	1.7	2.7	2.4	1.7	1.6	2.0	2.4	1.8	2.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.3	74.1	80.4	84.0	90.1	95.7	94.5	95.3	94.3	88.4	78.7	70.5
		MCWB	59.6	62.1	59.7	66.0	71.5	71.0	75.8	77.0	71.7	70.5	63.8	62.2
	2%	DB	65.1	69.3	75.5	80.3	87.4	91.4	92.1	92.1	91.1	83.3	72.7	67.5
		MCWB	58.8	61.0	60.1	64.0	70.9	74.7	76.5	75.6	71.8	67.7	60.1	61.9
	5%	DB	61.4	65.9	71.7	77.9	84.8	90.2	90.8	90.6	88.3	79.5	69.3	63.9
		MCWB	56.2	58.7	58.7	62.8	70.1	74.5	76.3	75.3	71.9	66.1	61.4	59.3
	10%	DB	58.6	62.0	68.2	75.2	81.4	87.8	88.7	88.0	85.7	76.1	66.3	60.3
		MCWB	53.9	54.8	58.1	61.5	68.0	73.5	75.5	74.3	71.6	64.3	59.2	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.9	65.7	66.5	70.4	75.2	79.0	81.9	81.6	76.6	73.2	68.6	66.4
		MCDB	66.3	70.2	70.8	77.1	82.1	87.1	87.2	87.9	86.6	79.5	71.1	68.6
	2%	WB	60.4	63.5	63.9	68.2	73.1	77.3	79.4	79.0	75.1	71.4	66.2	63.1
		MCDB	63.5	68.0	69.8	74.5	81.4	87.7	87.6	88.1	84.5	79.5	69.1	65.7
	5%	WB	57.8	60.4	62.0	66.1	71.6	76.1	77.9	77.3	73.8	69.4	63.4	60.4
		MCDB	61.0	63.9	68.4	73.2	81.1	86.0	87.4	86.8	82.7	76.1	67.7	63.0
	10%	WB	54.8	57.0	59.7	64.2	70.4	74.9	76.9	76.1	72.6	67.3	60.0	56.7
		MCDB	57.6	60.4	66.2	72.1	78.9	84.0	86.3	84.6	81.1	73.2	64.4	59.6
Mean Daily Temperature Range	5% DB	MDBR	18.2	19.2	20.7	23.0	21.2	20.8	19.8	19.9	21.4	22.6	21.7	17.5
		MCDBR	19.5	22.5	24.3	25.1	24.8	24.4	22.3	23.4	24.9	25.2	24.3	18.7
		MCWBR	14.6	14.2	13.8	11.6	10.8	9.4	8.9	8.8	9.2	11.7	14.7	14.2
	5% WB	MCDBR	16.5	17.2	19.9	19.1	20.2	20.7	20.0	19.8	19.7	19.4	16.4	16.9
		MCWBR	14.4	13.3	12.6	10.8	9.7	9.4	9.0	8.5	8.2	10.8	12.8	15.3
Clear-Sky Solar Irradiance	taub	0.313	0.318	0.359	0.390	0.439	0.469	0.510	0.514	0.421	0.370	0.335	0.314	
	taud	2.511	2.495	2.402	2.301	2.210	2.158	2.063	2.044	2.292	2.419	2.462	2.524	
	Ebn at Noon	285	296	290	285	271	261	249	246	266	273	274	278	
	Edh at Noon	26	30	36	41	46	48	53	53	39	32	28	25	
All-Sky Solar Radiation	RadAvg	796	961	1328	1717	1879	1973	1890	1752	1524	1241	908	680	
	RadStd	62	122	124	120	147	156	110	97	134	160	97	65	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (35 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+259	+189

Nomenclature: See separate page