

FOLSOM FIELD, AL, USA

WMO: 722031

Lat: 34.269N

Lon: 86.858W

Elev: 294

StdP: 97.85

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 63839

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.0	-5.8	-16.4	0.9	-3.0	-13.0	1.3	-2.1	8.3	13.9	7.5	11.6	2.1	0	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	34.0	23.5	32.9	24.0	32.1	23.7	26.2	31.0	25.3	30.8	24.7	29.9	1.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	20.8	28.4	24.0	19.6	27.1	23.1	18.5	27.0	82.9	31.2	79.2	30.9	76.6	29.5	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.0	5.3	-11.5	35.4	2.8	1.0	-13.5	36.1	-15.2	36.7	-16.8	37.2	-18.8	37.9		
(5)			-12.0	26.6	3.0	0.8	-14.2	27.2	-15.9	27.6	-17.5	28.1	-19.7	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	4.9	7.4	11.1	15.7	20.1	24.5	25.7	25.2	22.7	16.6	10.7	7.1	(6)
(7)		DBStd	8.54	6.25	5.71	5.45	4.24	3.82	2.20	2.00	2.28	3.25	4.65	4.86	5.33	(7)
(8)		HDD10.0	532	183	108	53	6	1	0	0	0	0	6	50	125	(8)
(9)		HDD18.3	1757	417	306	228	98	28	0	0	0	6	89	233	350	(9)
(10)		CDD10.0	2728	24	36	89	178	314	435	488	471	381	209	69	34	(10)
(11)		CDD18.3	913	0	2	5	21	84	185	229	212	137	35	3	1	(11)
(12)		CDH23.3	7942	0	3	38	181	715	1682	2065	1802	1151	289	17	0	(12)
(13)		CDH26.7	3209	0	0	4	19	213	721	938	786	454	72	2	0	(13)
(14)	Wind	WSAvg	1.9	2.4	2.6	2.5	2.4	1.6	1.4	1.2	1.2	1.4	1.7	2.1	2.3	(14)
(15)	Precipitation	PrecAvg	1436	146	140	144	122	126	110	109	100	103	87	117	143	(15)
(16)		PrecMax	1702	240	282	222	230	285	298	203	159	187	205	242	307	(16)
(17)		PrecMin	767	68	60	33	48	13	34	37	20	9	1	59	33	(17)
(18)		PrecStd	222	51	58	45	44	68	62	43	40	52	61	45	66	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.7	23.4	26.9	28.9	32.3	35.4	34.7	35.2	34.6	31.3	25.9	21.4	(19)
(20)			MCWB	15.4	16.7	15.4	18.9	22.0	21.7	24.4	25.0	22.1	21.4	17.6	16.8	(20)
(21)		2%	DB	18.4	20.7	24.2	26.8	30.8	33.0	33.4	33.4	32.9	28.5	22.6	19.7	(21)
(22)			MCWB	14.9	16.1	15.6	17.8	21.6	23.7	24.7	24.2	22.1	19.8	15.6	16.6	(22)
(23)		5%	DB	16.3	18.8	22.0	25.5	29.4	32.3	32.7	32.5	31.3	26.4	20.7	17.7	(23)
(24)			MCWB	13.5	14.8	14.8	17.1	21.2	23.6	24.6	24.0	22.2	18.9	16.3	15.2	(24)
(25)		10%	DB	14.8	16.7	20.1	24.0	27.5	31.0	31.5	31.1	29.8	24.5	19.0	15.7	(25)
(26)			MCWB	12.2	12.7	14.5	16.4	20.0	23.1	24.2	23.5	22.0	18.0	15.1	13.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	18.7	19.2	21.4	24.0	26.1	27.7	27.6	24.8	22.9	20.4	19.1	(27)
(28)			MCD B	19.1	21.2	21.6	25.1	27.8	30.6	30.6	31.1	30.3	26.4	21.7	20.3	(28)
(29)		2%	WB	15.8	17.5	17.7	20.1	22.8	25.2	26.3	26.1	23.9	21.9	19.0	17.3	(29)
(30)			MCD B	17.5	20.0	21.0	23.6	27.5	31.0	30.9	31.2	29.2	26.4	20.6	18.7	(30)
(31)		5%	WB	14.3	15.8	16.7	18.9	22.0	24.5	25.5	25.1	23.2	20.8	17.4	15.8	(31)
(32)			MCD B	16.1	17.7	20.2	22.9	27.3	30.0	30.8	30.5	28.1	24.5	19.8	17.2	(32)
(33)		10%	WB	12.7	13.9	15.4	17.9	21.3	23.9	24.9	24.5	22.6	19.6	15.5	13.7	(33)
(34)			MCD B	14.2	15.8	19.0	22.3	26.1	28.9	30.2	29.2	27.3	22.9	18.0	15.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	10.7	11.5	12.8	11.8	11.6	11.0	11.0	11.9	12.5	12.1	9.7	(35)
(36)			MCDBR	10.9	12.5	13.5	13.9	13.8	13.6	12.4	13.0	13.9	14.0	13.5	10.4	(36)
(37)			MCWBR	8.1	7.9	7.7	6.4	6.0	5.2	4.9	4.9	5.1	6.5	8.1	7.9	(37)
(38)		5% WB	MCD BR	9.1	9.5	11.1	10.6	11.2	11.5	11.1	11.0	10.9	10.8	9.1	9.4	(38)
(39)			MCWBR	8.0	7.4	7.0	6.0	5.4	5.2	5.0	4.7	4.6	6.0	7.1	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.318	0.359	0.390	0.439	0.469	0.510	0.514	0.421	0.370	0.335	0.314	(40)	
(41)		taud	2.511	2.495	2.402	2.301	2.210	2.158	2.063	2.044	2.292	2.419	2.462	2.524	(41)	
(42)		Ebn at Noon	899	933	915	897	853	823	786	776	839	860	863	876	(42)	
(43)		Edh at Noon	83	94	112	130	144	151	166	166	124	101	87	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.51	3.03	4.19	5.41	5.92	6.22	5.96	5.52	4.80	3.91	2.86	2.14	(44)	
(45)		RadStd	0.19	0.39	0.39	0.38	0.46	0.49	0.35	0.30	0.42	0.50	0.31	0.21	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+105

Nomenclature: See separate page