

MIAMI NORTH PERRY, FL, USA

WMO: 722037

Lat: 25.999N

Lon: 80.241W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 92809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.0	10.3	-0.8	3.5	12.5	2.1	4.4	14.2	10.5	20.2	9.3	20.4	3.6	340	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	33.8	25.4	33.0	25.3	32.5	25.2	26.8	31.0	26.5	30.5	26.2	30.2	4.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	28.2	25.4	20.6	28.2	25.0	20.1	28.2	83.5	30.4	82.0	30.2	80.8	30.3	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	8.4	7.7	4.5	36.3	1.9	2.4	3.2	38.0	2.0	39.5	1.0	40.8	-0.4	42.6		
			DB	WB	2.1	27.6	2.0	0.6	0.6	28.0	-0.6	28.4	-1.7	28.8	-3.2	29.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	19.5	21.1	22.5	24.5	26.5	28.1	28.8	28.9	28.2	26.5	23.3	21.5
	DBStd	4.06	3.95	3.44	3.02	2.19	1.51	1.47	1.25	1.09	1.31	2.13	2.87	3.65
	HDD10.0	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD18.3	78	36	15	6	1	0	0	0	0	0	3	17	
	CDD10.0	5465	296	311	386	434	511	543	582	587	547	513	399	357
	CDD18.3	2501	73	93	134	185	252	293	323	329	297	255	152	115
	CDH23.3	23245	319	478	808	1357	2312	3131	3734	3848	3217	2429	1018	594
	CDH26.7	7832	21	67	163	328	707	1194	1563	1608	1201	727	192	61
Wind	WSAvg	3.6	3.8	3.8	4.2	4.2	4.0	3.1	2.8	2.9	3.2	3.9	3.9	3.7
Precipitation	PrecAvg	1514	54	60	66	81	117	230	155	179	248	174	76	55
	PrecMax	1890	205	136	163	168	282	408	252	298	425	345	243	178
	PrecMin	1254	12	1	8	18	0	73	73	76	135	43	12	12
	PrecStd	184	41	42	39	44	66	108	52	61	83	98	63	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.3	29.8	31.5	32.3	33.2	34.6	34.6	34.5	34.3	33.0	32.2	29.2
		MCWB	22.1	21.8	22.6	22.9	23.6	25.3	25.4	25.7	25.6	25.0	24.0	23.5
	2%	DB	27.3	28.4	29.9	30.9	32.1	33.2	33.5	33.5	32.8	31.8	30.0	28.0
		MCWB	21.5	21.8	22.2	22.7	23.5	25.2	25.4	25.7	25.5	25.0	23.8	22.7
	5%	DB	26.3	27.4	28.5	29.6	31.1	32.4	32.8	32.9	32.2	31.0	28.6	27.3
		MCWB	20.9	21.3	21.8	22.2	23.4	25.1	25.4	25.7	25.4	24.6	22.8	22.1
	10%	DB	25.3	26.3	27.3	28.6	30.1	31.5	32.2	32.3	31.3	30.0	27.6	26.4
		MCWB	20.2	20.6	21.2	21.9	23.0	24.8	25.4	25.6	25.2	24.0	22.0	21.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.4	24.2	24.7	25.6	26.8	26.9	27.4	27.4	26.7	25.7	24.5
		MCDB	26.3	27.1	28.4	29.1	30.2	31.2	31.3	31.2	32.3	29.9	29.0	27.5
	2%	WB	22.6	22.8	23.5	24.1	24.9	26.2	26.5	26.8	26.7	25.9	24.7	23.9
		MCDB	25.6	26.3	27.4	28.0	29.2	30.6	30.9	30.8	30.8	29.3	28.2	26.8
	5%	WB	21.9	22.3	22.9	23.6	24.5	25.8	26.1	26.4	26.3	25.5	24.1	23.2
		MCDB	25.0	25.7	26.5	27.5	28.7	30.1	30.6	30.6	29.8	29.0	27.5	26.0
	10%	WB	21.3	21.7	22.2	23.0	24.1	25.5	25.8	26.1	25.8	25.1	23.4	22.7
		MCDB	24.3	25.1	26.1	26.8	28.3	29.8	30.2	30.3	29.4	28.7	26.6	25.4
Mean Daily Temperature Range	5% DB	MDBR	9.3	8.8	8.7	8.2	7.6	7.2	7.2	7.2	6.8	6.8	8.0	8.0
		MCDBR	8.5	8.7	9.2	9.0	8.5	7.9	7.7	7.7	7.3	7.3	7.9	7.5
		MCWBR	4.2	3.7	3.7	3.5	3.0	2.8	2.8	2.7	2.5	2.7	3.3	3.7
	5% WB	MCDBR	7.7	7.9	8.2	7.9	7.6	7.4	7.3	7.2	6.7	6.4	6.9	6.5
		MCWBR	4.4	3.8	3.9	3.5	3.1	3.0	2.9	2.9	2.7	2.7	3.2	3.7
Clear-Sky Solar Irradiance	taub	0.364	0.372	0.386	0.401	0.428	0.463	0.468	0.460	0.435	0.415	0.381	0.373	
	taud	2.521	2.515	2.462	2.404	2.371	2.330	2.310	2.358	2.429	2.453	2.496	2.513	
	Ebn at Noon	888	908	911	899	869	833	828	835	851	852	862	862	
	Edh at Noon	93	100	111	120	124	129	131	125	113	105	95	91	
All-Sky Solar Radiation	RadAvg	3.66	4.44	5.42	6.17	6.21	5.67	5.80	5.59	4.92	4.54	3.88	3.39	
	RadStd	0.24	0.26	0.27	0.29	0.51	0.51	0.27	0.30	0.25	0.32	0.19	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.51	+1.14	N/A	+0.60	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.38	+0.86	N/A	N/A	N/A	N/A	N/A	-21	+130	+102

Nomenclature: See separate page