

NAPLES, FL, USA

WMO: 722038

Lat: 26.155N

Lon: 81.775W

Elev: 9

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12897

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	44.5	47.9	29.5	23.5	53.7	34.2	28.9	53.4	23.0	73.0	19.9	71.7	5.7	30	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.6	92.0	78.0	90.9	78.1	90.0	78.0	81.4	87.7	80.5	87.1	79.9	86.8	10.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.6	153.9	84.6	78.7	149.1	84.1	77.9	145.1	83.6	44.9	87.7	44.0	87.2	43.2	86.8	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.1	17.2	15.5	37.6	94.5	3.4	1.5	35.2	95.5	33.2	96.4	31.2	97.2	28.7	98.3		
(5)			33.1	82.7	3.7	1.7	30.4	83.9	28.3	84.9	26.2	85.9	23.5	87.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.2	64.6	67.1	70.1	74.2	78.5	81.6	82.6	82.9	82.1	78.6	71.7	67.8		
	DBStd	7.95	7.26	6.69	5.55	4.06	2.76	2.21	2.02	1.96	2.07	4.02	5.34	7.01		
	HDD50	5	3	1	0	0	0	0	0	0	0	0	0	1		
	HDD65	249	100	54	23	2	0	0	0	0	0	1	13	56		
	CDD50	9202	455	480	625	726	883	949	1010	1021	962	887	650	554		
	CDD65	3969	87	112	182	278	418	499	545	556	512	423	213	144		
	CDH74	35781	391	570	1113	2069	3868	5124	5845	5968	5125	3697	1287	724		
	CDH80	12384	31	67	177	503	1307	2029	2388	2419	1925	1201	240	97		
(14) Wind	WSAvg	7.1	7.4	7.4	8.1	8.3	7.6	6.7	5.9	6.0	6.5	7.4	7.3	7.1		
(15) Precipitation	PrecAvg	49.7	1.9	1.7	1.5	2.2	3.0	7.9	8.0	8.3	8.2	3.8	1.5	1.4		
	PrecMax	71.4	8.5	5.9	5.9	7.0	9.6	19.9	14.0	13.3	19.2	15.3	6.8	6.8		
	PrecMin	28.4	0.1	0.0	0.0	0.1	0.5	2.2	2.8	3.7	3.9	0.4	0.0	0.1		
	PrecStd	11.8	2.1	1.3	1.3	1.6	1.9	3.6	2.8	2.6	3.7	3.1	1.6	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	84.7	86.0	88.9	91.4	93.3	93.1	93.7	92.4	91.2	87.2	84.9		
		MCWB	70.7	71.9	71.2	73.3	73.5	77.3	78.3	78.2	77.8	77.2	75.0	73.0		
	2%	DB	80.9	82.0	83.8	86.6	89.2	91.1	91.3	91.6	90.8	89.2	84.5	82.6		
		MCWB	69.8	71.0	70.8	72.8	74.0	78.1	78.8	78.7	77.9	76.5	73.3	72.4		
	5%	DB	78.7	80.2	82.0	84.7	87.7	89.8	90.2	90.4	89.7	87.6	82.7	80.8		
		MCWB	68.8	70.1	70.3	72.1	74.4	78.0	78.7	78.8	78.1	76.0	71.9	71.2		
	10%	DB	76.0	77.9	80.4	82.9	86.1	88.3	89.0	89.3	88.3	85.9	81.0	78.6		
		MCWB	67.7	68.8	69.7	71.6	74.2	77.6	78.5	78.8	77.8	75.3	70.8	70.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.8	74.7	76.6	77.9	79.8	81.9	82.4	83.2	81.3	80.7	77.2	76.0		
		MCDB	78.9	80.5	81.4	83.4	85.0	87.6	88.5	88.1	88.0	86.5	82.8	80.9		
	2%	WB	72.4	73.3	74.8	76.4	78.1	80.5	81.1	81.4	80.3	78.9	75.8	74.6		
		MCDB	77.4	79.1	80.0	82.6	84.4	87.0	87.8	87.5	87.2	85.0	81.6	79.5		
	5%	WB	70.8	72.1	73.2	75.1	77.1	79.8	80.2	80.3	79.6	78.0	74.6	73.2		
		MCDB	75.7	77.5	78.7	81.6	83.8	86.5	87.3	87.0	86.7	84.3	80.3	78.0		
	10%	WB	69.3	70.7	71.8	73.7	76.2	78.9	79.4	79.6	78.8	77.2	73.1	71.8		
		MCDB	74.2	75.7	77.4	80.1	83.1	85.7	86.7	86.8	85.6	83.5	78.5	76.7		
(35) Mean Daily Temperature Range	MDBR		17.9	17.8	17.4	16.9	16.0	13.8	13.5	13.6	13.2	14.5	16.7	16.9		
	5% DB	MCDBR	17.9	18.1	18.1	18.5	17.6	15.5	14.5	14.7	14.4	15.1	16.4	16.3		
		MCWBR	9.0	8.8	8.1	7.9	6.8	6.3	6.0	5.8	5.4	5.7	7.2	7.8		
	5% WB	MCDBR	15.2	15.6	14.2	15.2	14.4	13.8	13.4	13.3	13.1	13.0	13.8	14.2		
		MCWBR	9.6	8.6	8.8	7.8	6.6	6.3	6.1	6.0	5.6	5.8	7.3	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.352	0.370	0.381	0.394	0.421	0.443	0.458	0.448	0.421	0.402	0.366	0.356		
	taud		2.532	2.491	2.445	2.383	2.363	2.377	2.326	2.385	2.443	2.468	2.513	2.545		
	Ebn at Noon		286	288	290	287	278	270	265	268	274	274	279	279		
	Edh at Noon		29	32	36	39	40	39	41	38	36	33	30	28		
(44) All-Sky Solar Radiation	RadAvg		1194	1468	1786	2056	2102	1898	1870	1792	1616	1512	1294	1112		
	RadStd		87	90	106	89	148	169	116	82	104	86	70	76		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.13	+2.39	N/A	+0.70	+1.31	+1.51	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.70	+1.58	N/A	N/A	N/A	N/A	N/A	-38	+256	+205

Nomenclature: See separate page