

NAPLES, FL, USA

WMO: 722038

Lat: 26.155N

Lon: 81.775W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12897

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	8.8	-1.4	3.4	12.1	1.2	4.1	11.9	10.3	22.8	8.9	22.1	2.6	30	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.3	25.6	32.7	25.6	32.2	25.6	27.5	30.9	26.9	30.6	26.6	30.5	4.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.0	29.2	26.0	21.3	28.9	25.5	20.7	28.7	86.6	31.0	84.6	30.7	82.7	30.5	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.7	6.9	3.1	34.7	1.9	0.8	1.8	35.3	0.6	35.8	-0.4	36.2	-1.8	36.8		
			0.6	28.2	2.1	0.9	-0.9	28.8	-2.1	29.4	-3.2	29.9	-4.7	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	18.1	19.5	21.2	23.5	25.8	27.6	28.1	28.3	27.8	25.9	22.0	19.9
	DBStd	4.42	4.03	3.72	3.08	2.25	1.53	1.23	1.12	1.09	1.15	2.23	2.97	3.90
	HDD10.0	3	2	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	138	56	30	13	1	0	0	0	0	0	1	7	31
	CDD10.0	5112	253	267	347	403	491	527	561	567	534	493	361	308
	CDD18.3	2205	48	62	101	154	232	277	303	309	284	235	118	80
	CDH23.3	19878	217	317	618	1149	2149	2847	3247	3316	2847	2054	715	402
	CDH26.7	6880	17	37	98	279	726	1127	1327	1344	1069	667	133	54
Wind	WSAvg	3.2	3.3	3.3	3.6	3.7	3.4	3.0	2.6	2.7	2.9	3.3	3.3	3.2
Precipitation	PrecAvg	1263	49	43	39	56	76	201	203	210	208	96	38	36
	PrecMax	1813	216	149	149	177	244	506	355	339	487	388	172	173
	PrecMin	722	2	0	1	3	12	57	70	93	99	11	0	2
	PrecStd	299	54	33	34	40	48	92	70	65	93	78	40	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	29.3	30.0	31.6	33.0	34.1	33.9	34.3	33.5	32.9	30.7	29.4
		MCWB	21.5	22.2	21.8	23.0	23.0	25.2	25.7	25.7	25.5	25.1	23.9	22.8
	2%	DB	27.2	27.8	28.8	30.4	31.8	32.8	32.9	33.1	32.7	31.8	29.2	28.1
		MCWB	21.0	21.7	21.5	22.7	23.3	25.6	26.0	25.9	25.5	24.7	22.9	22.4
	5%	DB	26.0	26.8	27.8	29.3	30.9	32.1	32.3	32.4	32.0	30.9	28.2	27.1
		MCWB	20.4	21.2	21.3	22.3	23.6	25.6	26.0	26.0	25.6	24.5	22.2	21.8
	10%	DB	24.4	25.5	26.9	28.3	30.1	31.3	31.7	31.9	31.3	30.0	27.2	25.9
		MCWB	19.8	20.5	20.9	22.0	23.5	25.3	25.8	26.0	25.5	24.1	21.6	21.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	23.7	24.8	25.5	26.5	27.7	28.0	28.5	27.4	27.0	25.1	24.5
		MCDB	26.1	26.9	27.4	28.6	29.4	30.9	31.4	31.2	31.1	30.3	28.2	27.1
	2%	WB	22.5	22.9	23.8	24.7	25.6	27.0	27.3	27.5	26.8	26.1	24.3	23.7
		MCDB	25.2	26.1	26.7	28.1	29.1	30.6	31.0	30.8	30.7	29.5	27.5	26.4
	5%	WB	21.6	22.3	22.9	24.0	25.1	26.6	26.8	26.9	26.4	25.6	23.7	22.9
		MCDB	24.3	25.3	25.9	27.5	28.8	30.3	30.7	30.6	30.4	29.1	26.8	25.6
	10%	WB	20.7	21.5	22.1	23.2	24.5	26.0	26.4	26.5	26.0	25.1	22.8	22.1
		MCDB	23.4	24.3	25.2	26.7	28.4	29.8	30.4	30.4	29.8	28.6	25.8	24.8
Mean Daily Temperature Range	5% DB	MDBR	9.9	9.9	9.7	9.4	8.9	7.7	7.5	7.6	7.3	8.1	9.3	9.4
		MCDBR	9.9	10.1	10.1	10.3	9.8	8.6	8.1	8.1	8.0	8.4	9.1	9.1
		MCWBR	5.0	4.9	4.5	4.4	3.8	3.5	3.3	3.2	3.0	3.1	4.0	4.3
	5% WB	MCDBR	8.5	8.7	7.9	8.5	8.0	7.7	7.4	7.4	7.3	7.2	7.6	7.9
		MCWBR	5.3	4.8	4.9	4.3	3.7	3.5	3.4	3.3	3.1	3.2	4.0	4.6
Clear-Sky Solar Irradiance	taub	0.352	0.370	0.381	0.394	0.421	0.443	0.458	0.448	0.421	0.402	0.366	0.356	
	taud	2.532	2.491	2.445	2.383	2.363	2.377	2.326	2.385	2.443	2.468	2.513	2.545	
	Ebn at Noon	901	909	915	905	875	850	836	846	864	864	878	881	
	Edh at Noon	92	102	113	123	125	123	129	121	112	104	93	88	
All-Sky Solar Radiation	RadAvg	3.77	4.63	5.63	6.48	6.63	5.98	5.90	5.65	5.09	4.77	4.08	3.50	
	RadStd	0.27	0.28	0.33	0.28	0.47	0.53	0.37	0.26	0.33	0.27	0.22	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.63	+1.33	N/A	+0.39	+0.73	+0.84	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.39	+0.88	N/A	N/A	N/A	N/A	N/A	-21	+142	+114

Nomenclature: See separate page