

FORT LAUDERDALE EXECUTIVE, FL, USA

WMO: 722039

Lat: 26.197N

Lon: 80.171W

Elev: 14

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 12885

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.2	50.4	29.0	23.0	56.5	34.3	29.0	56.8	23.0	73.3	20.4	73.6	6.0	300	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.5	92.3	77.2	91.1	77.3	90.2	77.2	80.3	86.7	79.6	86.3	79.0	85.9	10.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	149.9	82.8	77.7	144.2	82.6	77.1	141.2	82.5	43.5	86.3	42.9	85.7	42.4	86.2	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.6	16.9	40.1	95.3	3.1	1.5	37.9	96.4	36.1	97.3	34.3	98.2	32.1	99.3		
(5)			35.0	81.9	3.7	1.8	32.4	83.2	30.2	84.3	28.1	85.3	25.3	86.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	76.7	67.2	70.0	72.1	76.0	79.4	82.2	83.6	83.9	82.5	79.4	73.6	70.4	(6)
(7)		DBStd	7.33	7.39	6.40	5.72	4.14	3.04	2.56	2.21	2.11	2.23	3.78	5.02	6.76	(7)
(8)		HDD50	3	2	0	0	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD65	153	67	29	15	1	0	0	0	0	0	1	6	34	(9)
(10)		CDD50	9761	535	561	685	779	910	967	1042	1051	976	913	708	634	(10)
(11)		CDD65	4438	136	170	235	330	445	517	577	586	526	448	265	203	(11)
(12)		CDH74	40875	564	827	1353	2393	4073	5488	6710	6896	5722	4234	1632	983	(12)
(13)		CDH80	13279	38	108	251	545	1182	2007	2770	2880	2073	1138	212	75	(13)
(14)	Wind	WSAvg	8.1	8.0	8.2	9.2	9.6	9.2	7.4	6.8	6.9	7.1	8.7	8.2	8.1	(14)
(15)	Precipitation	PrecAvg	59.4	2.3	2.5	2.8	3.3	4.7	8.5	6.5	7.2	9.1	7.1	3.0	2.3	(15)
(16)		PrecMax	77.6	7.6	6.1	7.5	7.3	12.0	17.8	10.7	14.2	16.0	12.5	10.5	6.2	(16)
(17)		PrecMin	45.6	0.0	0.2	0.0	0.2	0.0	2.5	2.7	2.4	4.4	1.9	0.2	0.4	(17)
(18)		PrecStd	8.3	1.8	1.7	2.1	2.1	2.9	4.6	2.4	2.9	3.0	4.0	2.7	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.2	86.1	88.9	90.2	92.2	93.3	93.5	92.2	90.4	86.5	84.0	(19)	
(20)			MCWB	70.9	70.9	72.1	73.3	74.2	77.1	77.3	77.8	77.2	76.7	75.2	74.1	(20)
(21)		2%	DB	81.0	83.0	85.3	87.4	89.5	91.2	91.6	91.9	90.5	88.4	84.1	81.9	(21)
(22)			MCWB	70.4	71.1	70.9	72.7	74.2	77.1	77.5	77.9	77.4	76.3	74.5	72.5	(22)
(23)		5%	DB	79.2	81.1	82.4	85.1	87.7	89.9	90.6	90.8	89.5	86.9	82.2	80.7	(23)
(24)			MCWB	69.3	70.3	70.7	72.0	74.1	77.0	77.5	78.0	77.4	75.7	72.6	71.6	(24)
(25)		10%	DB	77.3	79.2	80.8	83.0	85.8	88.2	89.7	89.9	88.1	85.3	81.0	79.1	(25)
(26)			MCWB	68.4	69.3	69.9	71.1	73.5	76.5	77.5	78.0	77.1	75.1	71.6	70.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.3	75.3	75.9	77.7	78.4	80.2	80.7	81.0	80.9	80.2	77.6	76.0	(27)
(28)			MCD B	78.8	79.4	83.4	84.2	84.2	87.6	87.0	87.4	86.7	85.0	82.3	80.3	(28)
(29)		2%	WB	72.9	73.4	74.1	75.6	77.2	79.1	79.8	80.2	79.9	78.5	76.3	74.9	(29)
(30)			MCD B	77.7	79.0	80.8	82.1	84.0	86.4	86.7	87.0	85.9	83.9	81.3	79.4	(30)
(31)		5%	WB	71.4	72.3	73.1	74.5	76.3	78.3	79.0	79.5	79.1	77.7	75.3	73.8	(31)
(32)			MCD B	76.7	78.0	79.5	81.2	83.2	85.7	86.2	86.7	85.2	83.7	80.5	78.5	(32)
(33)		10%	WB	70.1	71.1	71.8	73.3	75.4	77.8	78.4	79.0	78.3	77.0	74.0	72.8	(33)
(34)			MCD B	75.8	77.0	78.5	80.3	82.5	85.1	85.7	86.2	84.7	83.1	79.3	77.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.6	14.9	14.9	13.9	12.9	12.3	12.5	12.5	11.8	11.6	13.1	13.5	(35)
(36)			MCD BR	14.3	14.6	15.7	15.7	15.2	13.9	13.4	13.4	12.7	12.4	12.2	12.1	(36)
(37)			MCWBR	7.3	6.1	6.4	6.4	5.7	5.0	4.7	4.7	4.4	4.6	5.5	6.3	(37)
(38)		5% WB	MCD BR	13.0	12.8	14.2	13.7	13.0	12.8	12.6	12.6	12.0	11.0	11.3	11.0	(38)
(39)			MCWBR	7.8	6.2	6.7	6.1	5.6	5.3	5.1	5.1	4.9	4.7	5.6	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.364	0.371	0.386	0.403	0.429	0.465	0.471	0.464	0.436	0.415	0.381	0.373	(40)
(41)		taud		2.518	2.513	2.455	2.394	2.360	2.315	2.294	2.337	2.417	2.443	2.490	2.510	(41)
(42)		Ebn at Noon		282	288	288	285	275	263	262	264	269	270	273	273	(42)
(43)		Edh at Noon		30	32	36	39	40	42	42	40	36	34	30	29	(43)
(44)	All-Sky Solar Radiation	RadAvg		1148	1399	1707	1948	1970	1806	1839	1770	1557	1435	1221	1061	(44)
(45)		RadStd		76	85	90	92	166	164	92	96	80	102	61	77	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+337	+326
(47)	Regional (28 neighbors)	+0.72	+1.60	N/A	N/A	N/A	N/A	N/A	-38	+247	+196

Nomenclature: See separate page