

SOUTH LAFOURCHE, LA, USA

WMO: 722041

Lat: 29.445N

Lon: 90.261W

Elev: 1

StdP: 14.70

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 12993

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.1	(c) 35.7	(d) 21.9	(e) 16.5	(f) 39.4	(g) 26.8	(h) 20.8	(i) 43.4	(j) 23.9	(k) 52.5	(l) 21.0	(m) 52.5	(n) 5.2	(o) 10	(p) 0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 15.9	(c) 93.3	(d) 78.7	(e) 91.4	(f) 78.5	(g) 90.7	(h) 78.3	(i) 82.5	(j) 87.9	(k) 81.3	(l) 86.9	(m) 80.5	(n) 86.6	(o) 6.2	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.4	163.4	84.7	80.2	156.7	84.2	78.9	150.2	83.7	46.5	86.0	44.8	87.3	43.9	88.4	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.1	(b) 17.8	(c) 15.9	(e) 27.1	(f) 96.5	(g) 4.0	(h) 1.9	(i) 24.3	(j) 97.9	(k) 22.0	(l) 99.0	(m) 19.7	(n) 100.1	(o) 16.9	(p) 101.5		
(4) 20.1	(5) 17.8	(6) 15.9	(7) 27.1	(8) 96.5	(9) 4.0	(10) 1.9	(11) 24.3	(12) 97.9	(13) 22.0	(14) 99.0	(15) 19.7	(16) 100.1	(17) 16.9	(18) 101.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.5	53.9	58.1	63.3	68.9	75.4	80.9	81.7	82.1	79.7	71.0	61.4	57.0		
	DBStd	12.10	9.49	9.04	8.04	6.16	4.84	2.90	2.43	3.32	3.68	7.32	8.43	9.14		
	HDD50	147	68	26	7	0	0	0	0	0	0	0	10	36		
	HDD65	1227	363	226	128	34	2	0	0	0	0	31	163	280		
	CDD50	7274	187	254	420	569	788	927	983	996	892	653	353	252		
	CDD65	2880	18	34	77	152	325	477	518	531	442	219	56	31		
	CDH74	28203	42	112	353	1051	3053	5408	5577	5917	4407	1888	294	101		
	CDH80	10501	0	3	17	121	907	2350	2355	2566	1669	489	23	1		
(14) Wind	WSAvg	6.2	7.8	8.0	7.5	7.5	6.1	5.0	4.1	4.0	4.2	5.9	6.3	7.5		
(15) Precipitation	PrecAvg	63.6	5.4	4.1	4.4	3.5	4.4	6.7	8.1	7.2	6.3	4.8	4.1	4.7		
	PrecMax	91.2	18.3	9.7	11.3	14.7	12.5	16.4	11.9	17.1	20.6	14.5	15.2	14.4		
	PrecMin	45.5	0.1	0.6	0.2	0.0	0.0	2.0	2.9	2.4	1.7	0.6	0.3	1.5		
	PrecStd	12.0	4.7	2.6	2.5	3.2	3.4	3.3	2.6	3.9	4.6	3.4	3.5	3.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	80.6	81.9	84.5	90.5	94.8	94.9	95.5	94.1	90.4	82.4	79.6		
		MCWB	71.1	71.2	71.2	73.2	75.0	80.1	79.2	79.3	77.7	76.9	72.3	72.3		
	2%	DB	74.9	77.5	80.2	82.5	88.4	91.6	92.1	93.8	91.3	87.6	80.1	77.1		
		MCWB	68.9	69.8	70.8	72.5	74.8	78.1	78.8	79.3	77.7	75.5	70.9	70.8		
	5%	DB	72.1	74.8	78.3	81.4	86.7	90.8	90.8	91.4	90.0	85.4	77.7	73.7		
		MCWB	66.8	68.5	70.1	71.8	74.6	77.8	78.7	79.2	77.4	74.3	69.2	68.3		
	10%	DB	69.0	72.5	75.6	79.7	85.2	89.9	89.9	90.5	88.3	82.4	74.7	71.3		
		MCWB	64.7	67.5	68.6	70.5	74.3	77.5	78.6	79.1	76.9	72.5	67.7	67.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.8	73.3	74.5	76.8	78.3	86.7	83.6	83.9	81.4	80.6	75.4	74.7		
		MCDB	76.4	78.5	78.6	80.9	84.7	91.0	88.4	88.7	86.9	85.7	79.6	78.4		
	2%	WB	70.4	71.3	73.0	75.3	77.4	83.4	81.4	82.3	80.3	78.5	73.2	71.6		
		MCDB	73.6	75.9	77.8	80.7	84.4	88.4	87.2	87.9	86.6	83.4	77.3	75.8		
	5%	WB	68.3	69.8	71.6	74.2	76.5	80.6	80.6	81.4	79.3	77.2	71.2	69.9		
		MCDB	71.0	73.7	76.5	79.4	83.5	86.1	86.8	87.0	86.2	82.5	75.6	73.2		
	10%	WB	65.0	68.0	70.1	73.0	75.6	79.0	79.8	80.7	78.4	75.4	69.4	67.8		
		MCDB	68.5	72.0	74.5	78.1	82.6	86.1	86.4	86.7	85.0	81.1	74.1	70.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.1	17.8	18.5	18.2	17.4	16.9	15.6	15.9	16.2	19.3	20.5	17.0		
		MCDBR	19.2	17.3	17.1	17.8	17.9	18.4	17.3	17.0	17.5	18.2	19.8	18.0		
		MCWBR	13.8	11.5	10.2	9.8	7.6	7.9	7.4	6.7	7.4	9.3	12.2	13.1		
	5% WB	MCDBR	16.2	15.2	15.3	14.9	15.3	16.2	15.4	15.6	15.1	15.2	19.0	16.8		
		MCWBR	12.9	11.4	10.4	9.5	7.2	8.4	7.9	7.4	7.3	9.2	13.7	13.1		
(40) Clear-Sky Solar Irradiance	taub		0.346	0.362	0.377	0.422	0.446	0.465	0.500	0.500	0.444	0.388	0.362	0.351		
	taud		2.520	2.494	2.435	2.310	2.281	2.274	2.201	2.197	2.321	2.469	2.481	2.521		
	Ebn at Noon		283	287	289	278	270	263	253	253	264	274	274	275		
	Edh at Noon		28	31	36	42	43	43	46	46	39	32	29	27		
(44) All-Sky Solar Radiation	RadAvg		975	1158	1562	1874	2057	1928	1786	1684	1627	1462	1117	872		
	RadStd		79	145	136	163	102	155	130	151	130	146	102	76		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+254	+173

Nomenclature: See separate page