

WOOD COUNTY AP, TX, USA

WMO: 722042

Lat: 32.742N

Lon: 95.496W

Elev: 434

StdP: 14.47

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53978

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	27.8	10.0	9.3	32.6	15.6	12.3	37.0	19.9	53.0	18.2	53.0	3.9	350	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.0	100.0	75.1	98.6	75.1	95.0	75.5	79.7	88.1	78.7	88.0	78.1	87.9	5.1	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.5	145.1	83.0	76.6	140.8	82.4	75.2	134.5	81.6	43.4	87.9	42.5	89.5	41.7	88.2	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.6	12.4	DB	18.6	101.9	4.5	3.6	15.3	104.5	12.7	106.5	10.2	108.6	6.9	111.2	(4)
(5)			WB	17.3	81.5	4.5	1.6	14.0	82.7	11.4	83.6	8.8	84.5	5.5	85.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.0	46.9	51.0	58.4	65.0	72.8	80.6	83.4	84.0	77.6	66.4	56.3	48.3
	DBStd	15.29	10.25	10.40	9.47	7.68	6.25	4.07	4.17	4.40	5.50	8.23	9.41	9.47
	HDD50	515	180	104	32	3	0	0	0	0	0	2	44	150
	HDD65	2220	566	402	246	92	15	0	0	0	1	85	288	525
	CDD50	6348	85	133	292	454	707	918	1036	1055	828	510	233	97
	CDD65	2577	6	11	41	93	256	468	571	590	378	128	28	7
	CDH74	28093	19	59	265	771	2287	5137	6910	7373	3915	1177	150	30
	CDH80	13300	0	4	31	150	767	2406	3628	4067	1858	371	17	1
Wind	WSAvg	4.5	5.2	5.5	5.7	5.7	4.7	4.2	3.8	3.6	3.0	3.9	4.6	4.8
Precipitation	PrecAvg	46.1	3.9	3.6	4.1	3.9	4.6	4.1	3.0	2.6	3.6	4.5	4.0	4.0
	PrecMax	65.8	9.8	8.5	8.6	9.4	8.5	9.1	7.7	7.8	10.0	16.4	11.2	7.3
	PrecMin	22.8	0.2	0.2	0.5	1.4	0.9	0.6	0.1	0.3	0.8	0.4	0.7	0.6
	PrecStd	10.9	2.4	2.2	2.0	2.0	2.2	2.6	2.2	1.7	2.3	3.5	2.6	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.8	79.5	82.3	88.1	92.7	99.2	102.0	105.8	99.5	90.6	82.1	77.4
		MCWB	61.8	61.1	65.5	71.3	74.4	75.3	75.8	75.2	72.6	71.0	69.4	65.0
	2%	DB	72.7	75.1	80.8	83.8	90.0	95.4	99.5	101.5	95.3	87.9	78.9	72.8
		MCWB	61.9	63.0	65.0	69.5	74.0	75.8	75.7	74.4	73.2	71.3	67.4	64.1
	5%	DB	69.9	72.3	77.1	81.3	87.7	92.8	97.2	99.0	92.6	84.0	74.8	69.9
		MCWB	61.7	62.8	63.9	68.0	73.5	75.2	76.0	75.1	73.3	70.2	65.8	62.9
	10%	DB	64.4	68.4	73.2	79.0	84.1	90.7	93.3	95.4	90.3	81.2	72.2	65.5
		MCWB	56.8	61.3	62.7	66.4	72.3	76.0	76.0	75.4	72.8	68.2	65.0	59.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.8	68.5	70.3	74.6	77.7	80.6	80.6	81.4	79.3	77.2	72.3	69.4
		MCDB	71.9	74.3	77.3	82.1	85.6	88.2	88.9	89.9	85.5	84.4	78.1	73.0
	2%	WB	65.8	66.8	68.3	72.6	76.2	79.1	79.4	79.6	78.0	75.3	70.4	67.0
		MCDB	70.5	71.9	75.1	80.1	84.5	87.8	88.4	88.4	86.0	82.1	75.7	71.8
	5%	WB	63.3	65.0	66.9	71.1	75.2	78.2	78.5	78.4	76.9	73.8	68.4	64.1
		MCDB	67.0	69.4	73.8	78.1	83.6	87.5	88.4	88.5	85.5	79.9	73.5	67.3
	10%	WB	58.8	62.6	65.3	69.3	74.1	77.4	78.0	77.7	75.8	72.0	66.0	60.5
		MCDB	63.6	67.3	71.7	76.0	81.9	87.0	88.4	88.6	84.5	77.9	71.0	64.4
Mean Daily Temperature Range	5% DB	MDBR	20.3	19.8	21.2	21.7	19.1	18.6	19.3	21.0	21.7	22.7	21.4	19.9
		MCDBR	25.0	23.5	22.5	22.1	21.1	21.0	22.4	24.6	24.6	24.0	22.0	24.1
		MCWBR	15.2	14.6	10.9	10.8	8.5	6.5	5.3	6.0	7.8	10.1	13.0	16.4
	5% WB	MCDBR	19.6	19.4	18.7	18.0	17.8	17.3	18.4	19.5	19.5	18.4	18.1	20.2
		MCWBR	15.5	15.0	11.6	10.9	8.6	7.0	6.5	6.4	7.2	10.0	13.3	16.6
Clear-Sky Solar Irradiance	taub	0.318	0.336	0.361	0.397	0.428	0.444	0.455	0.453	0.406	0.359	0.344	0.325	
	taud	2.495	2.457	2.406	2.315	2.284	2.278	2.287	2.281	2.367	2.475	2.465	2.486	
	Ebn at Noon	286	292	291	283	274	268	265	264	273	279	274	277	
	Edh at Noon	28	31	36	41	43	43	42	42	37	31	28	26	
All-Sky Solar Radiation	RadAvg	873	991	1368	1692	1833	2027	2062	1916	1611	1283	935	768	
	RadStd	81	158	119	109	143	185	143	139	145	181	120	100	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page