

WOOD COUNTY AP, TX, USA

WMO: 722042

Lat: 32.742N

Lon: 95.496W

Elev: 132

StdP: 99.75

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53978

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-2.3	-12.2	1.3	0.3	-9.1	1.8	2.8	8.9	11.7	8.1	11.7	1.7	350	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.7	37.8	23.9	37.0	24.0	35.0	24.2	26.5	31.2	25.9	31.1	25.6	31.1	2.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	20.7	28.3	24.8	20.1	28.0	24.0	19.2	27.6	83.1	31.1	81.0	31.9	79.2	31.2	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.5	5.5	-7.5	38.8	2.5	2.0	-9.3	40.3	-10.7	41.4	-12.1	42.5	-13.9	44.0		
(5)			-8.2	27.5	2.5	0.9	-10.0	28.2	-11.5	28.7	-12.9	29.2	-14.7	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	8.3	10.6	14.7	18.4	22.7	27.0	28.6	28.9	25.3	19.1	13.5	9.1
	DBStd	8.50	5.69	5.78	5.26	4.27	3.47	2.26	2.32	2.45	3.06	4.57	5.23	5.26
	HDD10.0	286	100	58	18	2	0	0	0	0	0	1	24	83
	HDD18.3	1233	314	223	137	51	8	0	0	0	1	47	160	292
	CDD10.0	3527	47	74	162	252	393	510	576	586	460	283	129	54
	CDD18.3	1432	3	6	23	52	142	260	317	328	210	71	16	4
	CDH23.3	15607	11	33	147	428	1271	2854	3839	4096	2175	654	83	17
	CDH26.7	7389	0	2	17	83	426	1337	2016	2259	1032	206	9	1
Wind	WSAvg	2.0	2.3	2.5	2.5	2.5	2.1	1.9	1.7	1.6	1.3	1.7	2.1	2.1
Precipitation	PrecAvg	1172	99	91	104	98	118	105	77	67	91	114	102	101
	PrecMax	1672	250	216	218	239	215	230	195	198	255	416	284	185
	PrecMin	579	5	4	13	36	24	14	3	8	20	11	19	15
	PrecStd	278	60	56	52	50	56	66	55	44	59	89	65	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	26.4	28.0	31.2	33.7	37.4	38.9	41.0	37.5	32.6	27.8	25.2
		MCWB	16.6	16.2	18.6	21.8	23.5	24.1	24.3	24.0	22.6	21.7	20.8	18.3
	2%	DB	22.6	24.0	27.1	28.8	32.2	35.2	37.5	38.6	35.2	31.1	26.0	22.6
		MCWB	16.6	17.2	18.3	20.8	23.3	24.3	24.3	23.6	22.9	21.8	19.7	17.8
	5%	DB	21.1	22.4	25.0	27.4	30.9	33.8	36.2	37.2	33.7	28.9	23.8	21.0
		MCWB	16.5	17.1	17.7	20.0	23.0	24.0	24.4	23.9	22.9	21.2	18.8	17.2
	10%	DB	18.0	20.2	22.9	26.1	28.9	32.6	34.1	35.2	32.4	27.4	22.3	18.6
		MCWB	13.8	16.3	17.0	19.1	22.4	24.5	24.4	24.1	22.7	20.1	18.3	15.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.9	20.3	21.3	23.6	25.4	27.0	27.0	27.4	26.3	25.1	22.4	20.8
		MCDB	22.1	23.5	25.2	27.9	29.8	31.2	31.6	32.2	29.7	29.1	25.6	22.8
	2%	WB	18.8	19.3	20.2	22.5	24.6	26.2	26.3	26.5	25.5	24.1	21.3	19.4
		MCDB	21.4	22.2	24.0	26.7	29.2	31.0	31.3	31.3	30.0	27.9	24.3	22.1
	5%	WB	17.4	18.3	19.4	21.7	24.0	25.7	25.8	25.8	24.9	23.2	20.2	17.9
		MCDB	19.4	20.8	23.2	25.6	28.6	30.8	31.3	31.4	29.7	26.6	23.0	19.6
	10%	WB	14.9	17.0	18.5	20.7	23.4	25.2	25.5	25.4	24.3	22.2	18.9	15.8
		MCDB	17.6	19.6	22.0	24.4	27.7	30.6	31.3	31.5	29.1	25.5	21.7	18.0
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.0	11.8	12.0	10.6	10.4	10.7	11.7	12.1	12.6	11.9	11.1
		MCDBR	13.9	13.1	12.5	12.3	11.7	11.7	12.4	13.7	13.7	13.4	12.2	13.4
		MCWBR	8.5	8.1	6.1	6.0	4.7	3.6	3.0	3.3	4.3	5.6	7.2	9.1
	5% WB	MCDBR	10.9	10.8	10.4	10.0	9.9	9.6	10.2	10.8	10.9	10.2	10.0	11.2
		MCWBR	8.6	8.3	6.4	6.0	4.8	3.9	3.6	3.6	4.0	5.6	7.4	9.2
Clear-Sky Solar Irradiance	taub	0.318	0.336	0.361	0.397	0.428	0.444	0.455	0.453	0.406	0.359	0.344	0.325	
	taud	2.495	2.457	2.406	2.315	2.284	2.278	2.287	2.281	2.367	2.475	2.465	2.486	
	Ebn at Noon	902	919	917	893	863	845	834	831	860	881	863	872	
	Edh at Noon	87	99	113	129	134	135	133	132	116	97	89	83	
All-Sky Solar Radiation	RadAvg	2.75	3.12	4.31	5.33	5.78	6.39	6.50	6.04	5.08	4.04	2.95	2.42	
	RadStd	0.26	0.50	0.38	0.34	0.45	0.58	0.45	0.44	0.46	0.57	0.38	0.32	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page