

POMPANO BEACH, FL, USA

WMO: 722049

Lat: 26.250N

Lon: 80.108W

Elev: 6

StdP: 101.25

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 92805

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.0	(c) 10.3	(d) -1.8	(e) 3.3	(f) 14.1	(g) 1.2	(h) 4.1	(i) 14.2	(j) 11.0	(k) 20.6	(l) 10.1	(m) 20.6	(n) 4.2	(o) 330	(p) 0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.9	(c) 32.8	(d) 25.5	(e) 32.3	(f) 25.7	(g) 31.9	(h) 25.7	(i) 27.0	(j) 30.7	(k) 26.7	(l) 30.5	(m) 26.4	(n) 30.2	(o) 5.4	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	28.9	25.7	21.0	28.9	25.2	20.3	28.8	84.8	30.8	83.1	30.3	81.7	30.1	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.5	8.7	8.0	4.5	35.6	1.8	2.4	3.2	37.3	2.2	38.6	1.2	40.0	-0.1	41.7
			1.7	27.6	2.0	0.6	0.3	28.1	-0.9	28.4	-2.0	28.7	-3.4	29.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	19.7	21.1	22.3	24.3	26.1	27.8	28.6	28.8	28.1	26.4	23.3	21.6		
	DBStd	4.03	4.15	3.62	3.10	2.22	1.53	1.40	1.28	1.09	1.33	2.15	2.88	3.86		
	HDD10.0	2	1	0	0	0	0	0	0	0	0	0	0	1		
	HDD18.3	85	37	17	8	1	0	0	0	0	0	1	4	18		
	CDD10.0	5427	301	312	381	430	501	536	577	582	542	507	399	359		
	CDD18.3	2468	79	94	131	181	242	286	319	323	292	249	153	119		
	CDH23.3	22987	283	415	672	1217	2173	3139	3814	3934	3309	2436	994	599		
	CDH26.7	7081	11	37	91	205	508	1094	1562	1624	1189	612	111	37		
(14) Wind	WSAvg	4.2	4.5	4.4	4.8	4.8	4.4	3.7	3.4	3.5	3.6	4.6	4.6	4.5		
(15) Precipitation	PrecAvg	1498	61	62	75	82	126	219	167	188	219	163	77	59		
	PrecMax	1959	200	154	193	179	300	456	266	373	401	290	262	156		
	PrecMin	1178	5	8	2	5	6	78	77	77	123	35	6	15		
	PrecStd	209	48	41	54	51	73	111	58	72	68	95	66	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	29.3	31.0	31.6	32.5	33.6	33.8	33.3	33.6	32.1	29.8	28.7		
		MCWB	22.5	21.8	22.6	22.8	23.4	25.5	25.3	25.8	25.3	25.0	24.3	23.6		
	2%	DB	26.6	27.7	28.7	29.7	30.7	32.3	32.5	32.5	32.2	30.9	28.7	27.5		
		MCWB	21.8	22.3	22.7	23.0	24.0	25.7	25.8	25.9	25.6	25.0	23.8	22.8		
	5%	DB	26.0	26.7	27.5	28.7	29.9	31.5	32.1	32.2	31.4	30.1	27.8	27.0		
		MCWB	21.4	21.8	22.2	22.8	23.8	25.5	25.8	26.0	25.6	24.6	23.1	22.5		
	10%	DB	25.0	25.9	26.6	27.7	29.1	30.9	31.4	31.6	30.9	29.2	27.2	26.2		
		MCWB	20.8	21.4	21.4	22.0	23.4	25.3	25.6	25.8	25.4	24.3	22.6	22.1		
	0.4%	WB	23.9	24.1	25.4	25.2	25.8	27.3	27.3	27.4	27.4	26.8	26.1	24.7		
		MCDB	26.1	26.9	28.1	28.7	29.2	31.6	31.4	31.1	30.7	29.3	27.9	26.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	23.0	23.4	24.0	24.4	25.2	26.7	26.8	26.9	26.9	26.1	24.9	24.1		
		MCDB	25.5	26.2	27.1	27.7	28.6	30.7	31.0	30.8	30.3	28.8	27.6	26.3		
	5%	WB	22.4	22.8	23.3	23.9	24.7	26.2	26.4	26.7	26.5	25.7	24.2	23.6		
		MCDB	24.9	25.6	26.3	27.1	28.2	30.0	30.7	30.7	29.9	28.6	27.0	26.0		
	10%	WB	21.6	22.2	22.5	23.2	24.3	25.7	26.0	26.3	26.0	25.3	23.6	22.9		
		MCDB	24.2	24.9	25.7	26.7	27.8	29.5	30.2	30.4	29.4	28.4	26.5	25.5		
	5% DB	MDBR	7.8	7.4	7.3	6.6	6.0	5.8	5.9	5.9	5.6	5.5	6.6	6.8		
		MCDBR	6.6	7.0	7.6	7.5	6.8	6.5	6.3	6.3	6.1	5.8	5.9	5.6		
		MCWBR	3.8	3.4	3.8	3.7	3.1	2.9	3.1	2.9	2.5	2.7	3.0	3.1		
		MCWBR	6.2	6.1	7.1	6.6	6.1	6.1	5.9	5.8	5.6	5.4	5.2	5.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	4.2	3.3	4.0	3.8	3.1	3.1	3.2	3.1	2.7	2.9	3.1	3.3		
		MCWBR	4.2	3.3	4.0	3.8	3.1	3.1	3.2	3.1	2.7	2.9	3.1	3.3		
	Clear-Sky Solar Irradiance	taub	0.363	0.372	0.387	0.404	0.430	0.465	0.471	0.465	0.436	0.416	0.381	0.372		
		taud	2.518	2.510	2.452	2.393	2.359	2.316	2.294	2.336	2.418	2.441	2.490	2.511		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	888	907	909	896	867	831	825	831	850	850	861	861		
		Edh at Noon	93	101	112	122	126	131	133	127	115	106	95	91		
(44) All-Sky Solar Radiation	RadStd	RadAvg	3.61	4.41	5.38	6.15	6.23	5.73	5.82	5.61	4.92	4.53	3.84	3.34		
		RadStd	0.24	0.27	0.29	0.29	0.53	0.52	0.30	0.31	0.26	0.33	0.19	0.24		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	+1.55	+1.70	+0.46	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)		+0.38	+0.86	N/A	N/A	N/A	N/A	-21	+130	+102	

Nomenclature: See separate page