

OCALA, FL, USA

WMO: 722055

Lat: 29.167N

Lon: 82.233W

Elev: 87

StdP: 14.65

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12861

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.6	34.0	16.5	12.7	40.7	20.7	15.6	43.7	20.4	68.2	18.6	66.5	1.9	0	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.3	93.1	75.6	91.4	75.7	90.6	75.5	79.4	87.7	78.5	87.0	77.9	86.5	6.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	142.5	82.8	76.3	137.7	82.2	75.3	133.2	81.6	42.9	87.5	42.0	87.4	41.2	86.8	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.0	15.4	12.6	22.4	97.2	3.4	1.6	19.9	98.3	17.9	99.2	16.0	100.1	13.5	101.2		
			21.1	80.6	3.3	1.4	18.7	81.7	16.8	82.5	15.0	83.3	12.6	84.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.0	56.1	59.5	63.2	68.6	75.6	79.8	81.0	81.0	79.2	72.7	63.8	58.8
	DBStd	11.04	9.52	8.85	7.65	6.03	4.08	2.95	1.99	1.99	2.89	6.69	7.34	9.06
	HDD50	108	50	21	7	0	0	0	0	0	0	0	4	26
	HDD65	1011	301	191	124	35	1	0	0	0	0	22	106	231
	CDD50	7405	238	289	415	558	793	895	961	960	876	704	416	300
	CDD65	2832	24	38	67	143	328	445	496	495	426	261	69	40
	CDH74	24735	155	309	652	1414	3327	3912	4356	4355	3530	1988	505	232
	CDH80	9510	9	46	116	391	1418	1731	1839	1835	1421	614	74	16
Wind	WSAvg	4.8	5.4	5.5	5.8	5.4	5.0	4.4	3.8	3.8	4.4	4.6	4.6	4.9
Precipitation	PrecAvg	49.9	2.8	2.7	4.0	2.5	2.6	8.0	6.7	6.3	6.6	3.9	1.7	2.5
	PrecMax	65.9	8.3	9.7	8.4	6.7	7.9	12.3	10.8	10.6	19.3	8.1	4.4	9.1
	PrecMin	30.8	0.3	0.4	0.0	0.9	0.3	1.4	4.0	3.3	1.5	0.6	0.4	0.4
	PrecStd	8.7	2.0	2.4	2.4	1.5	1.8	2.6	1.6	1.9	4.2	2.1	1.1	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	84.1	86.2	89.8	93.4	97.1	93.5	93.5	92.7	90.6	84.5	81.8
		MCWB	67.7	69.5	70.0	69.8	71.9	75.6	77.2	77.2	75.3	75.9	72.5	69.8
	2%	DB	78.8	81.4	82.8	86.8	91.3	93.2	92.2	92.0	90.9	88.3	82.0	79.9
		MCWB	66.3	67.5	67.5	69.2	71.9	75.1	77.0	77.1	75.6	74.7	69.6	68.4
	5%	DB	75.0	78.7	81.1	84.2	90.1	91.0	90.7	90.7	89.9	86.0	80.0	76.8
		MCWB	64.5	65.9	65.7	68.1	71.1	75.3	77.0	77.1	75.6	73.8	67.8	66.9
	10%	DB	72.1	74.1	78.6	81.9	87.9	89.7	89.6	89.6	88.1	83.6	77.0	72.8
		MCWB	63.7	63.2	64.1	66.7	70.8	75.2	77.0	77.2	75.3	72.4	66.1	65.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.5	71.4	72.9	73.5	76.6	79.8	80.4	81.1	79.5	78.3	74.4	73.0
		MCDB	77.0	79.7	79.9	82.2	86.7	89.2	88.2	87.7	87.2	85.7	81.4	77.7
	2%	WB	68.6	69.6	70.3	72.1	75.2	78.2	79.2	79.5	78.2	77.0	72.5	70.5
		MCDB	75.0	77.8	78.6	81.7	85.3	87.8	87.6	87.4	86.4	84.2	79.1	75.9
	5%	WB	66.8	67.9	68.7	70.7	74.0	77.3	78.3	78.5	77.3	75.7	70.3	68.9
		MCDB	72.5	75.7	76.9	80.3	84.0	86.5	87.0	86.7	85.7	82.5	76.5	74.3
	10%	WB	64.7	66.0	66.8	69.2	72.9	76.4	77.6	77.9	76.5	74.5	68.6	66.9
		MCDB	70.3	72.7	74.6	78.4	82.9	85.3	86.5	86.3	84.5	80.6	74.8	72.3
Mean Daily Temperature Range	5% DB	MDBR	24.1	24.1	24.7	24.9	23.7	18.7	17.5	17.3	17.6	20.2	23.1	22.3
		MCDBR	24.2	25.1	26.6	26.0	26.3	22.0	19.4	19.5	19.9	19.7	23.3	22.1
		MCWBR	14.5	12.7	12.8	11.2	9.5	7.7	7.5	7.5	7.7	8.5	13.0	12.8
	5% WB	MCDBR	20.3	21.7	21.4	22.1	21.5	18.5	17.5	17.1	16.9	16.5	19.5	19.1
	MCWBR	13.2	12.2	12.0	10.9	8.6	7.5	7.6	7.2	7.0	7.6	12.1	12.7	
Clear-Sky Solar Irradiance	taub	0.336	0.350	0.365	0.387	0.426	0.456	0.493	0.470	0.422	0.391	0.352	0.339	
	taud	2.519	2.484	2.441	2.360	2.301	2.288	2.282	2.182	2.264	2.384	2.437	2.494	2.530
	Ebn at Noon	287	292	293	288	276	266	255	261	271	273	278	280	
	Edh at Noon	28	32	35	40	42	43	47	43	37	33	29	27	
All-Sky Solar Radiation	RadAvg	1062	1264	1627	1953	2063	1850	1772	1701	1546	1408	1154	969	
	RadStd	75	109	137	118	131	137	123	115	115	103	64	82	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (44 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-11	-94	+286	+207	

Nomenclature: See separate page