

JACKSONVILLE INTL, FL, USA

WMO: 722060

Lat: 30.4839N

Lon: 81.7011W

Elev: 36

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13889

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.6	32.8	16.3	12.5	39.2	20.9	15.7	41.3	23.4	56.4	20.6	57.8	3.8	310	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	94.5	77.0	92.6	76.8	90.9	76.4	79.9	89.0	79.1	87.8	78.4	86.6	7.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	143.3	82.8	76.9	140.4	82.3	76.2	137.1	81.8	43.2	88.8	42.4	87.9	41.7	86.9	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.1	17.9	16.1	23.9	97.7	2.9	2.3	21.8	99.4	20.1	100.7	18.5	101.9	16.4	103.6		
			21.6	81.8	3.1	1.1	19.4	82.7	17.5	83.3	15.8	83.9	13.5	84.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	68.9	53.6	57.2	61.8	67.8	74.4	79.8	81.8	81.5	78.2	70.9	61.8	56.7	(6)
(7)		DBStd	11.90	9.35	8.77	7.92	6.30	4.97	3.36	2.43	2.41	3.40	6.54	7.79	9.19	(7)
(8)		HDD50	157	72	29	9	0	0	0	0	0	0	7	40		(8)
(9)		HDD65	1268	366	242	154	45	3	0	0	0	26	148	284		(9)
(10)		CDD50	7040	183	231	376	533	757	893	987	976	847	647	362	248	(10)
(11)		CDD65	2676	12	24	55	128	296	443	522	511	397	208	53	27	(11)
(12)		CDH74	23223	77	165	442	1087	2658	3966	5021	4793	3167	1401	312	134	(12)
(13)		CDH80	8739	3	16	72	276	984	1688	2234	1986	1109	325	38	8	(13)
(14)	Wind	WSAvg	6.6	6.8	7.2	7.7	7.5	7.0	6.2	5.7	5.7	6.2	6.2	6.2	6.3	(14)
(15)	Precipitation	PrecAvg	50.3	3.1	2.7	3.3	2.6	2.9	6.8	6.1	6.6	7.2	4.5	2.0	2.5	(15)
(16)		PrecMax	72.2	8.1	9.4	8.9	7.4	12.5	20.3	14.0	15.4	14.0	10.9	4.8	8.7	(16)
(17)		PrecMin	29.2	0.3	0.6	0.4	0.6	0.5	2.0	2.0	2.4	2.9	0.2	0.0	0.4	(17)
(18)		PrecStd	10.2	2.0	1.9	2.0	1.7	2.6	3.8	2.5	3.2	3.2	3.2	1.3	2.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.9	82.4	85.3	89.1	94.1	97.0	97.0	96.0	92.8	88.5	83.9	81.2	(19)
(20)		0.4%	MCWB	67.9	68.0	68.0	70.6	73.4	76.9	77.5	77.7	75.7	75.3	72.5	71.0	(20)
(21)		2%	DB	76.2	79.0	82.1	86.1	91.1	94.0	94.2	93.4	90.0	85.8	80.5	77.8	(21)
(22)		2%	MCWB	66.3	66.7	67.2	69.5	72.4	76.6	77.6	78.1	75.7	74.2	70.0	68.8	(22)
(23)		5%	DB	72.5	75.5	79.1	83.3	88.4	91.3	92.3	91.3	88.1	83.7	77.7	74.5	(23)
(24)		5%	MCWB	64.0	64.6	65.5	68.7	72.0	76.3	77.5	77.7	75.6	72.8	68.2	67.3	(24)
(25)		10%	DB	68.7	71.6	75.9	80.5	85.6	88.7	90.2	89.3	86.2	81.4	74.7	70.9	(25)
(26)		10%	MCWB	62.4	62.6	63.8	67.1	71.4	75.8	77.3	77.5	75.3	71.9	66.9	65.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	70.3	72.2	74.1	77.0	80.2	80.8	81.0	79.5	78.3	75.2	72.7	(27)
(28)		0.4%	MCDWB	75.8	77.6	79.6	82.7	87.0	90.9	90.9	90.1	85.5	83.6	80.7	77.8	(28)
(29)		2%	WB	68.2	68.7	69.8	72.4	75.5	78.8	79.7	80.0	78.4	76.9	72.7	70.7	(29)
(30)		2%	MCDWB	73.4	75.7	77.4	80.8	84.4	88.6	89.3	88.9	84.6	82.3	77.0	75.3	(30)
(31)		5%	WB	65.9	66.9	68.2	71.1	74.6	77.9	78.9	79.1	77.7	75.7	70.7	68.8	(31)
(32)		5%	MCDWB	71.0	73.1	75.2	79.1	83.2	87.0	88.0	87.7	84.1	80.6	74.9	72.9	(32)
(33)		10%	WB	63.6	64.8	66.3	69.6	73.4	77.0	78.2	78.3	77.0	74.3	68.9	66.5	(33)
(34)		10%	MCDWB	68.0	70.0	72.8	77.0	81.7	85.4	86.9	86.2	83.2	79.0	73.3	70.4	(34)
(35)	Mean Daily Temperature Range		MDBR	21.9	22.0	22.7	22.7	21.2	18.1	17.8	16.5	15.7	18.5	21.3	20.7	(35)
(36)		5% DB	MCDDBR	23.8	23.7	24.7	24.4	23.9	21.6	20.3	19.1	18.2	18.5	21.6	21.1	(36)
(37)			MCWBR	14.4	12.5	11.6	10.2	8.5	7.6	6.9	6.6	6.7	8.4	11.7	12.5	(37)
(38)			MCDDBR	20.5	20.6	20.6	20.7	19.9	18.7	18.2	17.1	15.1	14.7	17.5	18.4	(38)
(39)		5% WB	MCWBR	13.7	12.3	11.1	10.2	8.1	7.4	7.0	6.7	6.4	7.2	10.7	12.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.347	0.372	0.395	0.437	0.482	0.510	0.493	0.429	0.399	0.359	0.345	(40)	
(41)		taud	2.528	2.502	2.442	2.366	2.283	2.220	2.147	2.198	2.377	2.426	2.488	2.528	(41)	
(42)		Ebn at Noon	284	291	290	285	272	259	251	254	268	269	273	275	(42)	
(43)		Edh at Noon	28	31	35	39	43	45	49	46	37	33	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	982	1177	1539	1882	2029	1892	1887	1750	1506	1328	1074	881	(44)	
(45)		RadStd	69	137	141	119	120	121	122	111	125	116	62	75	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	N/A	N/A	N/A	-34	-119	+236	+167
(47)	Regional (35 neighbors)	+0.81	+1.37	N/A	N/A	N/A	N/A	-25	-122	+297	+211

Nomenclature: See separate page