

JACKSONVILLE INTL, FL, USA

WMO: 722060

Lat: 30.4839N

Lon: 81.7011W

Elev: 11

StdP: 101.19

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13889

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.4	0.5	-8.7	1.8	4.0	-6.2	2.2	5.2	10.5	13.5	9.2	14.3	1.7	310	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	34.7	25.0	33.7	24.9	32.7	24.7	26.6	31.7	26.2	31.0	25.8	30.3	3.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.3	20.5	28.2	25.0	20.1	28.0	24.6	19.6	27.7	82.5	31.6	80.8	31.0	79.1	30.5	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.0	8.0	7.2	-4.5	36.5	1.6	1.3	-5.6	37.4	-6.6	38.2	-7.5	38.9	-8.7	39.8		
			-5.8	27.7	1.7	0.6	-7.0	28.1	-8.0	28.5	-9.0	28.9	-10.3	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	12.0	14.0	16.6	19.9	23.6	26.5	27.7	27.5	25.7	21.6	16.6	13.7
	DBStd	6.61	5.19	4.87	4.40	3.50	2.76	1.87	1.35	1.34	1.89	3.64	4.33	5.11
	HDD10.0	87	40	16	5	0	0	0	0	0	0	0	4	22
	HDD18.3	704	203	134	86	25	2	0	0	0	0	14	82	158
	CDD10.0	3911	102	128	209	296	421	496	548	542	471	359	201	138
	CDD18.3	1487	7	13	31	71	164	246	290	284	221	116	29	15
	CDH23.3	12902	43	92	246	604	1477	2203	2789	2663	1759	778	173	74
CDH26.7	4855	2	9	40	153	547	938	1241	1103	616	181	21	4	
Wind	WSAvg	2.9	3.1	3.2	3.4	3.3	3.1	2.8	2.6	2.5	2.8	2.8	2.8	2.8
Precipitation	PrecAvg	1278	78	69	83	67	73	173	154	168	184	115	50	63
	PrecMax	1835	205	240	225	187	317	515	356	392	356	278	121	221
	PrecMin	742	8	16	11	15	12	50	52	60	73	6	1	10
	PrecStd	259	51	48	51	42	67	96	63	82	82	82	32	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.6	28.0	29.6	31.7	34.5	36.1	36.1	35.5	33.8	31.4	28.9	27.3
		MCWB	19.9	20.0	20.0	21.4	23.0	24.9	25.3	25.4	24.3	24.1	22.5	21.6
	2%	DB	24.6	26.1	27.8	30.0	32.8	34.5	34.6	34.1	32.2	29.9	27.0	25.5
		MCWB	19.1	19.3	19.5	20.8	22.5	24.8	25.3	25.6	24.3	23.5	21.1	20.4
	5%	DB	22.5	24.2	26.2	28.5	31.3	33.0	33.5	33.0	31.2	28.7	25.4	23.6
		MCWB	17.8	18.1	18.6	20.4	22.2	24.6	25.3	25.4	24.2	22.7	20.1	19.6
	10%	DB	20.4	22.0	24.4	26.9	29.8	31.5	32.3	31.8	30.1	27.5	23.7	21.6
		MCWB	16.9	17.0	17.7	19.5	21.9	24.4	25.2	25.3	24.0	22.2	19.4	18.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	21.3	22.3	23.4	25.0	26.8	27.1	27.2	26.4	25.7	24.0	22.6
		MCDB	24.3	25.3	26.5	28.2	30.6	32.7	32.7	32.3	29.7	28.7	27.1	25.5
	2%	WB	20.1	20.4	21.0	22.5	24.2	26.0	26.5	26.6	25.8	25.0	22.6	21.5
		MCDB	23.0	24.3	25.2	27.1	29.1	31.4	31.8	31.6	29.2	28.0	25.0	24.0
	5%	WB	18.9	19.4	20.1	21.7	23.6	25.5	26.1	26.2	25.4	24.3	21.5	20.4
		MCDB	21.6	22.8	24.0	26.1	28.5	30.6	31.1	30.9	29.0	27.0	23.8	22.7
	10%	WB	17.6	18.2	19.1	20.9	23.0	25.0	25.7	25.7	25.0	23.5	20.5	19.2
		MCDB	20.0	21.1	22.7	25.0	27.6	29.7	30.5	30.1	28.4	26.1	22.9	21.3
Mean Daily Temperature Range	5% DB	MDBR	12.2	12.2	12.6	12.6	11.8	10.1	9.9	9.2	8.7	10.3	11.8	11.5
		MCDBR	13.2	13.2	13.7	13.5	13.3	12.0	11.3	10.6	10.1	10.3	12.0	11.7
		MCWBR	8.0	7.0	6.5	5.7	4.7	4.2	3.8	3.7	3.7	4.7	6.5	6.9
	5% WB	MCDBR	11.4	11.5	11.4	11.5	11.1	10.4	10.1	9.5	8.4	8.2	9.7	10.2
MCWBR		7.6	6.8	6.2	5.6	4.5	4.1	3.9	3.7	3.6	4.0	5.9	6.7	
Clear-Sky Solar Irradiance	taub	0.336	0.347	0.372	0.395	0.437	0.482	0.510	0.493	0.429	0.399	0.359	0.345	
	taud	2.528	2.502	2.442	2.366	2.283	2.220	2.147	2.198	2.377	2.426	2.488	2.528	
	Ebn at Noon	896	918	913	899	858	815	791	801	845	849	861	866	
	Edh at Noon	87	97	110	123	135	143	154	144	117	104	90	84	
All-Sky Solar Radiation	RadAvg	3.10	3.71	4.85	5.93	6.40	5.97	5.95	5.52	4.75	4.19	3.38	2.78	
	RadStd	0.22	0.43	0.45	0.37	0.38	0.38	0.38	0.35	0.39	0.37	0.20	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.43	N/A	N/A	N/A	N/A	N/A	-19	-66	+131	+93
(47)	Regional (35 neighbors)	+0.45	+0.76	N/A	N/A	N/A	N/A	-14	-68	+165	+117

Nomenclature: See separate page