

DOUGLAS, GA, USA

WMO: 722062

Lat: 31.477N

Lon: 82.861W

Elev: 257

StdP: 14.56

Time Zone: -5.00 (NAE)

Period: 04-19

WBAN: 63842

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.7	33.0	9.1	8.9	41.4	13.9	11.2	44.5	20.0	63.5	17.0	55.0	3.4	340	0.349

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	97.2	75.4	95.0	75.4	92.9	74.9	81.5	87.6	79.5	87.9	78.3	87.0	6.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	160.3	85.5	77.4	144.0	82.4	75.5	134.8	81.2	45.4	88.7	43.2	88.2	41.8	88.1	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.8	14.4	12.2	DB	25.2	99.0	3.7	2.1	22.5	100.5	20.3	101.7	18.2	102.9	15.5	104.4
			WB	21.9	81.3	3.3	1.8	19.5	82.6	17.6	83.7	15.8	84.7	13.4	86.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.6	52.0	55.5	60.8	67.9	75.3	81.2	83.0	82.7	78.9	70.1	60.0	55.5
	DBStd	12.90	9.53	8.67	8.30	6.19	4.94	3.34	2.69	2.71	3.86	7.08	7.65	8.97
	HDD50	201	93	39	14	0	0	0	0	0	0	0	10	45
	HDD65	1455	412	281	179	42	3	0	0	0	0	0	187	314
	CDD50	7007	154	194	350	537	783	935	1022	1014	868	624	309	217
	CDD65	2782	8	16	50	128	320	485	557	549	418	195	35	21
	CDH74	26908	39	106	444	1283	3000	4953	5960	5519	3751	1512	249	92
(13)	CDH80	11723	0	7	87	370	1249	2420	2923	2579	1603	453	27	5
(14)	Wind	WSAvg	4.6	5.1	5.0	5.3	5.1	4.7	4.2	3.6	4.6	4.5	4.6	4.7
(15) Precipitation	PrecAvg	50.3	4.8	3.7	4.9	2.4	2.4	6.1	5.9	5.7	4.8	3.6	2.4	3.0
	PrecMax	64.5	15.9	7.5	10.7	5.2	5.9	10.6	8.6	8.4	16.2	10.3	6.3	5.9
	PrecMin	34.0	0.8	0.9	0.2	0.1	0.4	1.8	2.0	3.0	0.8	0.5	0.3	0.8
	PrecStd	8.8	3.3	1.7	2.9	1.4	1.4	2.3	1.4	1.4	3.5	2.9	1.7	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	81.2	86.0	90.2	94.4	99.4	98.9	99.4	95.7	90.4	82.5	81.0
		MCWB	66.6	65.9	65.0	67.2	71.1	74.8	76.4	77.0	74.1	72.3	68.4	68.5
	2%	DB	74.4	77.4	82.1	87.7	91.2	96.9	96.8	96.9	92.6	87.9	80.7	76.8
		MCWB	64.4	64.0	65.1	66.6	69.2	74.1	76.3	76.4	73.1	70.7	66.1	66.2
	5%	DB	71.6	73.2	79.3	84.1	90.0	93.5	94.6	93.4	90.6	84.4	77.1	72.9
		MCWB	63.0	61.9	63.8	65.4	68.9	73.6	76.5	76.4	73.4	69.3	64.4	66.0
	10%	DB	66.4	70.3	75.2	81.5	87.6	91.1	92.0	91.0	88.6	81.9	73.2	70.3
		MCWB	61.2	60.9	61.7	64.1	69.3	74.5	76.3	76.4	73.3	68.1	63.2	65.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.4	69.6	70.2	72.4	75.4	84.2	85.3	81.6	78.9	77.4	74.0	72.1
		MCDB	72.5	74.4	78.3	80.3	84.7	90.3	91.9	89.8	88.0	83.3	80.1	76.3
	2%	WB	67.0	67.4	68.8	70.9	74.3	81.1	82.4	80.1	77.7	75.5	71.6	69.7
		MCDB	72.3	73.5	76.7	79.9	83.2	85.7	88.2	89.0	86.4	81.3	75.5	72.9
	5%	WB	64.9	65.2	67.1	69.4	73.2	78.2	79.9	78.9	76.7	74.1	68.9	67.7
		MCDB	68.9	72.1	74.5	77.6	81.9	86.0	88.0	88.0	84.9	79.6	73.6	72.0
	10%	WB	62.6	63.0	65.2	68.0	72.2	76.7	78.3	78.0	75.7	72.6	65.9	65.4
		MCDB	66.0	67.3	71.9	76.2	80.9	86.0	87.3	86.9	83.5	78.2	72.1	69.8
(35) Mean Daily Temperature Range	5% DB	MDBR	20.2	21.0	22.4	23.1	21.4	19.3	18.9	17.9	18.4	21.2	22.4	19.9
		MCDBR	22.2	23.8	25.3	26.3	24.3	22.7	21.2	21.0	21.2	22.6	24.5	21.2
		MCWBR	13.9	13.2	10.8	9.0	6.8	6.5	6.0	5.8	6.3	8.7	12.0	13.1
	5% WB	MCDBR	18.6	19.9	20.3	21.1	18.2	18.7	18.3	17.7	16.7	15.7	17.1	17.8
		MCWBR	14.1	13.5	11.0	10.3	6.6	8.0	7.8	6.2	5.9	7.9	11.7	13.5
(40) Clear-Sky Solar Irradiance	taub		0.325	0.332	0.366	0.387	0.428	0.476	0.510	0.503	0.425	0.377	0.347	0.329
	taud		2.512	2.493	2.417	2.350	2.273	2.205	2.110	2.131	2.341	2.445	2.478	2.526
	Ebn at Noon		286	295	291	287	274	260	251	251	268	275	275	279
	Edh at Noon		28	31	36	40	43	46	50	49	38	32	29	26
(44) All-Sky Solar Radiation	RadAvg		958	1148	1510	1852	2036	1954	1942	1763	1546	1342	1064	834
	RadStd		57	128	137	140	120	130	116	112	127	127	76	76

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.92	+1.35	N/A	N/A	N/A	N/A	N/A	-142	+306	+216	

Nomenclature: See separate page