

JACKSONVILLE NAS, FL, USA

WMO: 722065

Lat: 30.233N

Lon: 81.667W

Elev: 20

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93837

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.3	37.9	14.3	11.4	42.1	19.3	14.5	44.5	24.8	52.8	22.6	54.0	9.7	320	0.418

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	96.0	76.6	93.9	76.3	92.1	76.0	80.3	88.0	79.4	87.5	78.5	86.5	9.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.6	148.6	83.4	77.3	142.2	82.7	76.4	137.9	82.5	43.7	87.5	42.7	87.6	41.9	86.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.9	17.0	28.2	99.1	4.4	2.6	25.0	101.0	22.4	102.5	19.9	103.9	16.7	105.8		
(5)			24.0	82.3	3.9	2.4	21.3	84.0	19.0	85.4	16.8	86.7	14.0	88.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	71.8	56.2	60.0	64.9	71.3	77.9	82.3	84.1	83.9	81.2	74.1	65.1	59.7	(6)
(7)		DBStd	11.74	9.12	8.42	7.80	6.29	4.69	3.52	2.85	2.87	3.40	6.30	7.55	9.00	(7)
(8)		HDD50	88	45	15	4	0	0	0	0	0	0	0	2	22	(8)
(9)		HDD65	906	295	179	100	21	0	0	0	0	0	11	90	210	(9)
(10)		CDD50	8045	237	296	466	640	864	970	1058	1051	937	747	456	323	(10)
(11)		CDD65	3389	22	40	97	211	399	520	593	586	487	294	93	47	(11)
(12)		CDH74	31795	77	185	550	1397	3440	5287	6689	6596	4857	2113	431	173	(12)
(13)		CDH80	11935	4	19	102	392	1272	2175	2930	2757	1687	516	64	17	(13)
(14)	Wind	WSAvg	8.3	8.2	8.4	9.2	9.1	8.9	8.0	7.5	7.6	8.3	8.5	8.5	7.9	(14)
(15)	Precipitation	PrecAvg	46.3	2.9	2.9	3.7	2.3	3.2	5.6	6.1	6.5	6.5	2.4	2.0	2.6	(15)
(16)		PrecMax	72.2	7.4	7.1	9.3	8.9	10.9	12.5	13.5	17.8	15.9	8.2	7.4	8.0	(16)
(17)		PrecMin	24.8	0.3	0.5	0.4	0.4	0.5	1.3	2.4	2.5	0.2	0.0	0.0	0.2	(17)
(18)		PrecStd	10.6	1.7	1.7	2.6	1.6	2.6	2.6	2.4	3.3	4.1	1.9	1.5	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.0	82.5	86.3	90.3	94.9	99.6	98.4	98.0	94.1	90.1	85.3	82.3	(19)
(20)			MCWB	67.7	67.9	68.5	70.3	72.8	77.1	77.2	77.7	75.6	75.5	71.9	71.0	(20)
(21)		2%	DB	76.0	79.4	82.7	87.5	92.1	95.6	95.6	94.9	91.6	87.3	81.5	78.6	(21)
(22)			MCWB	65.9	66.6	67.4	69.9	72.2	76.0	77.2	77.4	75.3	74.3	70.7	69.0	(22)
(23)		5%	DB	72.8	75.8	80.0	84.5	89.7	92.7	93.4	92.7	89.8	85.0	78.9	75.3	(23)
(24)			MCWB	64.3	64.7	66.1	68.6	71.6	75.7	76.8	77.3	75.5	73.1	69.1	67.7	(24)
(25)		10%	DB	69.8	72.4	76.8	81.7	87.0	90.0	91.3	90.7	87.9	82.9	76.0	72.2	(25)
(26)			MCWB	62.6	63.4	64.3	67.2	71.3	75.2	76.7	77.2	75.2	72.2	67.7	66.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.7	70.4	73.2	74.5	77.3	80.2	81.6	82.2	81.4	79.2	75.8	73.0	(27)
(28)			MCD B	75.8	77.4	80.0	83.6	87.8	90.8	89.9	90.1	84.8	84.1	82.0	78.6	(28)
(29)		2%	WB	68.2	68.9	70.2	72.9	75.8	78.6	80.0	80.3	79.6	77.7	73.5	71.0	(29)
(30)			MCD B	73.6	76.1	77.6	81.6	85.1	89.0	88.9	88.6	84.6	83.4	78.4	76.3	(30)
(31)		5%	WB	66.1	67.2	68.6	71.5	74.8	77.8	78.9	79.3	78.4	76.3	71.4	69.2	(31)
(32)			MCD B	70.9	73.5	75.9	79.3	83.5	87.5	87.9	87.6	84.2	81.8	75.9	73.9	(32)
(33)		10%	WB	64.0	65.2	67.1	70.2	73.6	77.0	78.1	78.4	77.5	75.0	69.6	67.2	(33)
(34)			MCD B	68.7	70.6	74.2	78.1	81.9	86.0	86.9	86.4	84.0	80.5	74.9	71.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.8	17.6	18.1	17.6	16.5	15.2	15.0	13.9	12.9	14.3	16.4	16.3	(35)
(36)			MCDBR	19.1	19.5	20.4	19.5	19.8	19.1	17.2	16.5	15.3	14.8	16.7	16.9	(36)
(37)			MCWBR	11.2	9.3	8.8	7.4	6.6	6.1	5.6	5.3	5.2	6.0	8.4	9.2	(37)
(38)		5% WB	MCD BR	16.5	17.0	17.6	16.6	16.6	16.8	15.5	14.6	12.9	12.0	13.8	15.1	(38)
(39)			MCWBR	10.8	10.1	9.2	8.1	6.6	6.0	6.0	5.6	5.5	5.6	8.1	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.337	0.349	0.372	0.394	0.436	0.478	0.505	0.490	0.428	0.400	0.360	0.345	(40)	
(41)		taud	2.529	2.502	2.445	2.369	2.290	2.235	2.163	2.212	2.381	2.426	2.487	2.531	(41)	
(42)		Ebn at Noon	284	291	290	285	272	260	252	255	268	269	273	275	(42)	
(43)		Edh at Noon	28	31	35	39	43	45	48	45	37	33	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	994	1190	1553	1893	2025	1877	1862	1738	1507	1335	1082	896	(44)	
(45)		RadStd	71	132	140	119	123	128	121	113	124	114	62	77	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (33 neighbors)		+1.04	+1.98	N/A	N/A	N/A	N/A	-139	+320	+286
		+0.77	N/A	N/A	N/A	N/A	-20	-117	+299	+211

Nomenclature: See separate page