

CECIL FIELD, FL, USA

WMO: 722067

Lat: 30.219N

Lon: 81.876W

Elev: 25

StdP: 101.03

Time Zone: -5.00 (NAE)

Period: 90-19

WBAN: 63823

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	1.1	-8.7	1.8	4.9	-5.4	2.4	6.3	9.4	14.0	8.7	15.7	1.7	320	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	35.9	24.9	34.6	24.7	33.5	24.5	26.5	32.3	26.0	31.6	25.6	31.0	3.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.3	28.2	24.6	19.6	27.9	24.1	19.0	27.6	82.3	32.1	80.3	31.7	78.4	31.1	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.5	6.7	DB	-4.2	36.7	2.5	0.9	-5.9	37.4	-7.4	38.0	-8.8	38.5	-10.5	39.2	(4)
(5)			WB	-5.9	28.0	1.9	1.0	-7.3	28.7	-8.4	29.2	-9.5	29.8	-10.9	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	13.2	14.9	17.0	19.7	23.9	26.8	28.0	27.3	25.7	21.6	17.0	13.8
	DBStd	6.41	4.75	4.82	4.58	3.61	2.60	2.27	1.44	1.44	1.94	3.24	4.74	4.97
	HDD10.0	65	22	13	7	0	0	0	0	0	0	0	3	20
	HDD18.3	638	169	115	77	29	2	0	0	0	0	11	81	155
	CDD10.0	4000	122	149	223	291	430	504	559	537	471	361	214	139
	CDD18.3	1532	10	18	36	69	174	254	301	278	221	113	42	15
	CDH23.3	13915	52	125	339	661	1701	2445	3016	2590	1846	801	251	89
CDH26.7	5851	3	18	67	186	687	1204	1508	1171	740	210	48	9	
Wind	WSAvg	2.7	2.8	3.2	3.3	3.0	2.7	2.5	2.3	2.1	2.2	2.6	2.7	2.6
Precipitation	PrecAvg	1348	83	104	92	69	93	167	181	200	152	67	54	75
	PrecMax	2006	193	320	223	269	286	337	339	432	365	215	179	187
	PrecMin	678	17	27	7	10	7	31	57	59	30	0	2	8
	PrecStd	235	48	60	59	51	64	70	76	96	88	54	41	50
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	28.5	30.4	32.4	34.3	37.5	37.4	36.0	34.5	31.7	29.9	27.9
		MCWB	20.4	20.3	20.6	22.4	22.9	24.9	25.6	24.7	24.4	23.1	23.1	21.6
	2%	DB	24.9	27.0	28.4	30.4	32.9	36.2	35.8	34.7	33.1	30.2	28.0	26.0
		MCWB	19.0	19.9	19.3	20.5	22.5	25.0	25.1	24.9	24.0	22.7	21.5	19.9
	5%	DB	22.8	24.8	27.2	28.8	31.8	34.3	34.4	33.4	32.2	28.9	26.4	23.8
		MCWB	17.9	18.1	18.8	20.2	22.2	24.4	25.0	24.9	23.9	22.2	20.6	18.5
	10%	DB	21.2	22.6	25.3	27.4	30.5	32.7	33.1	32.3	31.0	27.7	24.3	21.8
		MCWB	16.9	17.2	17.8	19.5	21.8	24.1	25.0	24.8	23.8	21.7	19.8	18.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	21.5	22.1	24.8	25.2	26.8	27.2	27.1	26.2	25.4	24.5	22.4
		MCDB	24.1	26.4	27.1	30.2	30.3	34.0	32.4	32.2	29.7	29.0	27.8	26.0
	2%	WB	20.2	20.5	21.2	22.6	24.4	25.9	26.6	26.3	25.5	24.6	23.0	21.3
		MCDB	23.7	25.0	26.2	26.4	29.5	32.7	32.4	31.5	29.8	27.9	25.6	23.9
	5%	WB	19.1	19.6	20.3	21.7	23.9	25.4	26.1	25.8	25.1	23.8	22.1	20.0
		MCDB	21.7	23.5	24.9	25.9	29.0	31.6	32.0	30.9	29.5	26.8	24.7	22.8
	10%	WB	18.0	18.5	19.3	20.8	23.2	24.9	25.6	25.3	24.6	22.8	20.9	18.5
		MCDB	20.4	21.4	23.1	25.1	28.4	30.7	31.4	30.3	29.0	25.9	23.7	21.4
Mean Daily Temperature Range	5% DB	MDBR	12.2	12.4	13.2	13.5	12.8	11.6	11.3	10.4	10.0	10.7	11.8	11.9
		MCDBR	13.1	13.4	14.7	14.0	14.0	14.0	12.7	12.0	11.8	11.4	11.7	13.1
		MCWBR	8.3	7.5	7.3	6.5	5.7	4.7	4.4	4.4	5.0	5.8	6.5	7.8
	5% WB	MCDBR	10.7	11.8	12.3	11.3	11.9	12.1	11.5	10.5	9.9	9.3	10.1	10.8
		MCWBR	7.6	7.3	7.0	5.9	5.3	4.6	4.6	4.4	4.5	5.3	6.5	6.9
Clear-Sky Solar Irradiance	taub	0.335	0.346	0.371	0.391	0.433	0.474	0.505	0.489	0.427	0.396	0.358	0.342	
	taud	2.524	2.496	2.433	2.364	2.284	2.235	2.151	2.201	2.371	2.425	2.482	2.526	
	Ebn at Noon	899	920	914	903	861	822	795	805	847	852	864	871	
	Edh at Noon	88	98	112	124	135	141	153	144	118	104	91	84	
All-Sky Solar Radiation	RadAvg	3.15	3.76	4.90	5.96	6.39	5.89	5.84	5.45	4.76	4.23	3.44	2.83	
	RadStd	0.22	0.42	0.44	0.39	0.39	0.40	0.38	0.36	0.39	0.36	0.20	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	-11	-65	+166	+117

Nomenclature: See separate page